

Client: ADOC-Izard Co
 Sample Description: NPDES Monitoring
 Sample Location: WWTP Effluent
 Permit Number: AR0044016
 References: 40 CFR Part 136 Approved Methods, Containers, Preservation, Holding Times
 Standard Methods for the Examination of Water and Wastewater: EPA-600/4-79-020
 Quality Control: Blank, duplication, known addition, quarterly analysis of external references samples
 QA Frequency: Minimum of 10% Spikes and Duplicates

Sample Number: 37704-01
 Date Reported: 8/8/2012

Grab	Composite	Date/Time Received:
Date/Time	Date/Time	07/18/12 11:52
07/18/12 0:00	07/18/12 0:00	
Sampler	Sampler	
Ryan Hudgin	Ryan Hudgin	

Parameter	Reference	Test Date/Time	Initials	Result
Basic WW				
Temperature	2550 B	7/18/2012 12:02:00 AM	RJH	33.3 degrees C
pH	4500-H+ B	7/18/2012 12:01:00 AM	RJH	7.60 pH Units
DO	4500-O c or g	7/18/2012 12:03:00 AM	RJH	6.49 mg/l
cBOD	5210 B			3.24 mg/l
TSS	2540 D			2.0 mg/l
Fecal Coliforms	9222 D			190 Col/100 mls
Ammonia, NH3-N	4500-NH3 B,C		RJH	2.30 mg/l
Nitrate Nitrogen				
Nitrate	4500 NO3 E		RJH	<1.0 mg/l

* Quality assurance performed on other samples.

Chain of custody, equipment calibration and maintenance records, and QA/QC information are on file at the laboratory.



Bill Miles, Laboratory Manager

Kathy Tankersley

Arkansas Department of Correction
7800 Correction Circle
Pine Bluff, Arkansas 71603

720 721 72114S S4-16


PSRT FIRST-CLASS MAIL
US POSTAGE PAID
Little Rock, AR
PERMIT 700



4077120814-111015

RETURN SERVICE REQUESTED

72118



A D E Q

NPDES Enforcement Branch

5301 Northshore Drive

North Little Rock, AR

72118-5312