

ADEQ FAX 501 682-0880

SANITARY SEWER OVERFLOW (SSO) 24 HR REPORT

Name of Facility: City of Newport	Phone: 870 523-8121
NPDES Permit No: A 80037044 45225	
Date SSO Began: 4-8-21	Time SSO Began: 9:30 am
Date SSO Ended: 4-8-21	Time SSO Ended: 10:30 am
Address of SSO Corner of Lowe and Lee	
Receiving Stream	

Description Manhole Overflow
 Lift Station
 Main Line Overflow
 Service Line Overflow
 Other - Describe _____

Estimated Volume 500 Gallon

Cause of SSO - Check all that apply

- I and I - Rainfall
 Roots
 Grease
 Debris
 Equipment Failure
 Construction
 Vandalism
 Other - Describe _____

Action Taken - Check all that apply

- Machine rodded
 Jet-Vac
 Root Saw
 Hand Rodded
 Disinfected and Deodorized
 Spread Lime on Affected Area
 Other - Describe remove masonite siding out of MH on Center Drive

Environmental Impact

- NEAH - No Evidence of Adverse Health/Environmental Impact
 OEHC - Observed or Evidence of Human Contact
 EFK - Evidence of Fish Kill

Signature: Martin Stenard Date: 4-8-21