

THE CITY OF NEWPORT
WASTEWATER TREATMENT PLANT
615 THIRD STREET
FACILITY LOCATION
121 HIGHWAY 17 SOUTH
NEWPORT, ARKANSAS 72112
PHONE: (870) 523-8121
FAX: (870) 523-8214

16 November 2020

ADEQ
Enforcement Branch.
5301 Northshore Drive
North Little Rock, AR 72118-5317

Re: NPDES Permit AR0045225 AFIN: 34-00061
Non compliance report for October 2020

Date	Parameter	Outfall	Units	Permit Limit	Violation
10-30-20	Oil & Grease Daily Max	001	mg/L	15	17
Oct 2020	Oil & Grease Monthly Average	001	Mg/L	10	17

The huge rain during the last week of October made discharge from the facility necessary to prevent the aeration basin overflowing. The sample day was at the beginning of discharge and it is thought the high oil and grease was due to contamination of the chlorine contact chamber.

Sincerely,



Superintendent WWTP

cc: David Stewart, Mayor