

ADEQ FAX 501 682-0880

SANITARY SEWER OVERFLOW (SSO) 24 HR REPORT

Name of Facility: City of Newport	Phone: 870 523-8121
NPDES Permit No: AR 0045225	
Date SSO Began: 1-25-2020	Time SSO Began: 5:00 PM
Date SSO Ended: 1-25-2020	Time SSO Ended: 6:00 PM
Address of SSO 8200 Theatre Drive at Treatment Plant	
Receiving Stream Village creek	

- Description
- Manhole Overflow
 - Lift Station
 - Main Line Overflow
 - Service Line Overflow
 - Other - Describe Chlorine Contact Chamber overflow

Estimated Volume 1000 Gallon

Cause of SSO - Check all that apply

- I and I - Rainfall
- Roots
- Grease
- Debris
- Equipment Failure
- Construction
- Vandalism
- Other - Describe Belt broke on pump

Action Taken - Check all that apply

- Machine rodded
- Jet-Vac
- Root Saw
- Hand Rodded
- Disinfected and Deodorized
- Spread Lime on Affected Area
- Other - Describe Wash down area

Environmental Impact

- NEAH - No Evidence of Adverse Health/Environmental Impact
- OEHC - Observed or Evidence of Human Contact
- EFK - Evidence of Fish Kill

Signautre: Martin Steward

Date: 1-27-20