THE CITY OF NEWPORT WASTEWATER TREATMENT PLANT 615 THIRD STREET FACILITY LOCATION 121 HIGHWAY 17 SOUTH NEWPORT, ARKANSAS 72112

PHONE: (870) 523-8121 FAX: (870) 523-8214

20 January 2015

ADEQ Water Division 5301 Northshore Drive North Little Rock, AR 72118-5317

Re: Non compliance report for City of Newport Airbase Industrial Park

NPDES Permit AR0045225

Date	Parameter	Outfall	Units	Permit Limit	Violation
12/2014	CBOD 30 Day Average	001-A	Mg/L	10	20.1
12/1/8/2014	CBOD 7- Day Average	001-A	mg/L	15	16.5
12/15/2014	CBOD 7- Day Average	001-A	mg/L	15	28.4
12/22/2014	CBOD 7- Day Average	001-A	mg/L	15	26.1
12-2014	TSS 30 Day Average	001-A	Mg/L	15	34.8
12/8/2014	TSS 7 - Day Average	001-A	mg/L	22.5	29
12/15/2014	TSS 7- Day Average	001-A	Mg/L	22.5	44
12/22/2014	TSS 7 Day Average	001-A	Mg/L	22.5	57
12/1/2014	Ammonia Nitrogen 7 Day Average	001-A	Mg/L	9	15

Cold weather in November and December upset the settleability of the water. Unsuccessful attempt of varying sludge return and wasting did not produce acceptable water so discharge was diverted to the main plant until settleability improves.

Steward 1-20-15

Sincerely,

Martin Steward Superintendent WWTP

cc: David Stewart, Mayor

Sanitary Sewer Overflow Monthly Report

Facility Name: City of Newfort Permit Number: AR0045225 Reporting Period (Month/Year): December 2014

Aispert Industrial Park 12 No Sanitary Sewer Overflows This Monitoring Period

•		Summary Report Code Descr	iptions		
Cause(s) of SSO		SSO Impact	Action(s) Taken	Ultimate Discharge Location	
CO-Construction	D-Debris	NEAH-No Evidence of Adverse Health or Environmenta Impact	WO-Work Order	CR-Creek/Stream/River (please specify)	
#E-Equipment Failure HC-Hydro Clean	G-Grease	OEHC-Observed or Evidence of Human Contact EFK-Evidence of Fish Kill	EC-Environmental Cleanup HC-Hydro Cleaned	DÎ Ditch	
110 11, 40 0104	Failure/Break		no-riyuto cicanci	DR-Drop Inlet	
R-Rainfall	RG-Roots & Grease		HR-Hand Rodded	GR-Ground Surface	
RO-Roots	V-Vandalism .		EN-Referred to Engineering	PA-Paved Area	
	<u> </u>		PN-Public Notification	CB-Contained in Building	

Location		Manhole#	Start Date of SSO	End Date of SSO	Estimated Volume (in gallons)	Cause of SSO	Environmental Impact	Action (s) Taken to Address SSO	Ultimate Discharge Location
		_		· .					
									· · ·
						:		· ·	
						7.	<u> </u>		
							·····		
							:		
									
					·				
									-
								•	
					<u> </u>				
,					<u> </u>				
·	-01	1/1/)	1/)		1.			
	_{{\\ }	1 21 /11	1 1 1 1 1 1 1	d /	<u></u>	L	1 ~		
	:////		Terran	<i>.</i>		•	1-8-1	15	

Signature of Cognizant or Ranking Official

Date

[&]quot;I certify under penalty of law that this document and all attachments were prepared under my direction or supervision in accordance with a system designed to assure that qualified personnel properly gather and evaluate the information submitted. Based on my inquiry of the person or persons who manage the system, or those persons directly responsible for gathering the information, the information submitted is, to the best of my knowledge and belief, true, accurate, and complete. I am aware that there are significant penalties for submitting false information, including the possibility of fine and imprisonment for knowing violations."