

City of ^{Newport} Sanitary Sewer Overflow (SSO) Monthly Report

Facility Name: Airport Industrial Park NPDES Permit No. AR0045225 Monitoring Period (Month/Year): July 2015

No Sanitary Sewer Overflows This Monitoring Period

Summary Report Code Descriptions				
Cause(s) of SSO		SSO Impact	Action(s) Taken	Ultimate Discharge Location
CO-Construction	D-Debris	NEAH-No Evidence Adverse Health/ Environmental Impact		CR-Creek/Stream/River (specify)
E-Equipment Failure	G-Grease	OEHC-Observed or Evidence of Human Contact	EC-Environmental Cleanup	DI-Ditch
HC-Hydro Clean	LF-Line Failure	EFK-Evidence of Fish Kill	HC-Hydro Cleaned	DR-Drop Inlet
R-Rainfall	RG-Roots / Grease		HR-Hand Rodded	GR-Ground Surface
RO-Roots	V-Vandalism		EN-Referred to Engineering	PA-Paved Area
			PN-Public Notification	CB-Contained in Building

Location	Manhole #	Start Date of SSO	End Date of SSO	Estimated Volume (in gallons)	Cause of SSO	Environmental Impact	Action (s) Taken to Address SSO	Discharge Location

Matthew Steward

7-21-15

Signature of Cognizant or Ranking Official

Date

I certify under penalty of law that this document and all attachments were prepared under my direction or supervision in accordance with a system designed to assure that qualified personnel properly gather and evaluate the information submitted. Based on my inquiry of the person or persons who manage the system, or those persons directly responsible for gathering the information, the information submitted is, to the best of my knowledge and belief, true, accurate, and complete. I am aware that there are significant penalties for submitting false information, including the possibility of fine and imprisonment for knowing violations."

THE CITY OF NEWPORT
WASTEWATER TREATMENT PLANT
615 THIRD STREET
FACILITY LOCATION
121 HIGHWAY 17 SOUTH
NEWPORT, ARKANSAS 72112
PHONE: (870) 523-8121
FAX: (870) 523-8214

21 July 2015

ADEQ
Water Division
5301 Northshore Drive
North Little Rock, AR 72118-5317


Re: Non compliance report for City of Newport Airbase Industrial Park
NPDES Permit AR0045225 for June 2015

Date	Parameter	Outfall	Units	Permit Limit	Violation
6/2015	TSS 30 Day Average	001-A	Mg/L	15	21
6/4/2015	TSS 7 - Day Average	001-A	mg/L	22.5	71
6/8/2015	DO Instantaneous Minimum	001-A	Mg/L	5	4.6

A settling upset occurred in the clarifier during the sampling period causing TSS violation.
The upset was corrected by the next sampling event.

Post aeration rate was increased to correct low DO in effluent.

Sincerely,



Martin Stewart
Superintendent WWTP

cc: David Stewart, Mayor

2015 07 21 10:00 AM
NEWPORT WASTEWATER TREATMENT PLANT
615 THIRD STREET
NEWPORT, ARKANSAS 72112
PHONE: (870) 523-8121
FAX: (870) 523-8214