

THE CITY OF NEWPORT  
WASTEWATER TREATMENT PLANT  
615 THIRD STREET  
FACILITY LOCATION  
121 HIGHWAY 17 SOUTH  
NEWPORT, ARKANSAS 72112  
PHONE: (870) 523-8121  
FAX: (870) 523-8214

16 December 2014

ADEQ  
Water Division  
5301 Northshore Drive  
North Little Rock, AR 72118-5317

Re: Non compliance report for November 2014  
NPDES Permit AR0045225

Date	Parameter	Outfall	Units	Permit Limit	Violation
11/12/2014	CBOD 7 Day Average	001-A	mg/L	15	15.2

Nitrification problems are beginning to occur due to cool water temperatures affecting CBOD removal. CBOD was back within permit limit for the remainder of the month.

Sincerely,



Martin Steward  
Superintendent WWTP

cc: David Stewart, Mayor

