

THE CITY OF NEWPORT  
WASTEWATER TREATMENT PLANT  
615 THIRD STREET  
FACILITY LOCATION  
121 HIGHWAY 17 SOUTH  
NEWPORT, ARKANSAS 72112  
PHONE: (870) 523-8121  
FAX: (870) 523-8214

22 May 2013


ADEQ  
Water Division  
5301 Northshore Drive  
North Little Rock, AR 72118-5317

Re: Non compliance report for April 2013  
NPDES Permit AR0045225

Date	Parameter	Outfall	Units	Permit Limit	Violation
April 2013	TSS 30 Day Average	001A	mg/L	15	16.5

The above listed violation occurred during initial start up of discharge after an extended period of plant shut down. All parameters were back in compliance by the next sample event.

Sincerely,



5-22-13

Superintendent WWTP

cc: David Stewart, Mayor