

THE CITY OF NEWPORT
WASTEWATER TREATMENT PLANT
615 THIRD STREET
FACILITY LOCATION
121 HIGHWAY 17 SOUTH
NEWPORT, ARKANSAS 72112
PHONE: (870) 523-8121
FAX: (870) 523-8214

21 January 2014

ADEQ
Water Division
5301 Northshore Drive
North Little Rock, AR 72118-5317

Re: Non compliance report for December 2013
NPDES Permit AR0045225

Date	Parameter	Outfall	Units	Permit Limit	Violation
12 - 2013	TSS Monthly Average	001-A	mg/L	15	19.5
12-31- 2013	TSS 7 Day Average	001-A	mg/L	22.5	28

Nitrification process was upset by cold weather in December causing poor settling in the clarifier. Effluent discharge was diverted to the main plant until the nitrification process is back to normal.

Sincerely,



Martin Steward
Superintendent WWTP

cc: David Stewart, Mayor

NEWPORT (870) 523-8121
FACILITY LOCATION
121 HIGHWAY 17 SOUTH
NEWPORT, ARKANSAS 72112
PHONE: (870) 523-8121
FAX: (870) 523-8214

The City Of Newport
Wastewater Treatment Plant
615 Third Street
Newport, AR 72112

LITTLE ROCK AR 722

21 JAN 2014 PM 1 P



ZIP 72112
041L10225043

ARKANSAS DEPT OF ENVIRONMENTAL QUALITY
NPDES ENFORCEMENT SECTION
5301 NORTSHORE DRIVE
NORTH LITTLE ROCK, AR 72118-5317

721185317

