Sanitary Sewer Overflow (SSO) Monthly Report

Facility Name: City of Newport Airport Industrial Park **NPDES Permit No.:** AR0045225 **Monitoring Period (Month/Year):** Sept 2015

☒ No Sanitary Sewer Overflows This Monitoring Period

Summary Report Code Descriptions				
Cause(s) of SSO		**SSO Impact**	**Action(s) Taken**	**Ultimate Discharge Location**
CO-Construction	D-Debris	NEAH-No Evidence Adverse Health/ Environmental. Impact		CR-Creek/Stream/River (specify)
E-Equipment Failure	G-Grease	OEHC-Observed or Evidence of Human Contact	EC-Environmental Cleanup	DI-Ditch
HC-Hydro Clean	LF-Line Failure	EFK-Evidence of Fish Kill	HC-Hydro Cleaned	DR-Drop Inlet
R-Rainfall	RG-Roots / Grease		HR-Hand Rodded	GR-Ground Surface
RO-Roots	V-Vandalism		EN-Referred to Engineering	PA-Paved Area
			PN-Public Notification	CB-Contained in Building

Location	Manhole #	Start Date of SSO	End Date of SSO	Estimated Volume (in gallons)	Cause of SSO	Environmental Impact	Action (s) Taken to Address SSO	Discharge Location

Matt Leonard 10-16-15

Signature of Cognizant or Ranking Official **Date**

I certify under penalty of law that this document and all attachments were prepared under my direction or supervision in accordance with a system designed to assure that qualified personnel properly gather and evaluate the information submitted. Based on my inquiry of the person or persons who manage the system, or those persons directly responsible for gathering the information, the information submitted is, to the best of my knowledge and belief, true, accurate, and complete. I am aware that there are significant penalties for submitting false information, including the possibility of fine and imprisonment for knowing violations."