

NON-COMPLIANCE REPORT

Arkansas Department of Environmental Quality
Office of Water Quality – Enforcement Branch
5301 Northshore Drive
North Little Rock, AR 72118

RE: Permit No: AR0047384 Discharge Number: 001

Facility: Canfor Southern Pine/Anthony Forest Products Company - Urbana Sawmill

Address: 1236 Urbana Rd

City: Urbana State: AR Zip: 71768

Contact: Phil Witter Phone: 251-452-7174

Date of Non-Compliance	Parameter Exceeded	Quantity or Loading	Quality or Concentration	Permit Limits
June 22, 2023	Oil and Grease	--	223	10 / 15

We feel this problem was due to:

The sampler saw no indication of oil and grease during sampling, and there was no unusual activity at the facility. A sample collected the prior day was non-detect for oil and grease. Since January 2020 only 5 of 77 samples had a detection and the highest prior to this result was 41 mg/L. Other detections ranged from 5.6 to 8.6 mg/L. We believe this was a laboratory error.

We plan on correcting the problem in this manner:

We believe this is a laboratory error. Will confirm O&G in July sampling events when results are received.

Time estimated that it will take to correct problem:

Not applicable.

Sincerely,

Phil Witter

July 24, 2023

Submitted By:

Date

Submitted electronically via NetDMR

Certification Statement: I certify under penalty of law that this document and all attachments were prepared under my direction or supervision in accordance with a system designed to assure that qualified personnel properly gather and evaluate the information submitted. Based on my inquiry of the person or persons who manage the system, or those persons directly responsible for gathering the information, the information submitted is, to the best of my knowledge and belief, true, accurate, and complete. I am aware that there are significant penalties for submitting false information, including the possibility of fine and imprisonment for knowing violations. (Revised March 2016)