

# NON-COMPLIANCE REPORT

Arkansas Department of Environmental Quality  
Office of Water Quality – Enforcement Branch  
5301 Northshore Drive  
North Little Rock, AR 72118

RE: Permit No: AR0047384 Discharge Number: 001

Facility: Canfor Southern Pine/Anthony Forest Products Company - Urbana Sawmill

Address: 1236 Urbana Rd

City: Urbana State: AR Zip: 71768

Contact: Phil Witter Phone: 251-452-7174

Date of Non-Compliance	Parameter Exceeded	Quantity or Loading	Quality or Concentration	Permit Limits
March 3, 2021	Total Suspended Solids		50 / 66	35 / 53
March 3, 2021	Dissolved oxygen		1.85	<2

We feel this problem was due to:

~~Evidence of significant spring pollen bloom was present and affected the TSS results.~~

We plan on correcting the problem in this manner:

~~The TSS results for 3/15/21 and 4/12/21 have declined to 34 and 44 mg/L, respectively. DO readings for 3/15/21, 4/6/21, and 4/12/21 ranged between 2.53 and 6.47 mg/l~~

Time estimated that it will take to correct problem:

~~Self correcting natural condition.~~

Sincerely,

Phil Witter

APRIL 22, 2021

Submitted By:

Date

Submitted electronically via NetDMR

**Certification Statement:** I certify under penalty of law that this document and all attachments were prepared under my direction or supervision in accordance with a system designed to assure that qualified personnel properly gather and evaluate the information submitted. Based on my inquiry of the person or persons who manage the system, or those persons directly responsible for gathering the information, the information submitted is, to the best of my knowledge and belief, true, accurate, and complete. I am aware that there are significant penalties for submitting false information, including the possibility of fine and imprisonment for knowing violations. (Revised March 2016)