

# NON-COMPLIANCE REPORT

Arkansas Department of Environmental Quality  
Office of Water Quality – Enforcement Branch  
5301 Northshore Drive  
North Little Rock, AR 72118

RE: Permit No: AR0047384 Discharge Number: 001

Facility: Canfor Southern Pine/Anthony Forest Products Company - Urbana Sawmill

Address: 4337 Lawson Road

City: El Dorado State: AR Zip: 71730

Contact: Phil Witter Phone: 251-452-7174

Date of Non-Compliance	Parameter Exceeded	Quantity or Loading	Quality or Concentration	Permit Limits
January 26, 2024	Total Suspended Solids	--	95	35 / 53

We feel this problem was due to:

~~Excessive rainfall (approximately 7 inches) at the facility.~~

We plan on correcting the problem in this manner:

~~No correction necessary.~~

Time estimated that it will take to correct problem:

~~Not applicable.~~

Sincerely,

Phil Witter

February 8, 2024

Submitted By:

Date

Submitted electronically via NetDMR

**Certification Statement:** I certify under penalty of law that this document and all attachments were prepared under my direction or supervision in accordance with a system designed to assure that qualified personnel properly gather and evaluate the information submitted. Based on my inquiry of the person or persons who manage the system, or those persons directly responsible for gathering the information, the information submitted is, to the best of my knowledge and belief, true, accurate, and complete. I am aware that there are significant penalties for submitting false information, including the possibility of fine and imprisonment for knowing violations. (Revised March 2016)