

**NPDES Permit No. AR0047384**  
**Anthony Forest Products - Urbana**  
**Noncompliance Report**  
**June 2016**

All parameters were within permit limitations with the exception of fecal coliform and TSS at Outfall 001. Both monthly samples were collected during a discharge on June 16, 2016. Both the 7-day geometric mean limit of 2,000 # /100 ml and 30-day geometric mean limit of 1,000 #/100ml were exceeded with a result of 15,875 #/100 ml. The TSS monthly average value of 35 mg/L and monthly daily maximum value of 53 mg/L were exceeded with results of 51 mg/L and 54 mg/L, respectively.

As a result of the elevated fecal, Anthony Forest Products and their environmental consultants GBMc & Associates continue to conduct site investigations to try to locate the source of the fecal coliform. In addition, the sanitary treatment system has been cleaned and maintenance will be carried out on a monthly basis as part of the evaluation process. We will continue to monitor and evaluate the sanitary sewer treatment system in an effort to maintain permit compliance. The exceedance of TSS was likely a result of the 2-inch rainfall that occurred 2 days prior to the sampling date. Anthony Forest Products will continue to monitor TSS in an effort to maintain permit compliance.