



• P.O. BOX 724 • PHONE (870) 962-3291 • STRONG, AR 71765

Reply to:
URBANA DIVISION
P.O. BOX 724
STRONG, AR 71765

December 22, 2015

Arkansas Department of Environmental Quality
ADEQ Water Division – NPDES Enforcement Section
Attention: Enforcement Administrator
5301 Northshore Drive
North Little Rock, AR 72118-5317

Re: DMR Submittal / Noncompliance Report – NPDES Permit No. AR0047384 - Anthony Forest Products - Urbana

To Whom It May Concern:

Please find enclosed two sets (original & copy) of our monthly (November 1, 2015 – November 30, 2015) Discharge Monitoring Reports for the above referenced permit. All parameters were within permit limitations with the exception of fecal coliform at Outfall 001. Both monthly samples were collected during a discharge on November 17, 2015. Both the 7-day geometric mean limit of 2,000 #/100 ml and 30-day geometric mean limit of 1,000 #/100ml were exceeded with a result of 19500 #/100 ml.

As a result of the elevated fecal, Anthony Forest has hired a new licensed wastewater treatment operator employed by Crawford Plumbing to evaluate the treatment system and make recommendations. In addition, the sanitary treatment system has been cleaned and maintenance will be carried out on a monthly basis as part of the evaluation process. We will continue to monitor and evaluate the wastewater treatment system in an effort to maintain permit compliance.

If you have any questions about this report, please do not hesitate to contact me at 870-962-3261 or Kyle Hathcote at 501-847-7077.

Sincerely,
Anthony Forest Products


Stephen Murphy
General Manager

Enclosure: