

P.O. BOX 724 • PHONE (870) 962-3291 • STRONG, AR 71765

Reply to: URBANA DIVISION P.O. BOX 724 STRONG, AR 71765

October 20; 2014

Arkansas Department of Environmental Quality
ADEQ Water Division – NPDES Enforcement Section
Attention: Enforcement Administrator
5301 Northshore Drive
North Little Rock, AR 72118-5317

Re:

DMR Submittal / Noncompliance Report - NPDES Permit No. AR0047384 - Anthony Forest

Products - Urbana Mill

To Whom It May Concern:

Enclosed you will find two sets (original & copy) of our monthly (September 1, 2014 – September 30, 2014) Discharge Monitoring Reports for the above referenced permit. All parameters were within permit limitations except for monthly Dissolved Oxygen (DO) at Outfall 001. On September 3, 2014 a leak was discovered in our boards used to "block-in" our wet deck recirculation pond. This leak caused existing rain water that had been sitting stagnant in culverts and the outlet structure to be discharged via Outfall 001. The DO of this water when measured was 0.40 mg/L and 0.33 mg/L. The leak was fixed on September 4, 2014 and the discharge stopped. To avoid this from happening in the future, any rain water that collects in the culverts and outlet structure will be pumped back into our wet deck recirculation pond. We will continue to evaluate the wastewater treatment system in an effort to maintain permit compliance.


Please do not hesitate to contact me at (870) 962-3206 or Kyle Hathcote with GBM^c & Associates (501-847-7077) should you have any questions or need additional information.

Sincerely, Sincerely,

Anthony Forest Products

Stephen Murphy General Manager

Enclosure:





P.O. Box 724 Strong, AR 71765





Arkansas Department of Environmental Quality ADEO Water Division - NPDES Enforcement Section

Attention: Enforcement Administrator

5301 North Shore Drive

North Little Rock, AR 72118-5317