

ADEQ

ARKANSAS
Department of Environmental Quality

August 23, 2012

William King
P.O. Box 2008
Texarkana, AR 75504

RE: NPDES Permit Number: AR0048691 AFIN: 46-00237
Texarkana WWTP - North

Dear Mr. King,

A review of the NPDES file for the above mentioned facility for the period of January 2009 through June 2012 reveals the following compliance issues:

The facility has reported **3 effluent violations** of Part I, Section A. of NPDES Permit No. AR0048691:

Discharge Number	Parameter	DMR Value	Limit Value	DMR End Date
001-A	Oxygen, dissolved (DO), INST MIN, mg/L	5.5	7.	04/30/2012
001-A	Solids, total suspended, 7 DA AVG, mg/L	25	22.5	03/31/2012
001-A	Flow, in conduit or thru treatment plant, 7 DA AVG, ft	0.98	.95	12/31/2009

Any violation of your NPDES Permit is subject to enforcement action by this Department, pursuant to the Arkansas Water and Air Pollution Control Act. The regulations and your NPDES Permit require that you take all reasonable measures necessary to eliminate or prevent the occurrence of violations. Also, be aware that we maintain records of violations and of non-compliance reports documenting corrective action to determine the appropriateness and level of the enforcement action.

Should you have any questions concerning the above referenced compliance issues, please feel free to contact me at 501-682-0636, or you may e-mail me at copenhaver@adeq.state.ar.us.

Sincerely,



Lindsay Copenhaver
Enforcement Analyst
Water Division, Enforcement Branch