

# NON-COMPLIANCE REPORT

Arkansas Department of Environmental Quality  
Office of Water Quality – Enforcement Branch  
5301 Northshore Drive  
North Little Rock, AR 72118

RE: Permit No: AR0048691 Discharge Number: 001-A

Facility: North Texarkana WWTP

Address: 8301 N. Sanderson Lane

City: Texarkana State: AR Zip: 71854

Contact: J. D. Phillips, Executive Director Phone: (903) 798-3821

Date of Non-Compliance	Parameter Exceeded	Quantity or Loading	Quality or Concentration	Permit Limits
02/21/21 - 02/27/21	Flow, Daily Max, 7 day average	1.11	MGD	0.95

We feel this problem was due to:

~~Five days after an 18" snow event, the plant was hit with over 5" of rain.~~

We plan on correcting the problem in this manner:

~~The Utility's I & I division is working to locate any problems~~

Time estimated that it will take to correct problem:

~~Ongoing~~

Sincerely,

  
\_\_\_\_\_  
Submitted By:

04/05/2021  
\_\_\_\_\_  
Date

Submitted electronically via NetDMR

**Certification Statement:** I certify under penalty of law that this document and all attachments were prepared under my direction or supervision in accordance with a system designed to assure that qualified personnel properly gather and evaluate the information submitted. Based on my inquiry of the person or persons who manage the system, or those persons directly responsible for gathering the information, the information submitted is, to the best of my knowledge and belief, true, accurate, and complete. I am aware that there are significant penalties for submitting false information, including the possibility of fine and imprisonment for knowing violations. (Revised March 2016)