

NON-COMPLIANCE REPORT

Arkansas Department of Environmental Quality
Office of Water Quality – Enforcement Branch
5301 Northshore Drive
North Little Rock, AR 72118

RE: Permit No: AR0048691 Discharge Number: 001-A
Facility: North Texarkana WWTP
Address: 8301 N. Sanderson Lane
City: Texarkana State: AR Zip: 71854
Contact: J.D. Phillips, Executive Director Phone: (903) 798-3821

Date of Non-Compliance	Parameter Exceeded	Quantity or Loading	Quality or Concentration	Permit Limits
06/10/20	Fecal coliform, 7 day geo	2419	# /100 mL	400

We feel this problem was due to:

Two U.V. light modules malfunctioned caused by bad relay and bad power source.

We plan on correcting the problem in this manner:

Repairs were quickly made

Time estimated that it will take to correct problem:

Same day repairs

Sincerely,



07/09/2020

Submitted By:

Date

Submitted electronically via NetDMR

Certification Statement: I certify under penalty of law that this document and all attachments were prepared under my direction or supervision in accordance with a system designed to assure that qualified personnel properly gather and evaluate the information submitted. Based on my inquiry of the person or persons who manage the system, or those persons directly responsible for gathering the information, the information submitted is, to the best of my knowledge and belief, true, accurate, and complete. I am aware that there are significant penalties for submitting false information, including the possibility of fine and imprisonment for knowing violations. (Revised March 2016)