

Sanitary Sewer Overflow Monthly Report


Facility Name: City of Texarkana - North WWTP Permit Number: AR0048691 Reporting Period (Month/Year): February 2016

No Sanitary Sewer Overflows This Monitoring Period

Date	Starting Time	Ending Time	Location	Estimated Volume (Gals)	Cause of Overflow	Environmental Impact	Action Taken	Ultimate Discharge Location
02/28/2016	9:18 am	11:10 am	2416 Laurel St., Texarkana	200	Grease	NEAH	TR, WO	GR
11/10/2016	8:40 am	9:16 am	E. 22 nd & Senator, Texarkana	50	Unknown	NEAH	TR, WO	GR
11/18/2016	11:20 am	12:20 am	330 Pinehurst, Texarkana	100	Grease	NEAH	TR, WO	GR

Summary Report Code Descriptions				
Cause(s) of SSO		SSO Impact	Action(s) Taken	Ultimate Discharge Location
CO - Construction	D - Debris	NEAH - No Evidence of Adverse Health or Environmental Impact	WO - Work Order	CR - Creek/Stream/River (Please specify)
E - Equipment Failure	G - Grease	OEHC - Observed or Evidence of Human Contact	EC - Environmental Cleanup	DI - Ditch
RO - Roots	V - Vandalism	EFK - Evidence of Fish Kill	HC - Hydro Cleaned	DR - Drop Inlet
LB - Line Break	U - Unknown		TR - Treated with Enzymes	GR - Ground Surface
			EN - Referred to Engineering	PA - Paved Area
			PN - Public Notification	CB - Contained in Building

Signature of Cognizant or Ranking Official



Date March 9, 2016

"I certify under penalty of law that this document and all attachments were prepared under my direction or supervision in accordance with a system designed to assure that qualified personnel properly gather and evaluate the information submitted. Based on my inquiry of the person or persons who manage the system, or those persons directly responsible for gathering the information, the information submitted is, to the best of knowledge and belief, true, accurate, and complete. I am aware that there are significant penalties for submitting false information, including the possibility of fine and imprisonment for knowing violations".

CERTIFIED MAIL™



7013 2250 0000 9172 3116



1000




72118

U.S. POSTAGE
PAID
TEXARKANA, AR
71854
MAR 14, 16
AMOUNT

\$7.45

R2305E125002-15



Texarkana Water Utilities

801 Wood Street, P.O. Box 2008
Texarkana, Texas 75504

Arkansas Department of
Environmental Quality
NPDES Enforcement Section
5301 N. Shore Dr.
North Little Rock, AR 72118-5317

