

ADEQ

ARKANSAS
Department of Environmental Quality

November 18, 2011

Mr. Isaac Keeling
City of Clinton
P.O. Box 277
Clinton, AR 72031

RE: NPDES Permit Number AR0048836, AFIN 71-00018
NPDES Permit Effluent Violations

Dear Mr. Keeling:

A recent review of the above referenced NPDES permit has revealed the following violations for the monitoring period ending **September 30, 2011**.

DISCHARGE NUMBER	PARAMETER	VIOLATION	LIMIT	UNITS
001A	Total Ammonia Nitrogen (MO AVG)	<22.2	21.0	lb/d
001A	Total Ammonia Nitrogen (MO AVG)	<4.45	2.1	mg/L
001A	Total Ammonia Nitrogen (7DA AVG)	5.9	5.3	mg/L

As you know, Arkansas Pollution Control and Ecology Commission regulations and your NPDES Permit require you to take all reasonable measures necessary to eliminate or prevent the occurrence of violations. Please note that any violation of your permit can lead to enforcement action by ADEQ pursuant to the Arkansas Water and Air Pollution Control Act. Also, be aware that we maintain records of violations and of non-compliance reports documenting corrective action to determine the appropriateness and level of the enforcement action.

Thank you for your attention to this matter. Should you have any questions, feel free to contact me at 501-682-0632 or e-mail at bolenbaugh@adeq.state.ar.us.

Thank you,



Jason R. Bolenbaugh
Enforcement Analyst
Water Division Enforcement Branch