

ADEQ

ARKANSAS
Department of Environmental Quality

August 15, 2013

Isaac Keeling
City of Clinton
P.O. Box 277
Clinton, AR 72031

RE: NPDES Permit Number AR0048836, AFIN 71-00018

Dear Mr. Keeling:

A recent review of the NPDES file for the **City of Clinton-East** has revealed the following violations for the monitoring period ending **2/28/2013** and **3/31/2013**.

DISCHARGE NUMBER	PARAMETER	VIOLATION	LIMIT	DATE
001A	Oxygen, dissolved [DO], INST MIN, mg/L	6.5	7	2/28/2013
001A	Oxygen, dissolved [DO], INST MIN, mg/L	6.2	7	3/31/2013

As you know, Arkansas Pollution Control and Ecology Commission regulations and your NPDES Permit require you to take all reasonable measures necessary to eliminate or prevent the occurrence of violations. Please note that any violation of your permit can lead to enforcement action by ADEQ pursuant to the Arkansas Water and Air Pollution Control Act. Also, be aware that we maintain records of violations and of non-compliance reports documenting corrective action to determine the appropriateness and level of the enforcement action.

Thank you for your attention to this matter. Please refer to NPDES Permit Number **AR0048836** and AFIN **71-00018** in any written correspondence to ADEQ. Should you have any questions, feel free to call 501-682-0667 or e-mail bolenbaughm@adeq.state.ar.us.

Sincerely,



Michelle Bolenbaugh
Enforcement Analyst
Water Division Enforcement Branch