



ARKANSAS ENERGY & ENVIRONMENT

March 3, 2023

Honorable Richard McCormac, Mayor
City of Clinton
P.O. Box 277
Clinton, AR 72031

email: clintonmayor@artelco.com

**RE: Permit Number: AR0048836, AFIN: 71-00018
Effluent Violation Warning Letter**

Dear Mayor McCormac:

A review of the Permit file for the above mentioned facility for the period of October 1, 2022 through January 31, 2023 reveals the following compliance issues:

The facility has reported **5 effluent violations** of Part I Section A of Permit No. AR0048836

DMR End Date	Disch-Desig	Parameter Desc	Reported DMR Value	Limit Value	Vio %	Vio Code
11/30/2022	001-A	Cadmium, total recoverable (MO AVG, lb/d)	<17.88	.02	89,300%	Numeric Vio
11/30/2022	001-A	Coliform, fecal general (7 DA GEO, #/100mL)	2419.6	2000	21%	Numeric Vio
12/31/2022	001-A	Cadmium, total recoverable (MO AVG, lb/d)	64.68	.02	323,300%	Numeric Vio
12/31/2022	001-A	Cadmium, total recoverable (MO AVG, ug/L)	8.28	2.01	312%	Numeric Vio
12/31/2022	001-A	Cadmium, total recoverable (7 DA AVG, ug/L)	8.28	4.02	106%	Numeric Vio

Should you have any questions concerning the above referenced compliance issues, please feel free to contact me at 501-682-0736, or you may e-mail me at thomas.harrington@adeq.state.ar.us.

Sincerely,

Thomas Harrington
Enforcement Analyst, DEQ, OWQ

5301 Northshore Drive, North Little Rock, AR 72118

cc: Jackie Hinchey, Manager clintonwater9@gmail.com