



# ARKANSAS

## ENERGY & ENVIRONMENT

April 26, 2021

Honorable Richard McCormac, Mayor  
City of Clinton  
P.O. Box 277  
Clinton, AR 72031

RE: NPDES Permit Number AR0048836, AFIN 71-00018  
Permitted Effluent Limitation Violations

Dear Mayor McCormac,

A review of recent Discharge Monitoring Reports (DMRs) for the above-mentioned facility revealed the following compliance issues:

The facility has reported 4 violations of Part I, Section A of NPDES Permit No. AR0048836 during the review period. DEQ requires the City of Clinton to work toward preventing violations of the Part I, Section A., Effluent Limitations and Monitoring Requirements of the Permit.

Any violation of your NPDES Permit is subject to enforcement action by this Department, pursuant to the Arkansas Water and Air Pollution Control Act. The regulations and your NPDES Permit require that you take all reasonable measures necessary to eliminate or prevent the occurrence of violations.

Should you have any questions concerning the above referenced compliance issues, please feel free to contact me at 501-682-0667, or you may e-mail me at [gavin.gray@adeq.state.ar.us](mailto:gavin.gray@adeq.state.ar.us).

Sincerely,  


Gavin Gray  
Enforcement Analyst  
Office of Water Quality, Enforcement Branch

Monitoring Period End Date	Dsch#	Parameter	Limit Value	DMR Value	% Vio	Violation Code
02/28/2021	001-A	Cadmium, total recoverable, MO AVG, lb/d	0.02	<b>0.056</b>	<b>180%</b>	E90
01/31/2021	001-A	Cadmium, total recoverable, MO AVG, lb/d	0.02	<b>0.05</b>	<b>150%</b>	E90
01/31/2021	001-A	E. coli, MO AVG, MCFU/d	93100	93508.2	0%	E90
01/31/2021	001-A	E. coli, 7 DA AVG, #/100mL	2050	8670.7	323%	E90