

March 15, 2018

Hon. Richard McCormac, Mayor City of Clinton P.O. Box 277 Clinton, AR 72031

## RE: NPDES Permit Number AR0048836, AFIN 71-00018 Permitted Effluent Limitation Violations

Dear Mayor. Johnson,

A review of recent Discharge Monitoring Reports (DMRs) for the above-mentioned facility for the reveals the following compliance issues:

The facility has reported 1 violation of Part I, Section A of NPDES Permit No. AR0048836 during the review period. A detailed list of the violation has been included with this letter. The Department expects the City of Clinton to work toward preventing violations of the Part I, Section A., Effluent Limitations and Monitoring Requirements of the Permit.

The Department recommends that the City Clinton consult with a professional engineer for the purpose of developing a corrective action plan (CAP) designed to eliminate violations of the effluent limitations of the Permit.

Any violation of your NPDES Permit is subject to enforcement action by this Department, pursuant to the Arkansas Water and Air Pollution Control Act. The regulations and your NPDES Permit require that you take all reasonable measures necessary to eliminate or prevent the occurrence of violations.

Should you have any questions concerning the above referenced compliance issues, please feel free to contact me at 501-682-0667, or you may e-mail me at gavin.gray@adeq.state.ar.us.

Sincerely, (Jan ( TY

Gavin Gray Enforcement Analyst Office of Water Quality, Enforcement Branch

Monitoring Period End Date	Dsch#	Parameter	Limit Value	DMR Value	% Vio
12/31/2017	001-A	Oxygen, dissolved [DO], INST MIN, mg/L	>=7	6.2	11%