

RENE' MEINTS

REPORT OF NON-COMPLIANCE WITH EFFLUENT LIMITATIONS

PERMITEE: CLINTON, EAST 001

PERMIT: AR0048836 001

REPORTING PERIOD: MAY 2020

REPORT DATE: JUNE 2020

PARAMETER(S)	NPDES MIN	NPDES AVG	NPDES MAX	RESULT REPORTED	DATE OF EXCURSION
Cadmium #/day		0.02		46.7544	*

* Excursion Dates Include: May 4th.

COMMENTS:


We are going to slow the flow down at the sewer plant to see if that will lower the cadmium.

We are setting up tests with ESC, Inc. to check incoming sources to see if we can track where it is coming from. Once we find the source of the cadmium, then we will implement pre-treatment to the company responsible to try to lower the incoming cadmium. Due to Covid-19, ESC, Inc. is doing limited testing at this time.

PRINCIPAL EXECUTIVE OFFICER

TITLE

DATE


CLINTON, EAST 001

Mayor

6-24-20