

RENE' MEINTS

REPORT OF NON-COMPLIANCE WITH EFFLUENT LIMITATIONS

PERMITEE: CLINTON, EAST 001

PERMIT: AR0048836 001

REPORTING PERIOD: FEBRUARY 2021

REPORT DATE: MARCH 2021

| PARAMETER(S) | NPDES MIN | NPDES AVG | NPDES MAX | RESULT REPORTED | DATE OF EXCURSION |
|---------------|--------------|--------------|--------------|--------------------|----------------------|
| Cadmium #/day | | 0.02 | | 0.05 | * |

* Excursion Dates Include: Feb 1st.

COMMENTS:

We have slowed the flow down at the sewer plant to lower the cadmium. We will continue to monitor to try to find the source of the cadmium.

PRINCIPAL EXECUTIVE OFFICER

TITLE

DATE


CLINTON, EAST 001

Mayor

3-23-21