

REPORT OF NON-COMPLIANCE WITH EFFLUENT LIMITATIONS

PERMITEE: CLINTON, EAST 001

PERMIT: AR0048836 001

REPORTING PERIOD: FEBRUARY 2023

REPORT DATE: MARCH 2023

PARAMETER(S)	NPDES MIN	NPDES AVG	NPDES MAX	RESULT REPORTED	DATE OF EXCURSION
DO mg/L	7.00			6.70	02/02/23
DO mg/L	7.00			6.60	02/03/23
DO mg/L	7.00			5.82	02/07/23

* Excursion Dates Include: Feb 7th.


COMMENTS:

Esc is hired to do our samples. Their employee got the sample from the wrong location. If he had gotten it from the correct location, we would not have been low on our DO and would have met permit. We have caught the employee trying to get samples from the wrong location since then and have tried to correct this with ESC. They have apologized.


PRINCIPAL EXECUTIVE OFFICER

TITLE

DATE


CLINTON, EAST 001


Mayor


3-24-23