

RENE' MEINTS

REPORT OF NON-COMPLIANCE WITH EFFLUENT LIMITATIONS

PERMITEE: CLINTON, EAST 001

PERMIT: AR0048836 001

REPORTING PERIOD: MAY 2022

REPORT DATE: JUNE 2022

PARAMETER(S)	NPDES MIN	NPDES AVG	NPDES MAX	RESULT REPORTED	DATE OF EXCURSION
DO mg/L	7.00			5.50	05/01/22
Cadmium #/day		0.02		24.92	*

* Excursion Dates Include: May 2nd, 31st.

COMMENTS:


The low DO may be contributed to the fact that it was raining on that day and the sludge level was high that day. They may have caused the test results to show low DO.

We have contracted FTN Associates Ltd to test different points of entry to try to determine the source of the cadmium.

PRINCIPAL EXECUTIVE OFFICER

TITLE

DATE


CLINTON, EAST 001

Mayor

6-21-22