

# NON-COMPLIANCE REPORT

Arkansas Department of Environmental Quality  
NPDES Enforcement Section  
5301 Northshore Drive  
North Little Rock, AR 72118

RE: NPDES Permit No: AR004886 Discharge Number: 001

Facility: City of Clinton-East WWTF

Address: Factory Road

City: Clinton State: AR Zip: 72031

Contact: Richard McCormac Phone: (501) 745-4320

| Date of Non-Compliance | Parameter Exceeded | Quantity or Loading | Quality or Concentration | Permit Limits |
|------------------------|--------------------|---------------------|--------------------------|---------------|
| 9/2/2022               | Cadmium            | 12.51 lb/day        |                          | 0.02 lb/day   |
| 9/9/2022               | Fecal Coliform     |                     | 544.6 CFU                | 400 CFU       |
|                        |                    |                     |                          |               |
|                        |                    |                     |                          |               |

**We feel this problem was due to:**

Fecal Coliform – High sludge due to faulty valve.

Cadmium - unknown

**We plan on correcting the problem in this manner:**

Fecal Coliform – We are going to install a new valve.

We are in the process of executing a sampling plan to have different agencies test the wastewater to determine the reason for the high cadmium.

**Time estimated that it will take to correct problem:**

Fecal Coliform - Waiting on the Controls Technician. He is expected to be here by the end of the month.

Cadmium – Depending on the time it takes to initiate the sampling plan and getting the results.

Sincerely,



Authorized Signature

10-18-22

Date