

REPORT OF NON-COMPLIANCE WITH EFFLUENT LIMITATIONS

PERMITEE: Clinton East Plant PERMIT: AR0048836

REPORTING PERIOD: Jan-21 REPORT DATE: February 2021

PARAMETER (S)	NPDES MIN	NPDES AVG	NPDES MAX	RESULT REPORTED	DATE OF EXCURSION
Cadmium, Tot. Rec. (lb/d)		0.02		0.1	1/18/2021
E. Coli (MCFU/d)		93,100		93508.0	01/01/21-01/31/2021
E. Coli (#/100mL)		2050		8670.7	01/09/01-01/15/2021

EXCURSION DATES:

We are cleaning the ultra-violet lights more often to see if that will lower the E. Coli. We are also in the process of looking to purchase new ultra-violet lights to replace the existing lights in the sewer plant.

We have slowed the flow down at the sewer plant to see if that will lower the cadmium.

PRINCIPAL EXECUTIVE OFFICER

TITLE

DATE





