

REPORT OF NON-COMPLIANCE WITH EFFLUENT LIMITATIONS

PERMITEE: CLINTON, EAST 001

PERMIT: AR0048836 001

REPORTING PERIOD: FEBRUARY 2013

REPORT DATE: MARCH 2013

PARAMETER(S)	NPDES MIN	NPDES AVG	NPDES MAX	RESULT REPORTED	DATE OF EXCURSION
DO mg/L	7.00			6.5	02/07/13
DO mg/L	7.00			6.9	02/11/13

COMMENTS:

2/7/2013 DO taken during RAIN - Temp WAS @ freezing. No other abnormal plant conditions

2/11/2013 Plant Backwash system had went out due to electrical controls, Operator AND Electrician were backwashing system by hand switch controls. Individual taking readings at that time WAS UNWARE of plant conditions AND did not check with the operator.

PRINCIPAL EXECUTIVE OFFICER

TITLE

DATE

Roy Keeling
CLINTON, EAST 001

MANAGER

3-15-2013

Clinton Water & Sewer
P.O. Box 270
Clinton, AR 72031

ADEQ
Enforcement Section/Water Division
5301 Northshore Dr.
North Little Rock, AR 72118

Hasler

FIRST-CLASS MAIL

03/18/2013

US POSTAGE

\$00.86⁰⁰



ZIP 72031
011D10600716

7211865328 R015

