

NON-COMPLIANCE REPORT

Arkansas Department of Environmental Quality
NPDES Enforcement Section
5301 Northshore Drive
North Little Rock, AR 72118

RE: NPDES Permit No: AR 0050393 Discharge Number: 001

Facility: WVE PROPERTY OWNER ASSOC

Address: _____

City: _____ State: _____ Zip: _____

Contact: _____ Phone: _____

Date of Non-Compliance	Parameter Exceeded	Quantity or Loading	Quality or Concentration	Permit Limits
05 MAR 2018	COLIFORM FECAL GENERAL		100 / 100ml	1000 / 100ml
"	"		3000 / 100ml	2000 / 100ml

We feel this problem was due to:

not enough chlorine


We plan on correcting the problem in this manner:

added additional pucks, also cleaned the contact chamber out

Time estimated that it will take to correct problem:

approximately 4-5 hours.

Sincerely,



Authorized Signature

4/23/18

Date

Certification Statement: I certify under penalty of law that this document and all attachments were prepared under my direction or supervision in accordance with a system designed to assure that qualified personnel properly gather and evaluate the information submitted. Based on my inquiry of the person or persons who manage the system, or those persons directly responsible for gathering the information, the information submitted is, to the best of my knowledge and belief, true, accurate, and complete. I am aware that there are significant penalties for submitting false information, including the possibility of fine and imprisonment for knowing violations. (Revised March 2016)