

### NON-COMPLIANCE REPORT

Arkansas Department of Environmental Quality  
NPDES Enforcement Section  
5301 Northshore Drive  
North Little Rock, AR 72118

RE: NPDES Permit No: AR0050393 Discharge Number: A-001

Facility: \_\_\_\_\_

Address: \_\_\_\_\_

City: \_\_\_\_\_ State: \_\_\_\_\_ Zip: \_\_\_\_\_

Contact: \_\_\_\_\_ Phone: \_\_\_\_\_

Date of Non-Compliance	Parameter Exceeded	Quantity or Loading	Quality or Concentration	Permit Limits
10-DEC-18	Nitrogen ammonia as N		14 mg/L	≤10 mg/L

We feel this problem was due to:  
old sludge, possibly

We plan on correcting the problem in this manner:  
We removed 4200 gal of sludge, also increased wasting

Time estimated that it will take to correct problem:  
problem has been corrected

Sincerely,

  
Authorized Signature

1/11/19  
Date