

# NON-COMPLIANCE REPORT

Arkansas Department of Environmental Quality  
NPDES Enforcement Section  
5301 Northshore Drive  
North Little Rock, AR 72118

RE: NPDES Permit No: AR0050393 Discharge Number: 001-A

Facility: Waterview Estates WWTP - WVE POA, Inc

Address: Hwy 300

City: Roland State: AR Zip: 72135

Contact: Isalia Leon Phone: 501-221-1888

Date of Non-Compliance	Parameter Exceeded	Quantity or Loading	Quality or Concentration	Permit Limits
2/13/2024	Fecal 7D GEO		>2420#100/mL	2000#100/mL

We feel this problem was due to:

*not enough chlorine*

We plan on correcting the problem in this manner:

*adding more chlorine*

Time estimated that it will take to correct problem:

*1 day, subsequent has passed.*

Sincerely,

\_\_\_\_\_  
Authorized Signature

\_\_\_\_\_  
Date

**Certification Statement:** I certify under penalty of law that this document and all attachments were prepared under my direction or supervision in accordance with a system designed to assure that qualified personnel properly gather and evaluate the information submitted. Based on my inquiry of the person or persons who manage the system, or those persons directly responsible for gathering the information, the information submitted is, to the best of my knowledge and belief, true, accurate, and complete. I am aware that there are significant penalties for submitting false information, including the possibility of fine and imprisonment for knowing violations. (Revised March 2016)