

NON-COMPLIANCE REPORT

Arkansas Department of Environmental Quality
 Office of Water Quality - Enforcement Branch
 5301 Northshore Drive
 North Little Rock, AR 72118

RE: Permit No: AR0050393 Discharge Number: A-001
 Facility: WVE Property Owners Association, Inc. - Waterview Estates WWTF
 Address: _____
 City: _____ State: _____ Zip: _____
 Contact: _____ Phone: _____

Date of Non-Compliance	Parameter Exceeded	Quantity or Loading	Quality or Concentration	Permit Limit
11-NOV-21	CBOD		656 mg/L	≤ 20mg/L AVG
11-NOV-21	CBOD		110 mg/L	≤ 30mg/L

We feel this problem was due to:
a clogged tertiary filter

We plan on correcting the problem in this manner:
solenoid is replaced

Time estimated that it will take to correct problem:
filter is operating, approx. 1-2 days.

Sincerely,

Decker

12/14/2021

Submitted By:

Date

Submitted electronically via NetDMR

Certification Statement: I certify under penalty of law that this document and all attachments were prepared under my direction or supervision in accordance with a system designed to assure that qualified personnel properly gather and evaluate the information submitted. Based on my inquiry of the person or persons who manage the system, or those persons directly responsible for gathering the information, the information submitted is, to the best of my knowledge and belief, true, accurate, and complete. I am aware that there are significant penalties for submitting false information, including the possibility of federal imprisonment for knowing violations. (Revised March 2010)