

Arkansas Department of Environmental Quality
 NPDES Enforcement Section
 6301 Northshore Drive
 North Little Rock, AR 72118

RE: NPDES Permit No: AR0050393 Discharge Number: 001 A

Facility: _____

Address: _____

City: _____ State: _____ Zip: _____

Contact: _____ Phone: _____

Date of Non-Compliance	Parameter Exceeded	Quantity or Loading	Quality or Concentration	Permit Limits
05-APR-19	Ammonia as N		7.9 mg/L	≤ 5.6 mg/L

We feel this problem was due to:

temperature change (possible), return rates
from clarifiers

We plan on correcting the problem in this manner:

take another load of sludge out
increase air times, increased return rates

Time estimated that it will take to correct problem:

approx. 1 WEEK

Sincerely,

[Signature]
 Authorized Signature

5/8/19
 Date