

NON-COMPLIANCE REPORT

Arkansas Department of Environmental Quality
NPDES Enforcement Section
5301 Northshore Drive
North Little Rock, AR 72118

RE: NPDES Permit No: AR0050393

Discharge Number: A-001

Facility: _____

Address: _____

City: _____ State: _____ Zip: _____

Contact: _____ Phone: _____

Date of Non-Comp	Parameter Exceeded	Quantity or Loading	Quality or Concentration	Permit Limits
Aug-23	Solids, total suspended		<55 mg/l	<= 20 mg/l Avg
04-Aug-23	Solids, total suspended		100 mg/l	<= 30 mg/l Max

We feel this problem was due to: build up in contact chamber/clean well

We plan on correcting the problem in this manner: hiring sludge truck

Time estimated that it will take to correct the problem: cells have been cleaned, subsequent sample was good.

Sincerely,

Authorized Signature

Date