

# NON-COMPLIANCE REPORT

Arkansas Department of Environmental Quality  
NPDES Enforcement Section  
5301 Northshore Drive  
North Little Rock, AR 72118

RE: NPDES Permit No: A020050393 Discharge Number: A-001

Facility: \_\_\_\_\_

Address: \_\_\_\_\_

City: \_\_\_\_\_ State: \_\_\_\_\_ Zip: \_\_\_\_\_

Contact: \_\_\_\_\_ Phone: \_\_\_\_\_

Date of Non-Compliance	Parameter Exceeded	Quantity or Loading	Quality or Concentration	Permit Limits
21-DEC-20	Fecal Coliform		>2400 #/100mL	<= 2000 #/100mL

We feel this problem was due to:

time of sample not enough chlorine @


We plan on correcting the problem in this manner:

add an additional Cl<sub>2</sub> tank  
in between visits

Time estimated that it will take to correct problem:

approximately 2-3 Days

Sincerely,

  
\_\_\_\_\_  
Authorized Signature

1/20/21  
\_\_\_\_\_  
Date