

NON-COMPLIANCE REPORT

Arkansas Department of Environmental Quality
NPDES Enforcement Section
5301 Northshore Drive
North Little Rock, AR 72118

RE: NPDES Permit No: AR0050393 Discharge Number: A-001

Facility: _____

Address: _____

City: _____ State: _____ Zip: _____

Contact: _____ Phone: _____

Date of Non-Compliance	Parameter Exceeded	Quantity or Loading	Quality or Concentration	Permit Limits
10-DEC-18	Nitrogen ammonia as N		14 mg/L	≤10 mg/L

We feel this problem was due to:
old sludge, possibly

We plan on correcting the problem in this manner:
We removed 4200 gal of sludge, also increased wasting

Time estimated that it will take to correct problem:
problem has been corrected

Sincerely,

Authorized Signature

1/11/19
Date