

NON-COMPLIANCE REPORT

Arkansas Department of Environmental Quality
 Office of Water Quality – Enforcement Branch
 5301 Northshore Drive
 North Little Rock, AR 72118

RE: Permit No: AR 0050393 Discharge Number: 001-A
 Facility: WVE Property Owners Assoc., Inc - Water view Estates WWTTP
 Address: Highway 300
 City: Roland State: AR Zip: 72135
 Contact: Shirley Davis Phone: 501-221-1888

Date of Non-Compliance	Parameter Exceeded	Quantity or Loading	Quality or Concentration	Permit Limits
05-FEB-21	CBOD		71 mg/L	≤ 20 mg/L
05-FEB-21	CBOD		140 mg/L	≤ 30 mg/L

AVG
MAX

We feel this problem was due to:


filters were cleaned & backwashed before sample was taken

We plan on correcting the problem in this manner:

take sample after backwash & cleaning is complete and/or before yearly maint.

Time estimated that it will take to correct problem:

1 hour, subsequent samples are within permit

Sincerely,


3/10/21
 Date

Submitted By:

Submitted electronically via NetDMR

Certification Statement: I certify under penalty of law that this document and all attachments were prepared under my direction or supervision in accordance with a system designed to assure that qualified personnel properly gather and evaluate the information submitted. Based on my inquiry of the person or persons who manage the system, or those persons directly responsible for gathering the information, the information submitted is, to the best of my knowledge and belief, true, accurate, and complete. I am aware that there are significant penalties for submitting false information, including the possibility of fine and imprisonment for knowing violations. (Revised March 2016)