

NON-COMPLIANCE REPORT

Arkansas Department of Environmental Quality
NPDES Enforcement Section
5301 Northshore Drive
North Little Rock, AR 72118

RE: NPEDS Permit No: AR0050393

Discharge Number: A-001

Facility: _____

Address: _____

City: _____ State: _____ Zip: _____

Contact: _____ Phone: _____

Date of Non-Comp	Parameter Exceeded	Quantity or Loading	Quality or Concentration	Permit Limits
Jun-23	BOD, carbonaceous	3.66 lb/d		<= 2.5 lb/d Avg
Jun-23	BOD, carbonaceous		110 mg/l	<= 15 mg/l Avg
12-Jun-23	BOD, carbonaceous		110 mg/l	<= 22.5 mg/l Max

We feel this problem was due to: *a clogged return from primary clarifier which caused sludge retention time to increase*

We plan on correcting the problem in this manner: *return line has been cleared and return has been increased*

Time estimated that it will take to correct the problem: *1-2 days, subsequent sample has passed within limits*

Sincerely,

Authorized Signature

Date