

# NON-COMPLIANCE REPORT

Arkansas Department of Environmental Quality  
 NPDES Enforcement Section  
 5301 Northshore Drive  
 North Little Rock, AR 72118

RE: NPDES Permit No: AR 0050393 Discharge Number: A-001

Facility: \_\_\_\_\_

Address: \_\_\_\_\_

City: \_\_\_\_\_ State: \_\_\_\_\_ Zip: \_\_\_\_\_

Contact: \_\_\_\_\_ Phone: \_\_\_\_\_

Date of Non-Compliance	Parameter Exceeded	Quantity or Loading	Quality or Concentration	Permit Limits
11-NOV-19	Fecal Coliform		72400 #/100ml	<= 1000 30 AVG #/100 ml
11-NOV-19	Fecal Coliform		72400 #/100ml	<= 2000 7 MAX #/100 ml

We feel this problem was due to:  
Possibly due to the contact chamber may be needing  
maintenance

We plan on correcting the problem in this manner:  
Chamber has been cleaned out

Time estimated that it will take to correct problem:  
Subsequent sample has passed

Sincerely,



Authorized Signature

12/9/19

Date