NON-COMPLIANCE REPORT

Arkansas Department of Environmental Quality Office of Water Quality – Enforcement Branch 5301 Northshore Drive North Little Rock, AR 72118

RE: Permit No: ARG550398			Discharge Number: Outfall 001-S		
Facility: Canfor South	ern Pine/Anthony Forest Produc	ts Company - Urbana S	Sawmill		
Address: 1236 Urbana	Rd				
City: Urbana		State: AR	Zip: 71768		
Contact: Phil Witter		Phone: 251-452-7174			
Date of Non-Compliance	Parameter Exceeded	Quantity or Loading	Quality or Concentration	Permit Limits	
6/1/2021	Coliform, fecal general		>2400 /100 ml	200 / 400	
6/1/2021	Dissolved oxygen		1.92 mg/L	>= 6.0	
6/1/2021	BOD5		30 mg/L	10 / 15	
	e maintenance of sanita	,		•	
to staffing levels.	Then carryover of fecal	levels in back er	nd of treatment sy	/stem.	
Pumping out and	cleaning with chlorine s	shock of back end	<u>d components fai</u>	led to correct	
the problem.					
We have retained	ng the problem in this man an Environmental Man design, permit, and ins	agement Service	, ,	ing ————————————————————————————————————	
6 to 9 months bas	it will take to correct prob		lability of key equ	uipment	
components					
Sincerely,					
Phil Witter		6/23/2021			
Submitted By:		Date	Date		

✓ Submitted electronically via NetDMR

Certification Statement: I certify under penalty of law that this document and all attachments were prepared under my direction or supervision in accordance with a system designed to assure that qualified personnel properly gather and evaluate the information submitted. Based on my inquiry of the person or persons who manage the system, or those persons directly responsible for gathering the information, the information submitted is, to the best of my knowledge and belief, true, accurate, and complete. I am aware that there are significant penalties for submitting false information, including the possibility of fine and imprisonment for knowing violations. (Revised March 2016)