

NON-COMPLIANCE REPORT

Arkansas Department of Environmental Quality
Office of Water Quality – Enforcement Branch
5301 Northshore Drive
North Little Rock, AR 72118

RE: Permit No: ARG550398 Discharge Number: Outfall 001-S

Facility: Canfor Southern Pine/Anthony Forest Products Company - Urbana Sawmill

Address: 1236 Urbana Rd

City: Urbana State: AR Zip: 71768

Contact: Phil Witter Phone: 251-452-7174

Date of Non-Compliance	Parameter Exceeded	Quantity or Loading	Quality or Concentration	Permit Limits
12/6/2022	Total Suspended Solids		20 mg/L	15 / 22.5
12/6/2022	Dissolved oxygen		5.47 mg/L	>= 6.0

We feel this problem was due to:

~~Sampled during starting up and shakedown testing of new sanitary treatment system.~~
~~Subsequent DO reading taken January 19, 2023 was 6.12 mg/l.~~

We plan on correcting the problem in this manner:

~~Environmental Management Services, Inc. (engineering consulting firm) designed and installed a new upgraded sanitary treatment system~~

Time estimated that it will take to correct problem:

NA

Sincerely,

Phil Witter

1/30/2023

Submitted By:

Date

Submitted electronically via NetDMR

Certification Statement: I certify under penalty of law that this document and all attachments were prepared under my direction or supervision in accordance with a system designed to assure that qualified personnel properly gather and evaluate the information submitted. Based on my inquiry of the person or persons who manage the system, or those persons directly responsible for gathering the information, the information submitted is, to the best of my knowledge and belief, true, accurate, and complete. I am aware that there are significant penalties for submitting false information, including the possibility of fine and imprisonment for knowing violations. (Revised March 2016)