NON-COMPLIANCE REPORT

Arkansas Department of Environmental Quality Office of Water Quality – Enforcement Branch 5301 Northshore Drive North Little Rock, AR 72118

RE: Permit No: ARG550398			Discharge Number: Outfall 001-S		
Facility: Canfor South	nern Pine/Anthony Forest Produc	ts Company - Urbana S	Sawmill		
Address: 1236 Urbana	a Rd				
City: Urbana		State: AR	Zip: 71768		
Contact: Carol Austin		Phone: 251-243-5106			
		1 110110			
Date of Non-Compliance	Parameter Exceeded	Quantity or Loading	Quality or Concentration	Permit Limits	
6/20/2022	Total Suspended Solids		51 mg/L	15 / 22.5	
6/20/2022	Dissolved oxygen		1.89 mg/L	>= 6.0	
6/20/2022	BOD5		19 mg/L	10 / 15	
6/20/2022	Fecal coliform		>2400 MPN/100 ml	200 / 400	
Environmental Manew upgraded tre Health and ADEE	ng the problem in this man anagement Services, In atment system. The de Supply chain issues hat cturer, but delivery is no	c. (engineering c sign has been ap nave resulted in c	pproved by the Ar delayed delivery o	k Dept of	
Time estimated that	it will take to correct prob	lem:			
	' 				
Sincerely,					
Carol Austin		7/7/2022			
Submitted By:		Date			

✓ Submitted electronically via NetDMR

Certification Statement: I certify under penalty of law that this document and all attachments were prepared under my direction or supervision in accordance with a system designed to assure that qualified personnel properly gather and evaluate the information submitted. Based on my inquiry of the person or persons who manage the system, or those persons directly responsible for gathering the information, the information submitted is, to the best of my knowledge and belief, true, accurate, and complete. I am aware that there are significant penalties for submitting false information, including the possibility of fine and imprisonment for knowing violations. (Revised March 2016)