

Johnson, Miles

From: Evans, Randy <Randy.Evans@canfor.com>
Sent: Friday, November 03, 2017 10:33 AM
To: Johnson, Miles
Subject: Outfall exceedance report

Mr. Johnson,

Anthony Forest Products maintains coverage under ARG550398 and ARG550650. In accordance with Part 6.4.3 of the general permit, Anthony Forest is providing notice that the following parameters were exceeded:

The exceedances for Outfall 001 (ARG550398) included:

	Sample Results	Regulatory Limit
BOD 5-day mg/L	81 mg/L	Exceeded Monthly Avg. 10 mg/L and Daily Max 15
Total Suspended Solids mg/L	68 mg/L	Exceeded Monthly Avg. 15 mg/L and Daily Max 22.5
Dissolved Oxygen	1.0 mg/L	6.0 mg/L instantaneous minimum

The exceedances for Outfall 002 (ARG550540) included:

	Sample Results	Regulatory Limit
BOD 5-day 15 mg/L	110 mg/L	Exceeded Monthly Avg. 10 mg/L and Daily Max
Total Suspended Solids	16 mg/L	Exceeded Monthly Avg. 15 mg/L
Fecal Coliform Daily Max 400 colonies per 100 mL	1000 colonies per 100 mL	Exceeded Monthly Avg. 200 colonies per 100 mL and
Dissolved Oxygen	2.27 mg/L	6.0 mg/L instantaneous minimum

Anthony Forest Company believes that the current company that has been hired to service the units is not performing adequate maintenance on the system resulting in permit exceedances and is currently looking for a new service provider.

Please let me know if you have any further questions.

Thanks,

RANDY EVANS
Regional Safety Manager
AR, MS Region
Canfor Southern Pine.

T 870-962-3206
C 870-310-6547
Randy.Evans@canfor.com www.canfor.com
1236 Urbana Road, El Dorado, AR 71730

Canfor Legal Disclaimer: This e-mail and any attachment(s) are confidential. If you are not the intended recipient, please notify the sender immediately by return e-mail, delete this e-mail and do not copy, use or disclose it to any other person.