

# NON-COMPLIANCE REPORT

Arkansas Department of Environmental Quality  
Office of Water Quality – Enforcement Branch  
5301 Northshore Drive  
North Little Rock, AR 72118

RE: Permit No: ARG550540 Discharge Number: Outfall 002-S

Facility: Canfor Southern Pine/Anthony Forest Products Company - Urbana Sawmill

Address: 1236 Urbana Rd

City: Urbana State: AR Zip: 71768

Contact: Phil Witter Phone: 251-452-7174

Date of Non-Compliance	Parameter Exceeded	Quantity or Loading	Quality or Concentration	Permit Limits
6/6/2022 6/29/2022	Fecal coliform		>2400 MPN/100 ml	200 / 400
6/6/2022 6/29/2022	BOD5		5.8 and 18 mg/L	10 / 15

We feel this problem was due to:

~~Starting up and shakedown testing of new Orenco AX-100 sanitary treatment system. Pump controls and timer settings did not properly dose wastewater flow to treatment system.~~

We plan on correcting the problem in this manner:

~~Environmental Management Services, Inc. (engineering consulting firm) is making adjustments to optimize wastewater feed to the treatment system~~

Time estimated that it will take to correct problem:

~~60 days.~~

Sincerely,

Phil Witter

1/30/2023

Submitted By:

Date

Submitted electronically via NetDMR

**Certification Statement:** I certify under penalty of law that this document and all attachments were prepared under my direction or supervision in accordance with a system designed to assure that qualified personnel properly gather and evaluate the information submitted. Based on my inquiry of the person or persons who manage the system, or those persons directly responsible for gathering the information, the information submitted is, to the best of my knowledge and belief, true, accurate, and complete. I am aware that there are significant penalties for submitting false information, including the possibility of fine and imprisonment for knowing violations. (Revised March 2016)