

NON-COMPLIANCE REPORT

Arkansas Department of Environmental Quality
Office of Water Quality – Enforcement Branch
5301 Northshore Drive
North Little Rock, AR 72118

RE: Permit No: ARG550540 Discharge Number: Outfall 002-S

Facility: Canfor Southern Pine/Anthony Forest Products Company - Urbana Sawmill

Address: 1236 Urbana Rd

City: Urbana State: AR Zip: 71768

Contact: Phil Witter Phone: 251-452-7174

Date of Non-Compliance	Parameter Exceeded	Quantity or Loading	Quality or Concentration	Permit Limits
5/14/2019	Coliform, fecal general		>2400 /MPN 100 ml	200 / 400
5/14/2019	Oxygen, dissolved [DO]		4.21 mg/L	>= 6.0
5/14/2019	BOD, 5-day		31 mg/L	10 / 15
5/14/2019	Solids, total suspended		79 mg/L	15.0 / 22.5

We feel this problem was due to:

~~Inadequate maintenance of sanitary treatment system.~~

We plan on correcting the problem in this manner:

~~Testing, evaluation, and system improvements are underway in 2020; see subsequent NCR's for details.~~

Time estimated that it will take to correct problem:

~~See subsequent NCR's for details.~~

Sincerely,

Phil Witter

9/4/2020

Submitted By:

Date

Submitted electronically via NetDMR

Certification Statement: I certify under penalty of law that this document and all attachments were prepared under my direction or supervision in accordance with a system designed to assure that qualified personnel properly gather and evaluate the information submitted. Based on my inquiry of the person or persons who manage the system, or those persons directly responsible for gathering the information, the information submitted is, to the best of my knowledge and belief, true, accurate, and complete. I am aware that there are significant penalties for submitting false information, including the possibility of fine and imprisonment for knowing violations. (Revised March 2016)