

**AUTHORIZATION TO DISCHARGE WASTEWATER UNDER
THE NATIONAL POLLUTANT DISCHARGE ELIMINATION SYSTEM AND
THE ARKANSAS WATER AND AIR POLLUTION CONTROL ACT**

In accordance with the provisions of the Arkansas Water and Air Pollution Control Act (Act 472 of 1949, as amended, Ark. Code Ann. 8-4-101 et seq.), and the Clean Water Act (33 U.S.C. 1251 et seq.),

Hot Spring Power Company, LLC
410 Henderson Road
Malvern, AR 72104

is authorized to discharge from a facility located as follows: 410 Henderson Road, Malvern, Arkansas – 6.5 miles north of Malvern and 2.3 miles south of Magnet Cove near Hwy. 270W in Section 28, Township 3 South, Range 17 West in Hot Spring County, Arkansas.

Latitude: 34° 25' 48"; Longitude: 92° 50' 03"

to receiving waters named:

via a pipeline from the facility to the Ouachita River at Latitude: 34° 25' 41"; Longitude: 92° 51' 31" in Segment 2F of the Ouachita River Basin.

The monitoring outfall is located at the following coordinates:

Outfall 001: Latitude: 34° 25' 49"; Longitude: 92° 50' 00"

Discharge shall be in accordance with effluent limitations, monitoring requirements, and other conditions set forth in Parts I, II, III, and IV hereof.

The response to comments is attached.

Issue Date: March 31, 2007

Effective Date: May 1, 2007

Expiration Date: April 30, 2012



Martin Maner, P.E.
Chief, Water Division
Arkansas Department of Environmental Quality

**PART I
PERMIT REQUIREMENTS**

SECTION A. EFFLUENT LIMITATIONS AND MONITORING REQUIREMENTS: OUTFALL 001 - cooling tower blowdown and low volume waste water.

During the period beginning on the effective date and lasting until date of expiration, the permittee is authorized to discharge from Outfall 001. Such discharges shall be limited and monitored by the permittee as specified below:

<u>Effluent Characteristics</u>	<u>Discharge Limitations</u>				<u>Monitoring Requirements</u>	
	Mass (lbs/day, unless otherwise specified)		Concentration (mg/l, unless otherwise specified)		Frequency	Sample Type
	Monthly Avg.	Daily Max.	Monthly Avg.	Daily Max.		
Flow ¹	N/A	N/A	Report	Report	once/day	totalizing meter
Total Suspended Solids (TSS)	288	959	30	100	once/week	grab
Oil and Grease (O & G)	96	144	10	15	once/week	grab
pH	N/A	N/A	<u>Minimum</u> 6.0 s.u.	<u>Maximum</u> 9.0 s.u.	once/week	grab
Acute Biomonitoring ²	N/A	N/A	N/A	N/A	once/quarter	24-hr composite
<u>Pimephales promelas (Acute)</u> ² Pass/Fail Lethality (48-Hr NOEC) TEM6C Survival (48-Hr NOEC) TOM6C Coefficient of Variation (48-Hr NOEC) TQM6C			<u>48-hr Minimum</u> Report (Pass=0/Fail=1) Report % Report %		once/quarter once/quarter once/quarter	24-hr composite 24-hr composite 24-hr composite
<u>Daphnia pulex (Acute)</u> ² Pass/Fail Lethality (48-Hr NOEC) TEM3D Survival (48-Hr NOEC) TOM3D Coefficient of Variation (48-Hr NOEC) TQM3D			<u>48-hr Minimum</u> Report (Pass=0/Fail=1) Report % Report %		once/quarter once/quarter once/quarter	24-hr composite 24-hr composite 24-hr composite

1 Report monthly average and daily maximum as MGD.
2 See Condition No. 4 of Part III (Biomonitoring Requirements).

There shall be no discharge of distinctly visible solids, scum, or foam of a persistent nature, nor shall there be any formation of slime, bottom deposits, or sludge banks. There shall be no visible sheen due to the presence of oil (Sheen means an iridescent appearance on the surface of the water).

Samples taken in compliance with the monitoring requirements specified above shall be taken at the discharge from the final treatment unit.

**PART I
PERMIT REQUIREMENTS**

SECTION A. EFFLUENT LIMITATIONS AND MONITORING REQUIREMENTS: INTERNAL OUTFALL 01A - cooling tower blowdown.

During the period beginning on the effective date and lasting until date of expiration, the permittee is authorized to discharge from Internal Outfall 01A. Such discharges shall be limited and monitored by the permittee as specified below:

<u>Effluent Characteristics</u>	<u>Discharge Limitations</u>				<u>Monitoring Requirements</u>	
	Mass (lbs/day, unless otherwise specified)		Concentration (mg/l, unless otherwise specified)		Frequency	Sample Type
	Monthly Avg.	Daily Max.	Monthly Avg.	Daily Max.		
Flow ¹	N/A	N/A	Report	Report	once/day	totalizing meter
Free Available Chlorine (FAC) ²	0.16	0.39	0.2	0.5	once/week	grab
pH	N/A	N/A	<u>Minimum</u> 6.0 s.u.	<u>Maximum</u> 9.0 s.u.	once/week	grab

1 Report monthly average and daily maximum as MGD.

2 See Condition No. 6 of Part III. FAC may only be discharged a maximum of 2 hours per day.

Samples taken in compliance with the monitoring requirements specified above shall be taken prior to comingling with low volume waste water.

**PART I
PERMIT REQUIREMENTS**

SECTION A. EFFLUENT LIMITATIONS AND MONITORING REQUIREMENTS: INTERNAL OUTFALL 01B - low volume waste water².

During the period beginning on the effective date and lasting until date of expiration, the permittee is authorized to discharge from Internal Outfall 01B. Such discharges shall be limited and monitored by the permittee as specified below:

<u>Effluent Characteristics</u>	<u>Discharge Limitations</u>				<u>Monitoring Requirements</u>	
	Mass (lbs/day, unless otherwise specified)		Concentration (mg/l, unless otherwise specified)		Frequency	Sample Type
	Monthly Avg.	Daily Max.	Monthly Avg.	Daily Max.		
Flow ¹	N/A	N/A	Report	Report	once/day	calculated
Total Suspended Solids (TSS)	7.5	25	30	100	once/month	grab
Oil and Grease (O & G)	3.7	5	15	20	once/month	grab
pH	N/A	N/A	<u>Minimum</u> 6.0 s.u.	<u>Maximum</u> 9.0 s.u.	once/week	grab

- 1 Report monthly average and daily maximum as MGD.
- 2 See Condition No. 7 of Part III.

Samples taken in compliance with the monitoring requirements specified above shall be taken at the discharge from the final treatment unit.

SECTION B. SCHEDULE OF COMPLIANCE

The permittee shall achieve compliance with the effluent limitations specified for discharges in accordance with the following schedule:

Compliance is required on the effective date of the permit.

PART II STANDARD CONDITIONS

SECTION A – GENERAL CONDITIONS

1. Duty to Comply

The permittee must comply with all conditions of this permit. Any permit noncompliance constitutes a violation of the federal Clean Water Act and the Arkansas Water and Air Pollution Control Act and is grounds for enforcement action; for permit termination, revocation and reissuance, or modification; and/or for denial of a permit renewal application. **Any values reported in the required Discharge Monitoring Report (DMR) which are in excess of an effluent limitation specified in Part I shall constitute evidence of violation of such effluent limitation and of this permit.**

2. Penalties for Violations of Permit Conditions

The Arkansas Water and Air Pollution Control Act provides that any person who violates any provisions of a permit issued under the Act shall be guilty of a misdemeanor and upon conviction thereof shall be subject to imprisonment for not more than one (1) year, or a fine of not more than ten thousand dollars (\$10,000) or by both such fine and imprisonment for each day of such violation. Any person who violates any provision of a permit issued under the Act may also be subject to civil penalty in such amount as the court shall find appropriate, not to exceed ten thousand dollars (\$10,000) for each day of such violation. The fact that any such violation may constitute a misdemeanor shall not be a bar to the maintenance of such civil action.

3. Permit Actions

This permit may be modified, revoked and reissued, or terminated for cause including, but not limited to the following:

- a. Violation of any terms or conditions of this permit; or
- b. Obtaining this permit by misrepresentation or failure to disclose fully all relevant facts; or
- c. A change in any conditions that requires either a temporary or permanent reduction or elimination of the authorized discharge; or
- d. A determination that the permitted activity endangers human health or the environment and can only be regulated to acceptable levels by permit modification or termination.
- e. Failure of the permittee to comply with the provisions of APCEC Regulation No. 9 (Permit fees) as required by Part II.A.10. herein.

The filing of a request by the permittee for a permit modification, revocation and reissuance, or termination, or a notification of planned changes or anticipated noncompliance, does not stay any permit condition.

4. Toxic Pollutants

Notwithstanding Part II.A.3., if any toxic effluent standard or prohibition (including any schedule of compliance specified in such effluent standard or prohibition) is promulgated under APCEC Regulation No. 2, as amended, or Section 307(a) of the Clean Water Act for a toxic pollutant which is present in the discharge and that standard or prohibition is more stringent than any limitations on the pollutant in this permit, this permit shall be modified or revoked and reissued to conform to the toxic effluent standards or prohibition and the permittee so notified.

The permittee shall comply with effluent standards, narrative criteria, or prohibitions established under APCEC Regulation No. 2, as amended, or Section 307(a) of the Clean Water Act for toxic pollutants within the time provided in the regulations that establish those standards or prohibitions, even if the permit has not yet been modified to incorporate the requirement.

5. Civil and Criminal Liability

Except as provided in permit conditions on "Bypassing" (Part II.B.4.a.), and "Upsets" (Part II.B.5.b), nothing in this permit shall be construed to relieve the permittee from civil or criminal penalties for noncompliance. Any false or materially misleading representation or concealment of information required to be reported by the provisions of this permit or applicable state and federal statutes or regulations which defeats the regulatory purposes of the permit may subject the permittee to criminal enforcement pursuant to the Arkansas Water and Air Pollution Control Act (Act 472 of 1949, as amended).

6. Oil and Hazardous Substance Liability

Nothing in this permit shall be construed to preclude the institution of any legal action or relieve the permittee from any responsibilities, liabilities, or penalties to which the permittee is or may be subject to under Section 311 of the Clean Water Act.

7. State Laws

Nothing in this permit shall be construed to preclude the institution of any legal action or relieve the permittee from any responsibilities, liabilities, or penalties established pursuant to any applicable State law or regulation under authority preserved by Section 510 of the Clean Water Act.

8. Property Rights

The issuance of this permit does not convey any property rights of any sort, or any exclusive privileges, nor does it authorize any exclusive privileges, nor does it authorize any injury to private property or any invasion of personal rights, nor any infringement of Federal, State, or local laws or regulations.

9. Severability

The provisions of this permit are severable, and if any provision of this permit, or the application of any provisions of this permit to any circumstance is held invalid, the application of such provision to other circumstances, and the remainder of this permit, shall not be affected thereby.

10. Permit Fees

The permittee shall comply with all applicable permit fee requirements for wastewater discharge permits as described in APCEC Regulation No. 9 (Regulation for the Fee System for Environmental Permits). Failure to promptly remit all required fees shall be grounds for the Director to initiate action to terminate this permit under the provisions of 40 CFR Parts 122.64 and 124.5(d), as adopted in APCEC Regulation No. 6 and the provisions of APCEC Regulation No. 8.

SECTION B – OPERATION AND MAINTENANCE OF POLLUTION CONTROLS

1. Proper Operation and Maintenance

- a. The permittee shall at all times properly operate and maintain all facilities and systems of treatment and control (and related appurtenances) which are installed or used by the permittee to achieve compliance with the conditions of this permit. Proper operation and maintenance also includes adequate laboratory controls and appropriate quality assurance procedures. This provision requires the operation of backup or auxiliary facilities or similar systems which are installed by a permittee only when the operation is necessary to achieve compliance with the conditions of the permit.
- b. The permittee shall provide an adequate operating staff which is duly qualified to carryout operation, maintenance, and testing functions required to insure compliance with the conditions of this permit.

2. Need to Halt or Reduce not a Defense

It shall not be a defense for a permittee in an enforcement action that it would have been necessary to halt or reduce the permitted activity in order to maintain compliance with the conditions of this permit. Upon reduction, loss, or failure of the treatment facility, the

permittee shall, to the extent necessary to maintain compliance with its permit, control production or discharges or both until the facility is restored or an alternative method of treatment is provided. This requirement applies, for example, when the primary source of power for the treatment facility is reduced, is lost, or alternate power supply fails.

3. **Duty to Mitigate**

The permittee shall take all reasonable steps to minimize or prevent any discharge in violation of this permit which has a reasonable likelihood of adversely affecting human health or the environment or the water receiving the discharge.

4. **Bypass of Treatment Facilities**

a. **Bypass not exceeding limitation**

The permittee may allow any bypass to occur which does not cause effluent limitations to be exceeded, but only if it also is for essential maintenance to assure efficient operation. These bypasses are not subject to the provisions of Parts II.B.4.b. and 4.c.

b. **Notice**

- (1) Anticipated bypass. If the permittee knows in advance of the need for a bypass, it shall submit prior notice, if possible at least ten days before the date of the bypass.
- (2) Unanticipated bypass. The permittee shall submit notice of an unanticipated bypass as required in Part II.D.6. (24-hour notice).

c. **Prohibition of bypass**

- (1) Bypass is prohibited and the Director may take enforcement action against a permittee for bypass, unless:
 - (a) Bypass was unavoidable to prevent loss of life, personal injury, or severe property damage;
 - (b) There were no feasible alternatives to the bypass, such as the use of auxiliary treatment facilities, retention of untreated wastes, or maintenance during normal periods of equipment downtime. This condition is not satisfied if the permittee could have installed adequate backup equipment to prevent a bypass which occurred during normal or preventive maintenance; and
 - (c) The permittee submitted notices as required by Part II.B.4.b.
- (2) The Director may approve an anticipated bypass, after considering its adverse effects, if the Director determines that it will meet the three conditions listed above in Part II.B.4.c.(1).

5. Upset Conditions

- a. Effect of an upset. An upset constitutes an affirmative defense to an action brought for noncompliance with such technology based permit effluent limitations if the requirements of Part II.B.5.b. of this section are met. No determination made during administrative review of claims that noncompliance was caused by upset, and before an action for noncompliance, is final administrative action subject to judicial review.
- b. Conditions necessary for demonstration of upset. A permittee who wishes to establish the affirmative defense of upset shall demonstrate, through properly signed, contemporaneous operating logs, or other relevant evidence that:
 - (1) An upset occurred and that the permittee can identify the specific cause(s) of the upset;
 - (2) The permitted facility was at the time being properly operated.
 - (3) The permittee submitted notice of the upset as required by Part II.D.6.; and
 - (4) The permittee complied with any remedial measures required by Part II.B.3.
- c. Burden of proof. In any enforcement proceeding, the permittee seeking to establish the occurrence of an upset has the burden of proof.

6. Removed Substances

Solids, sludges, filter backwash, or other pollutants removed in the course of treatment or control of waste waters shall be disposed of in a manner such as to prevent any pollutant from such materials from entering the waters of the State. Written approval must be obtained from the ADEQ for land application only.

7. Power Failure

The permittee is responsible for maintaining adequate safeguards to prevent the discharge of untreated or inadequately treated wastes during electrical power failure either by means of alternate power sources, standby generators, or retention of inadequately treated effluent.

SECTION C – MONITORING AND RECORDS

1. Representative Sampling

Samples and measurements taken as required herein shall be representative of the volume and nature of the monitored discharge during the entire monitoring period. All samples shall be taken at the monitoring points specified in this permit and, unless otherwise specified, before the effluent joins or is diluted by any other waste stream, body of water, or substance. Monitoring points shall not be changed without notification to and the approval of the Director. Intermittent discharges shall be monitored.

2. Flow Measurement

Appropriate flow measurement devices and methods consistent with accepted scientific practices shall be selected and used to insure the accuracy and reliability of measurements of the volume of monitored discharges. The devices shall be installed, calibrated, and maintained to insure the accuracy of the measurements are consistent with the accepted capability of that type of device. Devices selected shall be capable of measuring flows with a maximum deviation of less than +/- 10% from true discharge rates throughout the range of expected discharge volumes and shall be installed at the monitoring point of the discharge.

3. Monitoring Procedures

Monitoring must be conducted according to test procedures approved under 40 CFR Part 136, unless other test procedures have been specified in this permit. The permittee shall calibrate and perform maintenance procedures on all monitoring and analytical instrumentation at intervals frequent enough to insure accuracy of measurements and shall insure that both calibration and maintenance activities will be conducted. An adequate analytical quality control program, including the analysis of sufficient standards, spikes, and duplicate samples to insure the accuracy of all required analytical results shall be maintained by the permittee or designated commercial laboratory. At a minimum, spikes and duplicate samples are to be analyzed on 10% of the samples.

4. Penalties for Tampering

The Arkansas Water and Air Pollution Control Act provides that any person who falsifies, tampers with, or knowingly renders inaccurate, any monitoring device or method required to be maintained under the Act shall be guilty of a misdemeanor and upon conviction thereof shall be subject to imprisonment for not more than one (1) year or a fine of not more than ten thousand dollars (\$10,000) or by both such fine and imprisonment.

5. Reporting of Monitoring Results

Monitoring results must be reported on a DMR form (EPA No. 3320-1). Permittees are required to use preprinted DMR forms provided by ADEQ, unless specific written authorization to use other reporting forms is obtained from ADEQ. Monitoring results obtained during the previous calendar month shall be summarized and reported on a DMR form postmarked no later than the 25th day of the month following the completed reporting period to begin on the effective date of the permit. Duplicate copies of DMR forms signed and certified as required by Part II.D.11. and all other reports required by Part II.D., shall be submitted to the Director at the following address:

NPDES Enforcement Section
Water Division
Arkansas Department of Environmental Quality
8001 National Drive
P.O. Box 8913
Little Rock, AR 72219-8913

If permittee uses outside laboratory facilities for sampling and/or analysis, the name and address of the contract laboratory shall be included on the DMR.

6. Additional Monitoring by the Permittee

If the permittee monitors any pollutant more frequently than required by this permit, using test procedures approved under 40 CFR Part 136 or as specified in this permit, the results of this monitoring shall be included in the calculation and reporting of the data submitted in the DMR. Such increased frequency shall also be indicated on the DMR.

7. Retention of Records

The permittee shall retain records of all monitoring information, including all calibration and maintenance records and all original strip chart recordings for continuous monitoring instrumentation, copies of all reports required by this permit, and records of all data used to complete the application for this permit for a period of at least 3 years from the date of the sample, measurement, report, or application. This period may be extended by request of the Director at any time.

8. Record Contents

Records and monitoring information shall include:

- a. The date, exact place, time and methods of sampling or measurements, and preservatives used, if any;
- b. The individuals(s) who performed the sampling or measurements;
- c. The date(s) and time analyses were performed;
- d. The individual(s) who performed the analyses;
- e. The analytical techniques or methods used; and
- f. The measurements and results of such analyses.

9. Inspection and Entry

The permittee shall allow the Director, or an authorized representative, upon the presentation of credentials and other documents as may be required by law, to:

- a. Enter upon the permittee's premises where a regulated facility or activity is located or conducted, or where records must be kept under the conditions of this permit;

- b. Have access to and copy, at reasonable times, any records that must be kept under the conditions of this permit;
- c. Inspect at reasonable times any facilities, equipment (including monitoring and control equipment), practices, or operations regulated or required under this permit, and
- d. Sample, inspect, or monitor at reasonable times, for the purposes of assuring permit compliance or as otherwise authorized by the Clean Water Act, any substances or parameters at any location.

SECTION D – REPORTING REQUIREMENTS

1. Planned Changes

The permittee shall give notice and provide plans and specification to the Director for review and approval prior to any planned physical alterations or additions to the permitted facility. Notice is required only when:

For Industrial Dischargers

- a. The alteration or addition to a permitted facility may meet one of the criteria for determining whether a facility is a new source in 40 CFR Part 122.29(b).
- b. The alteration or addition could significantly change the nature or increase the quantity of pollutants discharged. This notification applies to pollutants which are subject neither to effluent limitations in the permit, nor to notification requirements under 40 CFR Part 122.42(a)(1).

For POTW Dischargers:

Any change in the facility discharge (including the introduction of any new source or significant discharge or significant changes in the quantity or quality of existing discharges of pollutants) must be reported to the permitting authority. In no case are any new connections, increased flows, or significant changes in influent quality permitted that cause violation of the effluent limitations specified herein.

2. Anticipated Noncompliance

The permittee shall give advance notice to the Director of any planned changes in the permitted facility or activity which may result in noncompliance with permit requirements.

3. Transfers

The permit is nontransferable to any person except after notice to the Director. The Director may require modification or revocation and reissuance of the permit to change the name of the permittee and incorporate such other requirements as may be necessary under the Act.

4. Monitoring Reports

Monitoring results shall be reported at the intervals and in the form specified in Part II.C.5. **Discharge Monitoring Reports must be submitted even when no discharge occurs during the reporting period.**

5. Compliance Schedule

Reports of compliance or noncompliance with, or any progress reports on, interim and final requirements contained in any compliance schedule of this permit shall be submitted no later than 14 days following each schedule date. Any reports of noncompliance shall include the cause of noncompliance, any remedial actions taken, and the probability of meeting the next scheduled requirement.

6. Twenty-four Hour Report

- a. The permittee shall report any noncompliance which may endanger health or the environment. Any information shall be provided orally within 24 hours from the time the permittee becomes aware of the circumstances. A written submission shall also be provided within 5 days of the time the permittee becomes aware of the circumstances. The written submission shall contain the following information:
 - (1) a description of the noncompliance and its cause;
 - (2) the period of noncompliance, including exact dates and times, and if the noncompliance has not been corrected, the anticipated time it is expected to continue; and
 - (3) steps taken or planned to reduce, eliminate, and prevent reoccurrence of the noncompliance.
- b. The following shall be included as information which must be reported within 24 hours:
 - (1) Any unanticipated bypass which exceeds any effluent limitation in the permit;
 - (2) Any upset which exceeds any effluent limitation in the permit and
 - (3) Violation of a maximum daily discharge limitation for any of the pollutants listed by the Director in Part I of the permit to be reported within 24 hours to Enforcement of Water Division of the ADEQ.
- c. The Director may waive the written report on a case-by-case basis if the oral report has been received within 24 hours to Enforcement of Water Division of the ADEQ.

7. Other Noncompliance

The permittee shall report all instances of noncompliance not reported under Parts II.D.4., 5., and 6., at the time monitoring reports are submitted. The reports shall contain the information listed at Part II.D.6.

8. Changes in Discharge of Toxic Substances for Industrial Dischargers

The permittee shall notify the Director as soon as he/she knows or has reason to believe:

- a. That any activity has occurred or will occur which would result in the discharge on a routine or frequent basis of any toxic pollutant which is not limited in the permit, if that discharge will exceed the highest of the "notification levels" described in 40 CFR Part 122.42(a)(1); or
- b. That any activity has occurred or will occur which would result in any discharge on a non-routine or infrequent basis of a toxic pollutant which is not limited in the permit, if that discharge will exceed the highest of the "notification levels" described in 40 CFR Part 122.42(a)(2).

9. Duty to Provide Information

The permittee shall furnish to the Director, within a reasonable time, any information which the Director may request to determine whether cause exists for modifying, revoking and reissuing, or terminating this permit, or to determine compliance with this permit. The permittee shall also furnish to the Director, upon request, copies of records required to be kept by this permit. Information shall be submitted in the form, manner and time frame requested by the Director.

10. Duty to reapply

If the permittee wishes to continue an activity regulated by this permit after the expiration date of this permit, the permittee must apply for and obtain a new permit. The complete application shall be submitted at least 180 days before the expiration date of this permit. The Director may grant permission to submit an application less than 180 days in advance but no later than the permit expiration date. Continuation of expiring permits shall be governed by regulations promulgated in APCEC Regulation No. 6.

11. Signatory Requirements

All applications, reports, or information submitted to the Director shall be signed and certified as follows:

- a. All **permit applications** shall be signed as follows:
 - (1) For a corporation: by a responsible corporate officer. For the purpose of this section, a responsible corporate officer means:
 - (i) A president, secretary, treasurer, or vice-president of the corporation in charge of a principal business function, or any other person who performs similar policy or decision-making functions for the corporation; or
 - (ii) The manager of one or more manufacturing, production, or operation facilities, provided: the manager is authorized to make management decisions which govern

the operation of the regulated facility including having the explicit or implicit duty of making major capital investment recommendations, and initiating and directing other comprehensive measures to assure long term environmental compliance with environmental laws and regulations; the manager can ensure that the necessary systems are established or actions taken to gather complete and accurate information for permit application requirements; and where authority to sign documents has been assigned or delegated to the manager in accordance with corporate procedures.

- (2) For a partnership or sole proprietorship: by a general partner or proprietor, respectively; or
 - (3) For a municipality, State, Federal, or other public agency, by either a principal executive officer or ranking elected official. For purposes of this section, a principal executive officer of a Federal agency includes:
 - (i) The chief executive officer of the agency, or
 - (ii) A senior executive officer having responsibility for the overall operations of a principal geographic unit of the agency.
- b. All **reports** required by the permit and **other information** requested by the Director shall be signed by a person described above or by a duly authorized representative of that person. A person is a duly authorized representative only if:
- (1) The authorization is made in writing by a person described above.
 - (2) The authorization specified either an individual or a position having responsibility for the overall operation of the regulated facility or activity, such as the position of plant manager, operator of a well or a well field, superintendent, or position of equivalent responsibility. (A duly authorized representative may thus be either a named individual or any individual occupying a named position); and
 - (3) The written authorization is submitted to the Director.
- c. Certification. Any person signing a document under this section shall make the following certification:

“I certify under penalty of law that this document and all attachments were prepared under my direction or supervision in accordance with a system designed to assure that qualified personnel properly gather and evaluate the information submitted. Based on my inquiry of the person or persons who manage the system, or those persons directly responsible for gathering the information, the information submitted is, to the best of my knowledge and belief, true, accurate, and complete. I am aware that there are significant penalties for submitting false information, including the possibility of fine and imprisonment for knowing violations.”

12. Availability of Reports

Except for data determined to be confidential under 40 CFR Part 2 and APCEC Regulation No. 6, all reports prepared in accordance with the terms of this permit shall be available for public inspection at the offices of the Department of Environmental Quality. As required by the

Regulations, the name and address of any permit applicant or permittee, permit applications, permits, and effluent data shall not be considered confidential.

13. Penalties for Falsification of Reports

The Arkansas Air and Water Pollution Control Act provides that any person who knowingly makes any false statement, representation, or certification in any application, record, report, plan, or other document filed or required to be maintained under this permit shall be subject to civil penalties specified in Part II.A.2. and/or criminal penalties under the authority of the Arkansas Water and Air Pollution Control Act (Act 472 of 1949, as amended).

PART III OTHER CONDITIONS

1. The operator of this wastewater treatment facility shall have an Industrial license from the State of Arkansas in accordance with Act 1103 of 1991, Act 556 of 1993, Act 211 of 1971, and Regulation No. 3, as amended.
2. In accordance with 40 CFR Parts 122.62(a)(2) and 124.5, this permit may be reopened for modification or revocation and/or reissuance to require additional monitoring and/or effluent limitations when new information is received that actual or potential exceedance of State water quality criteria and/or narrative criteria are determined to be the result of the permittee's discharge(s) to a relevant water body, or a Total Maximum Daily Load (TMDL) is established or revised for the water body that was not available at the time of the permit issuance that would have justified the application of different permit conditions at the time of permit issuance.
3. Other Specified Monitoring Requirements

The permittee may use alternative appropriate monitoring methods and analytical instruments other than as specified in Part I Section A of the permit without a major permit modification under the following conditions:

- The monitoring and analytical instruments are consistent with accepted scientific practices;
- The requests shall be submitted in writing to the NPDES Section of the ADEQ Water Division for use of the alternate method or instrument.
- The method and/or instrument is in compliance with 40 CFR Part 136 or approved by the Director; and
- All associated devices are installed, calibrated and maintained to insure the accuracy of the measurements and are consistent with the accepted capability of that type of device. The calibration and maintenance shall be performed as part of the permittee's laboratory Quality Control/Quality Assurance program.

Upon written approval of the alternative monitoring method and/or analytical instruments, these methods or instruments must be consistently utilized throughout the monitoring period. ADEQ must be notified in writing and the permittee must receive written approval from ADEQ if the permittee decides to return to the original permit monitoring requirements.

4. WHOLE EFFLUENT TOXICITY TESTING (48-HOUR ACUTE NOEC FRESHWATER)

1. SCOPE AND METHODOLOGY

- a. The permittee shall test the effluent for toxicity in accordance with the provisions in this section.

APPLICABLE TO FINAL OUTFALL:	001
CRITICAL DILUTION (%):	22%
EFFLUENT DILUTION SERIES (%):	9%, 12%, 17%, 22%, & 29%
COMPOSITE SAMPLE TYPE:	Defined at PART I
TEST SPECIES/METHODS:	40 CFR Part 136

Daphnia pulex acute static renewal 48-hour definitive toxicity test using EPA/600/4-90/027F, or the latest update thereof. A minimum of five (5) replicates with eight (8) organisms per replicate must be used in the control and in each effluent dilution of this test.

Pimephales promelas (fathead minnow) acute static renewal 48-hour definitive toxicity test using EPA/600/4-90/027F, or the latest update thereof. A minimum of five (5) replicates with eight (8) organisms per replicate must be used in the control and in each effluent dilution of this test.

- b. The NOEC (No Observed Effect Concentration) is defined as the greatest effluent dilution at and below which lethality that is statistically different from the control (0% effluent) at the 95% confidence level does not occur. Acute lethal test failure is defined as a demonstration of a statistically significant lethal effect at test completion to a test species at or below the critical dilution.
- c. This permit may be reopened to require whole effluent toxicity limits, chemical specific effluent limits, additional testing, and/or other appropriate actions to address toxicity.
- d. Test failure is defined as a demonstration of statistically significant lethal effects to a test species at or below the effluent critical dilution.

2. PERSISTENT LETHALITY

The requirements of this subsection apply only when a toxicity test demonstrates significant lethal effects at or below the critical dilution. Significant lethal effects are herein defined as a statistically significant difference at the 95% confidence level between the survival of the appropriate test organism in a specified effluent dilution and the control (0% effluent).

a. Part I Testing Frequency Other Than Monthly

- i. The permittee shall conduct a total of two (2) additional tests for any species that demonstrates significant lethal effects at or below the critical dilution. The two additional tests shall be conducted monthly during the next two consecutive months. The permittee shall not substitute either of the two additional tests in lieu of routine toxicity testing. The full report shall be prepared for each test required by this section in accordance with procedures outlined in Item 4 of this section and submitted with the period discharge monitoring report (DMR) to the permitting authority for review.
- ii. If one or both of the two additional tests demonstrates significant lethal effects at or below the critical dilution, the permittee shall initiate Toxicity Reduction Evaluation (TRE) requirements as specified in Item 5 of this section. The permittee shall notify ADEQ in writing within 5 days of the failure of any retest, and the TRE initiation date will be the test completion date of the first failed retest. A TRE may also be required due to a demonstration of intermittent lethal effects at or below the critical dilution, or for failure to perform the required retests.
- iii. If one or both of the two additional tests demonstrates significant lethal effects at or below the critical dilution, the permittee shall henceforth increase the frequency of testing for this species to once per quarter for the life of the permit.
- iv. The provisions of Item 2.a are suspended upon submittal of the TRE Action Plan.

b. Part I Testing Frequency of Monthly

The permittee shall initiate the TRE requirements as specified in Item 5 of this section when any two of three consecutive monthly toxicity tests exhibit significant lethal effects at or below the critical dilution. A TRE

may be also be required due to a demonstration of intermittent lethal effects at or below the critical dilution, or for failure to perform the required retests.

3. REQUIRED TOXICITY TESTING CONDITIONS

a. Test Acceptance

The permittee shall repeat a test, including the control and all effluent dilutions, if the procedures and quality assurance requirements defined in the test methods or in this permit are not satisfied, including the following additional criteria:

- i. Each toxicity test control (0% effluent) must have a survival equal to or greater than 90%.
- ii. The percent coefficient of variation between replicates shall be 40% or less in the control (0% effluent) for: Daphnia pulex survival test; and fathead minnow survival test.
- iii. The percent coefficient of variation between replicates shall be 40% or less in the critical dilution, unless significant lethal effects are exhibited for: Daphnia pulex survival test; and fathead minnow survival test.

Test failure may not be construed or reported as invalid due to a coefficient of variation value of greater than 40%. A repeat test shall be conducted within the required reporting period of any test determined to be invalid.

b. Statistical Interpretation

For the Daphnia pulex survival test and the fathead minnow survival test, the statistical analyses used to determine if there is a statistically significant difference between the control and the critical dilution shall be in accordance with the methods for determining the NOEC as described in EPA/600/4-90/027F or the most recent update thereof.

If the conditions of Test Acceptability are met in Item 3.a above and the percent survival of the test organism is equal to or greater than 90% in the critical dilution concentration and all lower dilution concentrations, the test shall be considered to be a passing test, and the permittee shall report

an NOEC of not less than the critical dilution for the DMR reporting requirements found in Item 4 below.

c. Dilution Water

- i. Dilution water used in the toxicity tests will be receiving water collected as close to the point of discharge as possible but unaffected by the discharge. The permittee shall substitute synthetic dilution water of similar pH, hardness, and alkalinity to the closest downstream perennial water for;
 - (A) toxicity tests conducted on effluent discharges to receiving water classified as intermittent streams; and
 - (B) toxicity tests conducted on effluent discharges where no receiving water is available due to zero flow conditions.

- ii. If the receiving water is unsatisfactory as a result of instream toxicity (fails to fulfill the test acceptance criteria of Item 3.a), the permittee may substitute synthetic dilution water for the receiving water in all subsequent tests provided the unacceptable receiving water test met the following stipulations:
 - (A) a synthetic dilution water control which fulfills the test acceptance requirements of Item 3.a was run concurrently with the receiving water control;
 - (B) the test indicating receiving water toxicity has been carried out to completion (i.e., 48 hours);
 - (C) the permittee includes all test results indicating receiving water toxicity with the full report and information required by Item 4 below; and
 - (D) the synthetic dilution water shall have a pH, hardness, and alkalinity similar to that of the receiving water or closest downstream perennial water not adversely affected by the discharge, provided the magnitude of these parameters will not cause toxicity in the synthetic dilution water.

d. Samples and Composites

- i. The permittee shall collect two flow-weighted composite samples from the outfall(s) listed at Item 1.a above.

- ii. The permittee shall collect a second composite sample for use during the 24-hour renewal of each dilution concentration the for both tests. The permittee must collect the composite samples so that the maximum holding time for any effluent sample shall not exceed 36 hours. The permittee must have initiated the toxicity test within 36 hours after the collection of the last portion of the first composite sample. Samples shall be chilled to 4 degrees Centigrade during collection, shipping, and/or storage.
- iii. The permittee must collect the composite samples such that the effluent samples are representative of any periodic episode of chlorination, biocide usage or other potentially toxic substance discharged on an intermittent basis.
- iv. If the flow from the outfall(s) being tested ceases during the collection of effluent samples, the requirements for the minimum number of effluent samples, the minimum number of effluent portions and the sample holding time are waived during that sampling period. However, the permittee must collect an effluent composite sample volume during the period of discharge that is sufficient to complete the required toxicity tests with daily renewal of effluent. When possible, the effluent samples used for the toxicity tests shall be collected on separate days. The effluent composite sample collection duration and the static renewal protocol associated with the abbreviated sample collection must be documented in the full report required in Item 4 of this section.
- v. MULTIPLE OUTFALLS: If the provisions of this section are applicable to multiple outfalls, the permittee shall combine the composite effluent samples in proportion to the average flow from the outfalls listed in Item 1.a above for the day the sample was collected. The permittee shall perform the toxicity test on the flow-weighted composite of the outfall samples.

4. REPORTING

- a. The permittee shall prepare a full report of the results of all tests conducted pursuant to this Part in accordance with the Report Preparation Section of EPA/600/4-90/027F, for every valid or invalid toxicity test initiated, whether carried to completion or not. The permittee shall retain each full report pursuant to the provisions of Part II.C.7 of this permit. The permittee shall submit full reports upon the specific request of the

Department. For any test which fails, is considered invalid or which is terminated early for any reason, the full report must be submitted for review.

- b. A valid test for each species must be reported on the DMR during each reporting period specified in Part I of this permit unless the permittee is performing a TRE which may increase the frequency of testing and reporting. Only ONE set of biomonitoring data for each species is to be recorded on the DMR for each reporting period. The data submitted should reflect the LOWEST Survival results for each species during the reporting period. All invalid tests, repeat tests (for invalid tests), and retests (for tests previously failed) performed during the reporting period must be attached to the DMR for ADEQ review.
- c. The permittee shall report the following results of each valid toxicity test on DMR for that reporting period in accordance with Part II.D.4 of this permit. Submit retest information clearly marked as such with the following month's DMR. Only results of valid tests are to be reported on the DMR.
 - i. Pimephales promelas (fathead minnow)
 - (A) If the NOEC for survival is less than the critical dilution, enter a "1"; otherwise, enter a "0" for Parameter No. TEM6C.
 - (B) Report the NOEC value for survival, Parameter No. TOM6C.
 - (C) Report the highest (critical dilution or control) Coefficient of Variation, Parameter No. TQM6C.
 - ii. Daphnia pulex
 - (A) If the NOEC for survival is less than the critical dilution, enter a "1"; otherwise, enter a "0" for Parameter No. TEM3D.

- (B) Report the NOEC value for survival, Parameter No. TOM3D.
- (C) Report the highest (critical dilution or control) Coefficient of Variation, Parameter No. TQM3D.

5. MONITORING FREQUENCY REDUCTION

- a. The permittee may apply for a testing frequency reduction upon the successful completion of the first four consecutive quarters of testing for one or both test species, with no lethal effects demonstrated at or below the critical dilution without a major modification. If granted, the monitoring frequency for that test species may be reduced to not less than once per year for the less sensitive species (usually the fathead minnow) and not less than twice per year for the more sensitive test species (usually the *Daphnia pulex*).
- b. CERTIFICATION - The permittee must certify in writing that no test failures have occurred and that all tests meet all test acceptability criteria in item 3.a. above. In addition the permittee must provide a list with each test performed including test initiation date, species, NOECs for lethal and sub-lethal effects and the maximum coefficient of variation for the controls. Upon review and acceptance of this information the Department will issue a letter of confirmation of the monitoring frequency reduction. A copy of the letter will be forwarded to the Permit Compliance System section to update the permit reporting requirements.
- c. SURVIVAL FAILURES - If any test fails the survival endpoint at any time during the life of this permit, two monthly retests are required and the monitoring frequency for the affected test species shall be increased to once per quarter until the permit is re-issued. Monthly retesting is not required if the permittee is performing a TRE.
- d. This monitoring frequency reduction applies only until the expiration date of this permit, at which time the monitoring frequency for both test species reverts to once per quarter until the permit is re-issued.

6. TOXICITY REDUCTION EVALUATION (TRE)

- a. Within ninety (90) days of confirming lethality in the retests, the permittee shall submit a TRE Action Plan and Schedule for conducting a TRE. The TRE Action Plan shall specify the approach and methodology to be used in performing the TRE. A TRE is an investigation intended to determine

those actions necessary to achieve compliance with water quality-based effluent limits by reducing an effluent's toxicity to an acceptable level. A TRE is defined as a step-wise process which combines toxicity testing and analyses of the physical and chemical characteristics of a toxic effluent to identify the constituents causing effluent toxicity and/or treatment methods which will reduce the effluent toxicity. The TRE Action Plan shall lead to the successful elimination of effluent toxicity at the critical dilution and include the following:

- i. Specific Activities. The plan shall detail the specific approach the permittee intends to utilize in conducting the TRE. The approach may include toxicity characterizations, identifications and confirmation activities, source evaluation, treatability studies, or alternative approaches. When the permittee conducts Toxicity Characterization Procedures the permittee shall perform multiple characterizations and follow the procedures specified in the documents "Methods for Aquatic Toxicity Identification Evaluations: Phase I Toxicity Characterization Procedures" (EPA-600/6-91/003) or alternate procedures. When the permittee conducts Toxicity Identification Evaluations and Confirmations, the permittee shall perform multiple identifications and follow the methods specified in the documents "Methods for Aquatic Toxicity Identification Evaluations, Phase II Toxicity Identification Procedures for Samples Exhibiting Acute and Chronic Toxicity" (EPA/600/R-92/080) and "Methods for Aquatic Toxicity Identification Evaluations, Phase III Toxicity Confirmation Procedures for Samples Exhibiting Acute and Chronic Toxicity" (EPA/600/R-92/081), as appropriate.

The documents referenced above may be obtained through the National Technical Information Service (NTIS) by phone at (800)553-6847 or by writing:

U.S. Department of Commerce
National Technical Information Service
5285 Port Royal Road
Springfield, VA 22161

- ii. Sampling Plan (e.g., locations, methods, holding times, chain of custody, preservation, etc.). The effluent sample volume collected for all tests shall be adequate to perform the toxicity test, toxicity characterization, identification and confirmation procedures, and

conduct chemical specific analyses when a probable toxicant has been identified;

Where the permittee has identified or suspects specific pollutant(s) and/or source(s) of effluent toxicity, the permittee shall conduct, concurrent with toxicity testing, chemical specific analyses for the identified and/or suspected pollutant(s) and/or source(s) of effluent toxicity. Where lethality was demonstrated within 24 hours of test initiation, each composite sample shall be analyzed independently. Otherwise the permittee may substitute a composite sample, comprised of equal portions of the individual composite samples, for the chemical specific analysis;

- iii. Quality Assurance Plan (e.g., QA/QC implementation, corrective actions, etc.); and
 - iv. Project Organization (e.g., project staff, project manager, consulting services, etc.).
- b. The permittee shall initiate the TRE Action Plan within thirty (30) days of plan and schedule submittal. The permittee shall assume all risks for failure to achieve the required toxicity reduction.
- c. The permittee shall submit a quarterly TRE Activities Report, with the Discharge Monitoring Report in the months of January, April, July and October, containing information on toxicity reduction evaluation activities including:
- i. any data and/or substantiating documentation which identifies the pollutant(s) and/or source(s) of effluent toxicity;
 - ii. any studies/evaluations and results on the treatability of the facility's effluent toxicity; and
 - iii. any data which identifies effluent toxicity control mechanisms that will reduce effluent toxicity to the level necessary to meet no significant lethality at the critical dilution.
- d. The permittee shall submit a Final Report on TRE Activities no later than twenty-eight (28) months from confirming lethality in the retests, which provides information pertaining to the specific control mechanism selected that will, when implemented, result in reduction of effluent toxicity to no significant lethality at the critical dilution. The report will also provide a

specific corrective action schedule for implementing the selected control mechanism.

- e. Quarterly testing during the TRE is a minimum monitoring requirement. EPA recommends that permittees required to perform a TRE not rely on quarterly testing alone to ensure success in the TRE, and that additional screening tests be performed to capture toxic samples for identification of toxicants. Failure to identify the specific chemical compound causing toxicity test failure will normally result in a permit limit for whole effluent toxicity limits per federal regulations at 40 CFR 122.44(d)(1)(v).
5. There shall be no discharge of **polychlorinated biphenyls** compounds such as those commonly used for transformer fluid.
 6. The term "Free available chlorine" shall mean the value obtained using the amperometric titration method for free available chlorine described in the latest EPA approval edition of "Standard Methods for the Examination of Water and Wastewater" for total residual chlorine described in 40 CFR Part 136 for free available chlorine.

Neither free available chlorine nor total residual chlorine may be discharged from any cooling tower unit for more than **two hours** per day in any one day and not more than **one cooling tower unit** in any plant may discharge free available or total residual chlorine at any one time unless the discharger demonstrates to the permitting authority that the cooling tower units in a particular location cannot operate at or below this level of chlorination.

7. The term "low volume waste sources" means, taken collectively as if from one source, wastewater from all sources except those for which specific limitations are otherwise established. Low volume wastes sources include, but are not limited to: wastewaters from wet scrubber air pollution control systems, ion exchange water treatment system, water treatment evaporator blowdown, laboratory and sampling wastes, boiler blowdown, floor drains, cooling tower basin cleaning wastes, and recirculating house service water systems. Sanitary and air conditioning wastes are not included.
8. The facility shall not utilize cooling tower maintenance chemicals containing Chromium or Zinc without first modifying this permit.
9. Storm Water Pollution Prevention Plan Requirements

A. **General**

- (1) If your facility already has a storm water pollution prevention plan (SWPPP) in place, then you shall continue the implementation of this SWPPP. If you do not have a SWPPP, then you shall prepare a SWPPP

for your facility within 60 days of the effective starting date of this permit. Your SWPPP must be prepared in accordance with good engineering practices. Your SWPPP must:

- (a) Identify potential sources of pollution which may reasonably be expected to affect the quality of storm water discharges from your facility;
 - (b) Describe and ensure implementation of practices which you will use to reduce the pollutants in storm water discharges from the facility; and
 - (c) Assure compliance with the terms and conditions of this permit.
- (2) No Exposure Exclusions, as allowed by 40 CFR 122.26(g), can be obtained for the storm water discharges from the facility as long as all of the required conditions for applicability can be certified. These required conditions can be found in the federal regulation. The No Exposure Exclusion application form can be obtained from the Storm Water section of the ADEQ. Application for this exclusion must be made on the form obtained from the ADEQ.

B. Contents of Plan

(1) Pollution Prevention Team

- (a) You must identify the staff individual(s) (by name or title) that comprise the facility's storm water Pollution Prevention Team. Your Pollution Prevention Team is responsible for assisting the facility/plant manager in developing, implementing, maintaining and revising the facility's SWPPP. Responsibilities of each staff individual on the team must be listed.

(2) Site Description

- (a) Your SWPPP must include the following:
 - i. *Activities at Facility.* Description of the nature of the industrial activity(ies) at your facility;
 - ii. *General Location Map.* A general location map (e.g., U.S.G.S. quadrangle, or other map) with enough detail to identify the location of your facility and the receiving waters within one mile of the facility;

- iii. A legible site map identifying the following:
- (a) Directions of storm water flow (e.g., use arrows to show which ways storm water will flow);
 - (b) Locations of all existing structural BMPs;
 - (c) Locations of all surface water bodies;
 - (d) Locations of potential pollutant sources identified under Section B(4)(a) of this Part and where significant materials are exposed to precipitation;
 - (e) Location where major spills or leaks identified under Section B(5) of this Part have occurred;
 - (f) Locations of the following activities where such activities are exposed to precipitation: fueling stations, vehicle and equipment maintenance and/or cleaning areas, loading/unloading areas, locations used for the treatment, storage or disposal of wastes, and liquid storage tanks;
 - (g) Locations of storm water outfalls and an approximate outline of the area draining to each outfall;
 - (h) Location and description of non-storm water discharges;
 - (i) Locations of the following activities where such activities are exposed to precipitation: processing and storage areas; access roads, rail cars and tracks; the location of transfer of substance in bulk; and machinery;
 - (j) Location and source of runoff from adjacent property containing significant quantities of pollutants of concern to the facility (an evaluation of how the quality of the runoff impacts your storm water discharges may be included).

(3) **Receiving Waters and Wetlands**

- (a) You must provide the name of the nearest receiving water(s), including intermittent streams, dry sloughs, arroyos and the areal extent and description of wetland or other special aquatic sites that may receive discharges from your facility.

(4) **Summary of Potential Pollutant Source**

- (a) You must identify each separate area at your facility where industrial materials or activities are exposed to storm water. Industrial materials or activities include, but are not limited to, material handling equipment or activities, industrial machinery, raw materials, intermediate products, by-products, final products, or waste products. Material handling activities include the storage, loading/unloading, transportation, or conveyance of any raw material, intermediate product, final product or waste product. For each separate area identified, the description must include:
- i. *Activities in Area.* A list of the activities (e.g., material storage, equipment fueling and cleaning, cutting steel beams); and
 - ii. *Pollutants.* A list of the associated pollutant(s) or pollutant parameter(s) (e.g., crankcase oil, iron, biochemical oxygen demand, pH, etc.) for each activity. The pollutant list must include all significant materials that have been handled, treated, stored or disposed in a manner to allow exposure to storm water between the time of three (3) years before being covered under this permit and the present.

(5) **Spills and Leaks**

- (a) You must clearly identify areas where potential spills and leaks, which can contribute pollutants to storm water discharges, can occur, and their accompanying drainage points. For areas that are exposed to precipitation or that otherwise drain to a storm water conveyance at the facility to be covered under this permit, you must provide a list of significant spills and leaks of toxic or hazardous pollutants that occurred during the three (3) year period prior to the starting date of this permit. Your list must be updated if significant spills or leaks occur in exposed areas of your facility during the time you are covered by the permit.

- (b) Significant spills and leaks include, but are not limited to releases of oil or hazardous substances in excess of quantities that are reportable under CWA 311 (see 40 CFR 110.10 AND 40 CFR 117.21) or section 102 of the Comprehensive Environmental Response, Compensation and Liability Act (CERCLA). Significant spills may also include releases of oil or hazardous substances that are not in excess of reporting requirements.

(6) **Sampling Data**

- (a) You must provide a summary of existing storm water discharge sampling data taken at your facility. All storm water sampling data collected during the term of this permit must also be summarized and included in this part of the SWPPP.

(7) **Storm Water Controls**

- (a) Description of Existing and Planned BMPs. Describe the type and location of existing non-structural and structural best management practices (BMPs) selected for each of the areas where industrial materials or activities are exposed to storm water. All the areas identified in Section B(4)(a) of this Part should have a BMP(s) identified for the areas discharges. For areas where BMPs are not currently in place, describe appropriate BMPs that you will use to control pollutants in storm water discharges. Selection of BMPs should take into consideration:
 - i. The quantity and nature of the pollutants, and their potential to impact the water quality of receiving waters;
 - ii. Opportunities to combine the dual purposes of water quality protection and local flood control benefits (including physical impacts of high flows on streams - e.g., bank erosion, impairment of aquatic habitat, etc.);
 - iii. Opportunities to offset the impact impervious areas of the facility on ground water recharge and base flows in local streams (taking into account the potential for ground water contamination.)
- (b) BMP Types to be Considered. The following types of structural, non-structural, and other BMPs must be considered for implementation at your facility. Describe how each is, or will be, implemented. This requirement may have been fulfilled with area-

specific BMPs identified under Section B(7)(a) of this Part, in which case the previous descriptions are sufficient. However, many of the following BMPs may be more generalized or non site-specific and therefore not previously considered. If you determine that any of these BMPs are not appropriate for your facility, you must include an explanation of why they are not appropriate. The BMP examples listed below are not intended to be an exclusive list of BMPs that you may use. You are encouraged to keep abreast of new BMPs or new applications of existing BMPs to find the most cost effective means of permit compliance for your facility. If BMPs are being used or planned at the facility which are not listed here (e.g., replacing a chemical with a less toxic alternative, adopting a new or innovative BMP, etc.), include descriptions of them in this section of the SWPPP.

(c) Non-Structural BMPs

- i. *Good Housekeeping:* You must keep all exposed areas of the facility in a clean, orderly manner where such exposed areas could contribute pollutants to storm water discharges. Common problem areas include: around trash containers, storage areas and loading docks. Measures must also include: a schedule for regular pickup and disposal of garbage and waste materials; routine inspections for leaks and conditions of drums, tanks and containers.
- ii. *Minimizing Exposure:* Where practicable, industrial materials and activities should be protected by a storm resistant shelter to prevent exposure to rain, snow, snowmelt, or runoff.
- iii. *Preventive Maintenance:* You must have a preventive maintenance program which includes timely inspection and maintenance of storm water management devices, (e.g., cleaning oil/water separators, catch basins) as well as inspecting, testing, maintaining and repairing facility equipment and systems to avoid breakdowns or failures that may result in discharges of pollutants to surface waters.
- iv. *Spill Prevention and Response Procedures:* You must describe the procedures which will be followed for cleaning up spills or leaks. Those procedures, and necessary spill response equipment, must be made available to those

employees that may cause or detect a spill or leak. Where appropriate, you must explain existing or planned material handling procedures, storage requirements, secondary containment, and equipment (e.g., diversion valves), which are intended to minimize spills or leaks at the facility. Measures for cleaning up hazardous material spills or leaks must be consistent with applicable RCRA regulations at 40 CFR Part 264 and 40 CFR Part 265.

- v. *Routine Facility Inspections:* In addition to or as part of the comprehensive site evaluation required under Section G of this Part, you must have qualified facility personnel inspect all areas of the facility where industrial materials or activities are exposed to storm water. The inspections must include an evaluation of existing storm water BMPs. Your SWPPP must identify how often these inspections will be conducted. You must correct any deficiencies you find as soon as practicable, but no later than 14 days from the date of the inspection. You must document in your SWPPP the results of your inspections and the corrective actions you took in response to any deficiencies or opportunities for improvement that you identify.
- vi. *Employee Training:* You must describe the storm water employee training program for the facility. The description should include the topics to be covered, such as spill response, good housekeeping, and material management practices, and must identify periodic dates (e.g., every 6 months during the months of July and January) for such training. You must provide employee training for all employees that work in areas where industrial materials or activities are exposed to storm water, and for employees that are responsible for implementing activities identified in the SWPPP (e.g., inspectors, maintenance people). The employee training should inform them of the components and goals of your SWPPP.

(d) Structural BMPs

- i. *Sediment and Erosion Control:* You must identify the areas at your facility which, due to topography, land disturbance (e.g., construction), or other factors, have a potential for significant soil erosion. You must describe the structural,

vegetative, and/or stabilization BMPs that you will be implementing to limit erosion.

- ii. *Management of Runoff:* You must describe the traditional storm water management practices (permanent structural BMPs other than those which control the generation or source(s) of pollutants) that currently exist or that are planned for your facility. These types of BMPs typically are used to divert, infiltrate, reuse, or otherwise reduce pollutants in storm water discharges from the site. Factors to consider when you are selecting appropriate BMPs should include: 1) the industrial materials and activities that are exposed to storm water, and the associated pollutant potential of those materials and activities; and 2) the beneficial and potential detrimental effects on surface water quality, ground water quality, receiving water base flow (dry weather stream flow), and physical integrity of receiving waters. Structural measures should be placed on upland soils, avoiding wetlands and flood plains, if possible. Structural BMPs may require a separate permit under section 404 of the CWA before installation begins.
- iii. *Example BMPs:* BMPs you could use include but are not limited to: storm water detention structures (including wet ponds); storm water retention structures; flow attenuation by use of open vegetated swales and natural depressions; infiltration of runoff onsite; and sequential systems (which combine several practices).

(e) Other Controls

- i. No solid materials, including floatable debris, may be discharged to waters of the United States, except as authorized by a permit issued under section 404 of the CWA. Off-site vehicle tracking of raw, final, or waste materials or sediments, and the generation of dust must be minimized. Tracking or blowing of raw, final, or waste materials from areas of no exposure to exposed areas must be minimized. Velocity dissipation devices must be placed at discharge locations and along the length of any outfall channel to provide a non-erosive flow velocity from the structure to a water course so that the natural physical and biological characteristics and functions are maintained and

protected (e.g., no significant changes in the hydrological regime of the receiving water).

C. Maintenance

- (1) All BMPs you identify in your SWPPP must be maintained in effective operating condition. If site inspections required by Section B(7)(c)(v) of this Part identify BMPs that are not operating effectively, maintenance must be performed before the next anticipated storm event, or as necessary to maintain the continued effectiveness of storm water controls. If maintenance prior to the next anticipated storm event is impracticable, maintenance must be scheduled and accomplished as soon as practicable. In the case of non-structural BMPs, the effectiveness of the BMP must be maintained by appropriate means (e.g., spill response supplies available and personnel trained, etc.).

D. Non-Storm Water Discharges

(1) Certification of Non-Storm Water Discharges

- (a) Your SWPPP must include a certification that all discharges (i.e., outfalls) have been tested or evaluated for the presence of non-storm water. The certification must be signed in accordance with Part II Section D.11 of the individual permit, and include:
 - i. The date of any testing and/or evaluation;
 - ii. Identification of potential significant sources of non-storm water at the site;
 - iii. A description of the results of any test and/or evaluation for the presence of non-storm water discharges;
 - iv. A description of the evaluation criteria or testing method used; and
 - v. A list of the outfalls or onsite drainage points that were directly observed during the test.
 - vi. If you are unable to provide the certification required (testing for non-storm water discharges), you must notify the Director 180 days after the effective starting date of this permit to be covered by this permit. If the failure to certify

is caused by the inability to perform adequate tests or evaluations, such notification must describe:

- vii. The reason(s) why certification was not possible;
- viii. The procedure of any test attempted;
- ix. The results of such test or other relevant observations; and
- x. Potential sources of non-storm water discharges to the storm sewer.
- xi. A copy of the notification must be included in the SWPPP at the facility. Non-storm water discharges to waters of the United States which are not authorized by an NPDES permit are unlawful, and must be terminated.

E. Allowable Non-storm Water Discharges

- (1) Certain sources of non-storm water are allowable under this permit. For the list of allowable non-storm water discharges please see Part I.B.1.a.i on Page 16 of the Industrial Storm Water General Permit number ARR000000. In order for these discharges to be allowed, your SWPPP must include:
 - (a) An identification of each allowable non-storm water source;
 - (b) The location where it is likely to be discharged; and
 - (c) Descriptions of appropriate BMPs for each source.
 - (d) Except for flows from fire fighting activities, you must identify in your SWPPP all sources of allowable non-storm water that are discharged under the authority of this permit.
 - (e) If you include mist blown from cooling towers amongst your allowable non-storm water discharges, you must specifically evaluate the potential for the discharges to be contaminated by chemicals used in the cooling tower and determined that the levels of such chemicals in the discharges would not cause or contribute to a violation of an applicable water quality standard after implementation of the BMPs you have selected to control such discharges.

F. Comprehensive Site Compliance Evaluation

(1) Frequency and Inspectors

- (a) You must conduct facility inspections at least once a year. The inspections must be done by qualified personnel provided by you. The qualified personnel you use may be either your own employees or outside consultants that you have hired, provided they are knowledgeable and possess the skills to assess conditions at your facility that could impact storm water quality and assess the effectiveness of the BMPs you have chosen to use to control the quality of your storm water discharges. If you decide to conduct more frequent inspections, your SWPPP must specify the frequency of inspections.

(2) Scope of the Compliance Evaluation

- (a) Your inspections must include all areas where industrial materials or activities are exposed to storm water, as identified in Section B(4)(a) of this Part, and areas where spills and leaks have occurred within the past 3 years. Inspectors should look for: a) industrial materials, residue, or trash on the ground that could contaminate or be washed away in storm water; b) leaks or spills from industrial equipment, drums, barrels, tanks, or similar containers; c) offsite tracking of industrial materials or sediment where vehicles enter or exit the site; d) tracking or blowing of raw, final, or waste materials from areas of no exposure to exposed areas; and e) for evidence of, or the potential for, pollutants entering the drainage system. Storm water BMPs identified in your SWPPP must be observed to ensure that they are operating correctly. Where discharge locations or points are accessible, they must be inspected to see whether BMPs are effective in preventing significant impacts to receiving waters. Where discharge locations are inaccessible, nearby downstream locations must be inspected if possible.

(3) Follow-up Actions

- (a) Based on the results of the inspections, you must modify your SWPPP as necessary (e.g., show additional controls on the map required by Section B(2)(a)(iii) of this Part and revise the description of controls required by Section B(7)(a) of this Part to include additional or modified BMPs designed to correct the problems identified. You must complete revisions to the SWPPP

within 14 calendar days following the inspection. If existing BMPs need to be modified or if additional BMPs are necessary, implementation must be completed before the next anticipated storm event. If implementation before the next anticipated storm event is impracticable, they must be implemented as soon as practicable.

(4) Compliance Evaluation Report

- (a) You must insure a report summarizing the scope of the inspection, name(s) of personnel making the inspection, the date(s) of the inspection, and major observations relating to the implementation of the SWPPP is completed and retained as part of the SWPPP for at least three years from the date permit coverage expires or is terminated. Major observations should include: the location(s) of discharges of pollutants from the site; and location(s) of BMPs that need to be maintained; location(s) where additional BMPs are needed that did not exist at the time of inspection. You must retain a record of actions taken in accordance with Part II Section C.7 (Retention of Records) of this permit as part of the storm water pollution prevention plan for at least three years from the date that permit coverage expires or is terminated. The inspection reports must identify any incidents of non-compliance. Where an inspection report does not identify any incidents of non-compliance, the report must contain a certification that the facility is in compliance with the storm water pollution prevention plan and this permit. Both the inspection report and any reports of follow-up actions must be signed in accordance with Part II Section D (Reporting Requirements) of this permit.

(5) Credit As a Routine Facility Inspection

- (a) Where compliance evaluation schedules overlap with inspections required under Section B(7)(c)(v) of this Part, your annual compliance evaluation may also be used as one of the Section B(7)(c)(v) of this Part , routine inspections.

G. Maintaining Updated SWPPP

- (1) You must amend the storm water pollution prevention plan whenever:
- (a) There is a change in design, construction, operation, or maintenance at your facility which has a significant effect on the

discharge, or potential for discharge, of pollutants from your facility;

- (b) During inspections or investigations by you or by local, State, Tribal or Federal officials it is determined the SWPPP is ineffective in eliminating or significantly minimizing pollutants from sources identified under Section B(4) of this Part, or is otherwise not achieving the general objectives of controlling pollutants in discharges from your facility.

H. Signature, Plan Review and Making Plans Available

- (1) You must sign your SWPPP in accordance with Part II Section D.11, and retain the plan on-site at the facility covered by this permit (see Part II Section C.7 for records retention requirements).
- (2) You must keep a copy of the SWPPP on-site or locally available to the Director for review at the time of an on-site inspection. You must make your SWPPP available upon request to the Director, a State, Tribal or local agency approving storm water management plans, or the operator of a municipal separate storm sewer receiving discharge from the site. Also, in the interest of public involvement, EPA encourages you to make your SWPPPs available to the public for viewing during normal business hours.
- (3) The Director may notify you at any time that your SWPPP does not meet one or more of the minimum requirements of this permit. The notification will identify provisions of this permit which are not being met, as well as the required modifications. Within thirty (30) calendar days of receipt of such notification, you must make the required changes to the SWPPP and submit to the Director a written certification that the requested changes have been made.
- (4) You must make the SWPPP available to the USFWS or NMFS upon request.

I. Additional Requirements for Storm Water Discharges Associated With Industrial Activity From Facilities Subject to EPCRA Section 313 Reporting Requirements.

- (1) Potential pollutant sources for which you have reporting requirements under EPCRA 313 must be identified in your summary of potential pollutant sources as per Section B(4) of this Part. Note this additional requirement only applies to you if you are subject to reporting requirements under EPCRA 313.

10. After two years of data (i.e., a minimum of 24 data points) demonstrating compliance with the TSS and the O & G limits at Outfall 01B, the permittee may request a reduction in the monitoring frequency from once per month to once per quarter. This request must be made in writing and must be approved by the Department prior to taking place. The reductions in frequency will be made without a major permit modification.

PART IV DEFINITIONS

All definitions contained in Section 502 of the Clean Water Act shall apply to this permit and are incorporated herein by reference. Additional definitions of words or phrases used in this permit are as follows:

1. **“Act”** means the Clean Water Act, Public Law 95-217 (33.U.S.C. 1251 et seq.) as amended.
2. **“Administrator”** means the Administrator of the U.S. Environmental Protection Agency.
3. **“Applicable effluent standards and limitations”** means all State and Federal effluent standards and limitations to which a discharge is subject under the Act, including, but not limited to, effluent limitations, standards of performance, toxic effluent standards and prohibitions, and pretreatment standards.
4. **“Applicable water quality standards”** means all water quality standards to which a discharge is subject under the federal Clean Water Act and which has been (a) approved or permitted to remain in effect by the Administrator following submission to the Administrator pursuant to Section 303(a) of the Act, or (b) promulgated by the Director pursuant to Section 303(b) or 303(c) of the Act, and standards promulgated under (APCEC) Regulation No. 2, as amended.
5. **“Bypass”** means the intentional diversion of waste streams from any portion of a treatment facility.
6. **“Daily Discharge”** means the discharge of a pollutant measured during a calendar day or any 24-hour period that reasonably represents the calendar day for purposes of sampling. *Mass Calculations:* For pollutants with limitations expressed in terms of mass, the “daily discharge” is calculated as the total mass of pollutant discharged over the sampling day. *Concentration Calculations:* For pollutants with limitations expressed in other units of measurement, determination of concentration made using a composite sample shall be the concentration of the composite sample. When grab samples are used, the “daily discharge” determination of concentration shall be the arithmetic average (weighted by flow value) of all the samples collected during that sampling day by using the following formula: where C= daily concentration, F=daily flow and n=number of daily samples

$$\frac{C_1F_1 + C_2F_2 + \dots + C_nF_n}{F_1 + F_2 + \dots + F_n}$$

7. **“Monthly average”** means the highest allowable average of “daily discharges” over a calendar month, calculated as the sum of all “daily discharges” measured during a calendar month divided by the number of “daily discharges” measured during that month. For Fecal Coliform Bacteria (FCB) report the monthly average (see 30-day average below).

8. **“Daily Maximum”** discharge limitation means the highest allowable “daily discharge” during the calendar month. The 7-day average for Fecal Coliform Bacteria (FCB) is the geometric mean of the values of all effluent samples collected during the calendar week in colonies per 100 ml.
9. **“Department”** means the Arkansas Department of Environmental Quality (ADEQ).
10. **“Director”** means the Administrator of the U.S. Environmental Protection Agency and/or the Director of the Arkansas Department of Environmental Quality.
11. **“Grab sample”** means an individual sample collected in less than 15 minutes in conjunction with an instantaneous flow measurement.
12. **“Industrial User”** means a nondomestic discharger, as identified in 40 CFR Part 403, introducing pollutants to a POTW.
13. **“National Pollutant Discharge Elimination System”** means the national program for issuing, modifying, revoking and reissuing, terminating, monitoring and enforcing permits, and imposing and enforcing pretreatment requirements under Sections 307, 402, 318, and 405 of the Clean Water Act.
14. **“POTW”** means a Publicly Owned Treatment Works.
15. **“Severe property damage”** means substantial physical damage to property, damage to the treatment facilities which causes them to become inoperable, or substantial and permanent loss of natural resources which can reasonably be expected to occur in the absence of a bypass. Severe property damage does not mean economic loss caused by delays in products.
16. **“APCEC”** means the Arkansas Pollution Control and Ecology Commission.
17. **“Sewage sludge”** means the solids, residues, and precipitate separated from or created in sewage by the unit processes at a POTW. Sewage as used in this definition means any wastes, including wastes from humans, households, commercial establishments, industries, and storm water runoff that are discharged to or otherwise enter a POTW.
18. **“7-day average”** discharge limitation, other than for Fecal Coliform Bacteria (FCB), is the highest allowable arithmetic mean of the values for all effluent samples collected during the calendar week. The 7-day average for Fecal Coliform Bacteria (FCB) is the geometric mean of the values of all effluent samples collected during the calendar week in colonies/100 ml. The Discharge Monitoring Report should report the highest 7-day average obtained during the calendar month. For reporting purposes, the 7-day average values should be reported as occurring in the month in which the Saturday of the calendar week falls in.
19. **“30-day average”**, other than for Fecal Coliform Bacteria (FCB), is the arithmetic mean of the daily values for all effluent samples collected during a calendar month, calculated as the sum of all daily discharges measured during a calendar month divided by the number of daily discharges measured during that month. The 30-day average for Fecal Coliform Bacteria (FCB) is the geometric mean of the values for all effluent samples collected during a calendar month. For Fecal Coliform Bacteria (FCB), report the monthly average as a 30-day geometric mean in colonies per 100 ml.

20. **“24-hour composite sample”** consists of a minimum of 12 effluent portions collected at equal time intervals over the 24-hour period and combined proportional to flow or a sample collected at frequent intervals proportional to flow over the 24-hour period.
21. **“12-hour composite sample”** consists of 12 effluent portions, collected no closer together than one hour and composited according to flow. The daily sampling intervals shall include the highest flow periods.
22. **“6-hour composite sample”** consists of six effluent portions collected no closer together than one hour (with the first portion collected no earlier than 10:00 a.m.) and composited according to flow.
23. **“3-hour composite sample”** consists of three effluent portions collected no closer together than one hour (with the first portion collected no earlier than 10:00 a.m.) and composited according to flow.
24. **“Treatment works”** means any devices and systems used in storage, treatment, recycling, and reclamation of municipal sewage and industrial wastes, of a liquid nature to implement section 201 of the Act, or necessary to recycle reuse water at the most economic cost over the estimated life of the works, including intercepting sewers, sewage collection systems, pumping, power and other equipment, and alterations thereof; elements essential to provide a reliable recycled supply such as standby treatment units and clear well facilities, and any works, including site acquisition of the land that will be an integral part of the treatment process or is used for ultimate disposal of residues resulting from such treatment.
25. **“Upset”** means an exceptional incident in which there is unintentional and temporary noncompliance with technology-based permit effluent limitations because of factors beyond the reasonable control of the permittee. Any upset does not include noncompliance to the extent caused by operational error, improperly designed treatment facilities, lack of preventive maintenance, or careless or improper operations.
26. **“For Fecal Coliform Bacteria (FCB)”**, a sample consists of one effluent grab portion collected during a 24-hour period at peak loads. For Fecal Coliform Bacteria (FCB) report the monthly average as a 30-day geometric mean in colonies per 100 ml.
27. **“Dissolved oxygen limit”**, shall be defined as follows:
 - a. When limited in the permit as a monthly average minimum, shall mean the lowest acceptable monthly average value, determined by averaging all samples taken during the calendar month;
 - b. When limited in the permit as an instantaneous minimum value, shall mean that no value measured during the reporting period may fall below the stated value.
28. **The term “MGD”** shall mean million gallons per day.
29. **The term “mg/l”** shall mean milligrams per liter or parts per million (ppm).
30. **The term “µg/l”** shall mean micrograms per liter or parts per billion (ppb).
31. **The term “cfs”** shall mean cubic feet per second.
32. **The term “ppm”** shall mean parts per million.
33. **The term “s.u.”** shall mean standard units.

34. **The term “Instantaneous Maximum”** when limited in the permit as an instantaneous maximum value, shall mean that no value measured during the reporting period may fall above the stated value.

35. **Monitoring and Reporting:**

When a permit becomes effective, monitoring requirements are of the immediate period of the permit effective date. Where the monitoring requirement for an effluent characteristic is monthly or more frequently, the Discharge Monitoring Report (DMR) shall be submitted by the 25th of the month following the sampling. Where the monitoring requirement for an effluent characteristic is Quarterly, Semi-Annual, Annual, or Yearly, the DMR shall be submitted by the 25th of the month following the monitoring period end date.

MONTHLY:

is defined as a calendar month or any portion of a calendar month for monitoring requirement frequency of once/month or more frequently.

QUARTERLY:

(1) is defined as a fixed calendar quarter or any part of the fixed calendar quarter for a non-seasonal effluent characteristic with a measurement frequency of once/quarter. Fixed calendar quarters are: January through March, April through June, July through September, and October through December; or

(2) is defined as a fixed three month period (or any part of the fixed three month period) of or dependent upon the seasons specified in the permit for a seasonal effluent characteristic with a monitoring requirement frequency of once/quarter that does not coincide with the fixed calendar quarter. Seasonal calendar quarters are: May through July, August through October, November through January, and February through April.

SEMI-ANNUAL:

is defined as the fixed time periods January through June, and July through December (or any portion thereof) for an effluent characteristic with a measurement frequency of once/6 months or twice/year.

ANNUAL or YEARLY:

is defined as a fixed calendar year or any portion of the fixed calendar year for an effluent characteristic or parameter with a measurement frequency of once/year. A calendar year is January through December, or any portion thereof.

36. **The term “Weekday”** means Monday – Friday.

Final Fact Sheet

For renewal of NPDES Permit Number AR0049611 to discharge to Waters of the State

1. PERMITTING AUTHORITY.

The issuing office is:

Arkansas Department of Environmental Quality
8001 National Drive
Post Office Box 8913
Little Rock, Arkansas 72219-8913

2. APPLICANT.

The applicant is:

Hot Spring Power Company, LLC
410 Henderson Road
Malvern, AR 72104

3. PREPARED BY.

The permit was prepared by:

Loretta Reiber, P.E.
NPDES Branch, Water Division

4. DATE PREPARED.

The final permit was prepared on 03/31/2007.

5. PREVIOUS PERMIT ACTIVITY.

Effective Date: 12/01/2001
Modification Date: N/A
Expiration Date: 11/30/2006

The permittee submitted a permit renewal application on 05/30/2006. It is proposed that the current NPDES permit be reissued for a 5-year term in accordance with regulations promulgated at 40 CFR Part 122.46(a).

6. **RECEIVING STREAM SEGMENT AND DISCHARGE LOCATION.**

The monitoring outfall is located at the following coordinates:

Latitude: 34° 25' 49" Longitude: 92° 50' 00"

The receiving waters named:

via a pipeline from the facility to the Ouachita River at Latitude: 34° 25' 41"; Longitude: 92° 51' 31" in Segment 2F of the Ouachita River Basin. The receiving stream is a Water of the State classified for primary contact recreation, raw water source for public, industrial, and agricultural water supplies, propagation of desirable species of fish and other aquatic life, and other compatible uses.

7. **303(d) LIST AND ENDANGERED SPECIES CONSIDERATIONS.**

a. **303(d) List**

The receiving stream is not listed on the 303(d) list. Therefore no permit action is needed.

b. **Endangered Species:**

No comments on the application were received from the U.S. Fish and Wildlife Service (USF&WS). The draft permit and Fact Sheet were be sent to the USF&WS for their review.

The Arkansas Natural Heritage Commission stated that the following species of concern are present in the receiving stream near the location of the outfall: *Arkansia wheeleri* – Ouachita rock pocketbook – federal concern (endangered); *Lampsilis abruputa* – pink mucket – federal concern (endangered); *Ligumia recta* – black sandshell – state concern; and *Toxolasma lividus* – purple lilliput – state concern. ADEQ has concluded that issuance of this NPDES permit will have no effect on any endangered or candidate species or the critical habitat.

8. **OUTFALL AND TREATMENT PROCESS DESCRIPTION.**

The following is a description of the facility described in the application:

Expected Average Flows: Outfall 001: 1.15 MGD.
Internal Outfall 01A: 1.12 MGD.
Internal Outfall 01B: 0.03 MGD.

The expected average flows are used in this permit due to lack of actual discharges. The permittee began normal operations in April 2006.

Type of Treatment: Outfall 001: none.
 Internal Outfall 01A: none.
 Internal Outfall 01B: filter system and oil/water separator.

Discharge Description: Outfall 001: cooling tower blowdown & low volume waste water.
 Internal Outfall 01A: cooling tower blowdown.
 Internal Outfall 01B: low volume waste water.

9. APPLICANT ACTIVITY.

Under the standard industrial classification (SIC) code 4911, the applicant's activities are the operation of steam electric power generating station

10. SEWAGE SLUDGE PRACTICES.

Sludge is thickened with polymer and dewatered with a filter press prior to transfer to an off site landfill for disposal.

11. PERMIT CONDITIONS.

The Arkansas Department of Environmental Quality has made a determination to issue a permit for the discharge described in the application. Permit requirements are based on NPDES regulations (40 CFR Parts 122, 124, and Subchapter N) and regulations promulgated pursuant to the Arkansas Water and Air Pollution Control Act (Act 472 of 1949, as amended, Ark. Code Ann. 8-4-101 et. seq.).

a. **Final Effluent Limitations**

Outfall 001 - cooling tower blowdown and low volume waste water

1. **Conventional and/or Toxic Pollutants**

<u>Effluent Characteristics</u>	<u>Discharge Limitations</u>				<u>Monitoring Requirements</u>	
	Mass (lbs/day, unless otherwise specified)		Concentration (mg/l, unless otherwise specified)		Frequency	Sample Type
	Monthly Avg.	Daily Max	Monthly Avg.	Daily Max		
Flow (MGD)	N/A	N/A	Report	Report	once/day	totalizing meter
Total Suspended Solids (TSS)	288	959	30	100	once/week	grab
Oil and Grease (O & G)	96	144	10	15	once/week	grab
pH	N/A	N/A	<u>Minimum</u> 6.0 s.u.	<u>Maximum</u> 9.0 s.u.	once/week	grab
Acute Biomonitoring	N/A	N/A	See # 14 below		once/quarter	24-hr composite

2. **Solids, Foam, and Free Oil:** There shall be no discharge of distinctly visible solids, scum, or foam of a persistent nature, nor shall there be any formation of slime, bottom deposits, or sludge banks. There shall be no visible sheen due to the presence of oil (Sheen means an iridescent appearance on the surface of the water).

b. **Final Effluent Limitations**

Internal Outfall 01A - cooling tower blowdown

1. **Conventional and/or Toxic Pollutants**

<u>Effluent Characteristics</u>	<u>Discharge Limitations</u>				<u>Monitoring Requirements</u>	
	Mass (lbs/day, unless otherwise specified)		Concentration (mg/l, unless otherwise specified)		Frequency	Sample Type
	Monthly Avg.	Daily Max	Monthly Avg.	Daily Max		
Flow (MGD)	N/A	N/A	Report	Report	once/day	totalizing meter
Free Available Chlorine (FAC)	0.16	0.39	0.2	0.5	once/week	grab
pH	N/A	N/A	<u>Minimum</u> 6.0 s.u.	<u>Maximum</u> 9.0 s.u.	once/week	grab

c. **Final Effluent Limitations**

Internal Outfall 01B - low volume waste water

1. **Conventional and/or Toxic Pollutants**

<u>Effluent Characteristics</u>	<u>Discharge Limitations</u>				<u>Monitoring Requirements</u>	
	Mass (lbs/day, unless otherwise specified)		Concentration (mg/l, unless otherwise specified)		Frequency	Sample Type
	Monthly Avg.	Daily Max	Monthly Avg.	Daily Max		
Flow (MGD)	N/A	N/A	Report	Report	once/day	calculated
Total Suspended Solids (TSS)	7.5	25	30	100	once/month	grab
Oil and Grease (O & G)	3.7	5	15	20	once/month	grab
pH	N/A	N/A	<u>Minimum</u> 6.0 s.u.	<u>Maximum</u> 9.0 s.u.	once/week	grab

12. **BASIS FOR PERMIT CONDITIONS.**

The following is an explanation of the derivation of the conditions of the permit and the reasons for them or, in the case of notices of intent to deny or terminate, reasons suggesting the decisions as required under 40 CFR Part 124.7 (48 FR 1413, April 1, 1983).

Technology-Based versus Water Quality-Based Effluent Limitations and Conditions

Following regulations promulgated at 40 CFR Part 122.44(1)(2)(ii), the permit limits are based on either technology-based effluent limits pursuant to 40 CFR Part 122.44(a) or on State water quality standards and requirements pursuant to 40 CFR Part 122.44(d), whichever are more stringent.

A. **Technology-Based Effluent Limitations and/or Conditions**

Regulations promulgated at 40 CFR Part 122.44(a) require technology-based effluent limitations to be placed in NPDES permits based on effluent limitations guidelines where applicable, on Best Professional Judgment (BPJ) in the absence of guidelines, or on a combination of the two.

(1) **Applicable Effluent Limitations Guidelines**

Discharges from facilities of this type are covered by Federal effluent limitations guidelines promulgated under 40 CFR Part 423 Steam Electric Power Generating Point Source Category.

Outfall 001

The TSS concentration limits were based on the allowable concentrations at Internal Outfall 01B and the judgment of the permit writer. They have remain unchanged from the current permit.

Internal Outfall 01A - Cooling Tower Blowdown

The permittee has provided ADEQ with the Material Safety Data Sheets for the chemicals used in the cooling tower. No chromium or zinc is present in any of the chemicals. The permit will forbid the use of chemicals in the cooling tower which contain chromium or zinc without first modifying this permit.

Effluent limitations for Free Available Chlorine (FAC) are based on 40 CFR Part 423.15(j). The calculation of the loadings (lbs per day) uses an expected average flow of 1.12 MGD and the following equation (See below). However; based on 40 CFR 423.13(d)(2) FAC can be discharged 2 hours/day, therefore;

$$\text{Mass limits (lbs/day)} = (\text{Concentration (mg/l)} \times \text{Flow (MGD)} \times 8.34) * (2/24)$$

The pH limits of 6.0 – 9.0 s.u. are based on 40 CFR Part 423.15(a).

Internal Outfall 01B – Low Volume Waste Water

Effluent limitations for Total Suspended Solids (TSS) and oil and grease are based on 40 CFR Part 423.15(c). The effluent limitation for pH is based on 40 CFR Part 423.15(a). The calculation of the loadings (lbs per day) uses an expected average flow of 0.03 MGD and the following equation (See below).

$$\text{lbs/day} = \text{Concentration (mg/l)} \times \text{Flow (MGD)} \times 8.34$$

The pH limits of 6.0 – 9.0 s.u. are based on 40 CFR Part 423.15(a).

(2) Stormwater runoff

Effluent limitations guidelines have not been promulgated for discharges of this sort. Therefore under the authority of Section 402 (a) (1) of the Clean Water Act and State laws, the State has developed a permit on a case-by-case basis. Stormwater pollution prevention plan requirements are included. The permittee's stormwater discharges are currently covered under the General Permit for Stormwater Discharges Associated with Industrial Activity (tracking number ARR00C394). Upon issuance of the final permit, the permittee's coverage under the general permit will be terminated.

B. State Water Quality Numerical Standards Based Limitations

The pH and the Oil and Grease limitations at Outfall 001 are based on Chapter 5, Sections 2.504 and 2.510 of APCEC Regulation No. 2 as amended, respectively. The calculation of the loadings (lbs per day) uses an expected average flow of 1.15 MGD and the following equation (See below).

$$\text{lbs/day} = \text{Concentration (mg/l)} \times \text{Flow (MGD)} \times 8.34$$

Temperature limits have not been included for Outfall 001 because the effluent could not reach a temperature which would cause an exceedance of the water quality standard (86.0°F for the Typical Gulf Coastal Ecoregion) in Section 2.502 of APCEC Regulation 2 nor raise the temperature of the receiving stream in excess of 5° F. Field sampling records for Station OUA0006A (Ouachita River near Malvern) state that the lowest and the highest recorded temperatures for the time period 01/14/1992 through 10/10/2006 are 3° C (37.4° F on 01/10/2001) and 29° C (84.2° F on 09/09/1992). The allowable effluent temperatures are calculated as follows using the lowest and the highest recorded temperatures.

$$T_e = \{[(Q_e + 7Q_{10}) * T_d] - [7Q_{10} * T_b]\} / Q_e$$

Where:

Q_e = effluent flow = 1.78 cfs

$7Q_{10}$ = flow of receiving stream = 246 cfs, based on "Identification and Classification of Perennial Stream of Arkansas", Arkansas Geological Commission Map

T_b = upstream temperature

T_d = downstream temperature

T_e = effluent temperature

At the lowest temperature of 37.4° F, the effluent could raise the temperature of the stream up to 5° F. Therefore, T_d is calculated as follows:

$$T_d = T_b + 5$$

$$T_d = 37.4 + 5$$

$$T_d = 42.4^\circ \text{ F}$$

The temperature of the effluent is then calculated as follows:

$$T_e = \{[(1.78 + 246) * 42.4] - [246 * 37.4]\} / 1.78$$

$$T_e = \{[10505.9] - [9200.4]\} / 1.78$$

$$T_e = 733.4^\circ \text{ F}$$

At the highest stream temperature of 84.2° F, the effluent could only raise the temperature 1.8° F because it cannot cause the stream temperature to go above 86° F.

$$T_d = 86^\circ \text{ F}$$

$$T_e = \{[(1.78 + 246) * 86] - [246 * 84.2]\} / 1.78$$

$$T_e = \{[21309.1] - [20713.2]\} / 1.78$$

$$T_e = 334.8^\circ \text{ F}$$

C. Toxics Pollutants-Priority Pollutant Scan (PPS)

(1) Post Third Round Policy and Strategy

Section 101 of the Clean Water Act (CWA) states that "...it is the national policy that the discharge of toxic pollutants in toxic amounts be prohibited..." To insure that the CWA's prohibitions on toxic discharges are met, EPA has issued a "Policy for the Development of Water Quality-Based Permit Limitations by Toxic Pollutants"(49 FR 9016-9019, 3/9/84). In support of the national policy, Region 6 adopted the "Policy for post Third Round NPDES Permitting" and the "Post Third Round NPDES Permit Implementation Strategy" on October 1, 1992. The Regional policy and strategy are designed to insure that no source will be allowed to discharge any wastewater which (1) results in instream aquatic toxicity; (2) causes a violation of an applicable narrative or numerical State water quality standard resulting in non-conformance with the provisions of 40 CFR Part 122.44(d); (3) results in the endangerment of a drinking water supply; or (4) results in aquatic bioaccumulation which threatens human health.

(2) Implementation

The State of Arkansas is currently implementing EPA's Post Third-Round Policy in conformance with the EPA Regional strategy. The 5-year NPDES permits contain technology-based effluent limitations reflecting the best controls available. Where these technology-based permit limits do not protect water quality or the designated uses, or where there are no applicable technology-based limits, additional water quality-based effluent limitations and/or conditions are included in the NPDES permits. State narrative and numerical water quality standards from APCEC Regulation No. 2 are used in conjunction with EPA criteria and other available toxicity information to determine the adequacy of technology-based permit limits and the need for additional water quality-based controls.

(3) Priority Pollutant Scan

In accordance with the regional policy ADEQ has reviewed and evaluated the effluent in evaluating the potential toxicity of each analyzed pollutant:

- a. The results were evaluated and compared to EPA's Minimum Quantification Levels (MQLs) to determine the potential presence of a respective toxic pollutant. Those pollutants which are greater than or equal to the MQLs are determined to be reasonably present in the effluent and an evaluation of their potential toxicity is necessary.
- b. Those pollutants with one datum shown as "non-detect" (ND), providing the level of detection is equal to or lower than MQL are determined to be not potentially present in the effluent and eliminated from further evaluation.
- c. Those pollutants with a detectable value even if below the MQL are determined to be reasonably present in the effluent and an evaluation of their potential toxicity is necessary.
- d. For those pollutants with multiple data values and all values are determined to be non-detect, therefore no further evaluation is necessary. However, where data set includes some detectable concentrations and some values as ND, one-half of the detection level is used for those values below the level of detection to calculate the geometric mean of the data set.

The concentration of each pollutant after mixing with the receiving stream was compared to the applicable water quality standards as established in the Arkansas Water Quality Standards, APCEC Regulation No. 2 and with the aquatic toxicity, human health, and drinking water criteria obtained from the "Quality Criteria for Water, 1986 (Gold Book)". The following expression was used to calculate the pollutant instream waste concentration (IWC):

$$IWC = ((C_e \times Q_e) + (C_b \times Q_b)) / (Q_e + Q_b)$$

Where:

IWC = instream concentration of pollutant after mixing with receiving stream ($\mu\text{g/l}$)

C_e = pollutant concentration in effluent ($\mu\text{g/l}$)

Q_e = effluent flow of facility (cfs)

C_b = background concentration of pollutant in receiving stream ($\mu\text{g/l}$)

Q_b = background flow of receiving stream (cfs)

The following values were used in the IWC calculations:

C_e = varies with pollutant. A single value from the Priority Pollutant Screen (PPS) submitted by the permittee as part of the NPDES permit application or the geometric mean of a group of data points (less than 20 data points) is multiplied by a factor of 2.13. This factor is based on EPA's Region 6 procedure (See attachment IV of

Continuing Planning Process(CPP)) to extrapolate limited data sets to better evaluate the potential toxicity for higher effluent concentrations to exceed water quality standards. This procedure employs a statistical approach which yields an estimate of a selected upper percentile value (the 95th percentile) of an effluent data set which would be expected to exceed 95% of effluent concentrations in a discharge. If 20 or more data points during the last two years are available, do not multiply by 2.13, but instead use the maximum reported values.

$Q_e = 1.15 \text{ MGD} = 1.78 \text{ cfs}$, based on expected design flow.

$C_b = 0 \text{ } \mu\text{g/l}$

$Q_b =$ (See below):

e. Aquatic Toxicity

Chronic Toxicity: Flow = 61.50 cfs, for comparison with chronic aquatic toxicity. This flow is **25** percent of the 7-day, 10-year low-flow (7Q10) for the receiving stream. The 7Q10 of 246.00 cfs is based on "Identification and Classification of Perennial Stream of Arkansas", Arkansas Geological Commission Map.

Acute Toxicity: Flow = 31.98 cfs, for comparison with acute aquatic toxicity. This flow is **13** percent of the 7Q10 for the receiving stream.

f. Bioaccumulation

Flow = 246.00 cfs, for comparison with bioaccumulation criteria. This flow is the long term average (LTA) of the receiving stream which is based on "Identification and Classification of Perennial Streams of Arkansas", Arkansas Geological Commission Map.

g. Drinking Water

Flow = 246.00 cfs, for comparison with drinking water criteria. This flow is the 7Q10 for the receiving stream.

The following values were used to determine limits for the pollutants:

Hardness = 28 mg/l, based on Attachment VI of CPP.

pH = 7.19 s.u., based on compliance data from Arkansas Water Quality Inventory Report 305(b), Water Quality Data Base System, utilizing ADEQ accumulated data for Station OUA0006A (Ouachita River near Malvern).

(4) Water Quality Standards for Metals and Cyanide

Standards for Chromium (VI), Mercury, Selenium, and Cyanide are expressed as a function of the pollutant's water-effect ratio (WER), while standards for cadmium, chromium (III), copper, lead, nickel, silver, and zinc are expressed as a function of the pollutant's WER, and as a function of hardness.

The WER is assigned a value of 1.0 unless a scientifically defensible study clearly demonstrates that a value less than 1.0 is necessary or a value greater than 1.0 is sufficient to fully protect the designated uses of the receiving stream from the toxic effects of the pollutant.

The WER approach compares bioavailability and toxicity of a specific pollutant in receiving water and in laboratory test water. It involves running toxicity tests for at least two species, measuring LC50 for the pollutant using the local receiving water collected from the site where the criterion is being implemented, and laboratory toxicity testing water made comparable to the site water in terms of chemical hardness. The ratio between site water and lab water LC50 is used to adjust the national acute and chronic criteria to site specific values.

(5) Conversion of Dissolved Metals Criteria for Aquatic Life to Total Recoverable Metal

Metals criteria established in APCEC Regulation No. 2 for aquatic life protection are based on dissolved metals concentrations and hardness values (See Page 6 of **Attachment 1**). However, Federal Regulations cited at 40 CFR 122.45(c) require that effluent limitations for metals in NPDES permits be expressed as total recoverable (See Pages 1 and 6 of **Attachment 1**). Therefore a dissolved to the total recoverable metal conversion must be implemented. This involves determining a linear partition coefficient for the metal of concern and using this coefficient to determine the fraction of metal dissolved, so that the dissolved metal ambient criteria may be translated to a total effluent limit. The formula for converting dissolved metals to total recoverable metals for streams and lakes are provided in **Attachment 2** and Region 6 Implementation Guidance for Arkansas Water Quality Standards promulgated at 40 CFR Part 131.36.

(6) Comparison of the submitted information with the water quality standards and criteria

The following pollutants were determined to be present in the effluent as reported by the permittee.

Pollutant	Concentration Reported, µg/l	MQL, µg/l
Zinc, Total Recoverable	43.0	20
Arsenic, Total Recoverable	23.9	10

However, ADEQ has determined from the information submitted by the permittee that no water quality standards or Gold Book criteria are exceeded. Therefore no permit action is necessary to maintain these standards or criteria (See **Attachment 1.**)

13. FINAL LIMITATIONS

The following effluent limitations or "report" requirements were placed in the permit based on the more stringent of the technology-based, water quality-based, or previous NPDES permit limitations:

Parameter	Water Quality-Based		Technology-Based		Previous NPDES Permit		Draft Permit	
	Monthly Avg. mg/l	Daily Max. mg/l	Monthly Avg. mg/l	Daily Max. mg/l	Monthly Avg. mg/l	Daily Max. mg/l	Monthly Avg. mg/l	Daily Max. mg/l
OUTFALL 001								
TSS	N/A	N/A	30	100	30	100	30	100
O & G	10	15	N/A	N/A	10	15	10	15
pH	6.0 - 9.0 s.u.		N/A		6 - 9 s.u.		6.0 - 9.0 s.u.	
INTERNAL OUTFALL 01A								
FAC	N/A	N/A	0.2	0.5	0.2	0.5	0.2	0.5
pH	N/A		6.0 - 9.0 s.u.		6 - 9 s.u.		6.0 - 9.0 s.u.	
INTERNAL OUTFALL 01B								
TSS	N/A	N/A	30	100	30	100	30	100
O & G	N/A	N/A	15	20	15	20	15	20
pH	N/A		6.0 - 9.0 s.u.		6 - 9 s.u.		6.0 - 9.0 s.u.	

14. BIOMONITORING.

Section 101(a)(3) of the Clean Water Act states that ".....it is the national policy that the discharge of toxic pollutants in toxic amounts be prohibited." In addition, ADEQ is required under 40 CFR Part 122.44(d)(1), adopted by reference in APCEC Regulation 6, to include

conditions as necessary to achieve water quality standards as established under Section 303 of the Clean Water Act. Arkansas has established a narrative criteria which states "toxic materials shall not be present in receiving waters in such quantities as to be toxic to human, animal, plant or aquatic life or to interfere with the normal propagation, growth and survival of aquatic biota."

Whole effluent biomonitoring is the most direct measure of potential toxicity which incorporates the effects of synergism of effluent components and receiving stream water quality characteristics. It is the national policy of EPA to use bioassays as a measure of toxicity to allow evaluation of the effects of a discharge upon a receiving water (49 Federal Register 9016-9019, March 9, 1984). EPA Region 6 and the State of Arkansas are now implementing the Post Third Round Policy and Strategy established on September 9, 1992.

Biomonitoring of the effluent is thereby required as a condition of this permit to assess potential toxicity. The biomonitoring procedures stipulated as a condition of this permit are as follows:

TOXICITY TESTS	FREQUENCY
Acute Biomonitoring	Once/quarter

Requirements for measurement frequency are based on Appendix D of the CPP.

Since 7Q10 is greater than 100 cfs (ft³/sec) and dilution ratio is greater than 100:1, acute biomonitoring requirements will be included in the permit.

The calculations for dilution used for the acute biomonitoring are as follows:

$$\text{Critical Dilution (CD)} = (Q_d / (Q_d + Q_b)) \times 100$$

$$Q_d = \text{Design Flow} = 1.15 \text{ MGD} = 1.78 \text{ cfs}$$

$$7Q_{10} = 246 \text{ cfs}$$

$$Q_b = \text{Background flow} = 0.1 \times (0.25) \times 7Q_{10} = 6.15$$

$$CD = ((1.78) / (1.78 + 6.15)) \times 100 = 22\%$$

Toxicity tests shall be performed in accordance with protocols described in "Methods for Measuring the Acute Toxicity of Effluent to Freshwater and Marine Organisms", EPA/600/4-90/027. A minimum of five effluent dilutions in addition to an appropriate control (0%) are to be used in the toxicity tests. These additional effluent concentrations are **9%, 12%, 17%, 22%, and 29%** (See **Attachment I** of CPP). The low-flow effluent concentration (critical dilution) is defined as **22%** effluent. The requirement for acute biomonitoring tests is based on the magnitude of the facility's discharge with respect to receiving stream flow. The stipulated test species are representative of organisms indigenous to the geographic area of the facility; the use of these is consistent with the requirements of

the State water quality standards. The biomonitoring frequency has been established to provide data representative of the toxic potential of the facility's discharge, in accordance with the regulations promulgated at 40 CFR Part 122.48.

Results of all dilutions as well as the associated chemical monitoring of pH, temperature, hardness, dissolved oxygen, conductivity, and alkalinity shall be reported according to EPA/600/4-90/027 and shall be submitted as an attachment to the DMR.

This permit may be reopened to require further biomonitoring studies, TRE and/or effluent limits if biomonitoring data submitted to the Department shows toxicity in the permittee's discharge. Modification or revocation of this permit is subject to the provisions of 40 CFR 122.62, as adopted by reference in APCEC Regulation No. 6. Increased or intensified toxicity testing may also be required in accordance with Section 308 of the Clean Water Act and Section 8-4-201 of the Arkansas Water and Air Pollution Control Act (Act 472 of 1949, as amended).

BIOMONITORING FREQUENCY RECOMMENDATION AND RATIONALE FOR ADDITIONAL REQUIREMENTS

Permit Number: AR0049611

Facility Name: **Hot Spring Power Company, LLC**

Previous Critical Dilution: **26%** Proposed Critical Dilution: **22%**

Date of Review: **8-11-06** Name of Reviewer: **Clem**

Number of Test Performed during previous 5 years by Species:

***Pimephales promelas* (Fathead minnow) : 7**

***Daphnia pulex* (water flea): 7**

Failed Test Dates during previous 5 years by Species:

***Pimephales promelas* (Fathead minnow) : None**

***Daphnia pulex* (water flea): None**

Previous TRE Activities:

Frequency Recommendation by Species:

***Pimephales promelas* (Fathead minnow) : four/year**

***Daphnia pulex* (water flea): four/year**

Additional Requirements (including WET Limits) Rationale/Comments Concerning Permitting:

Rationale: *Continuous Planning Process, 2000, Appendix D, E.,2.a.* "If the permittee passed all previous toxicity tests, toxicity testing frequency shall be four times a year for both species."

15. SAMPLE TYPE AND SAMPLING FREQUENCY.

Requirements for sample type and sampling frequency have been based on the current NPDES permit with the exception of the sampling frequency of TSS and O & G at Internal Outfall 01B. Those sampling frequencies have been changed to once per week because of the expected discharge flow and to match the sampling frequencies at the other outfalls.

16. CHANGES FROM THE PREVIOUSLY ISSUED PERMIT.

The permittee is responsible for reading the permit in detail carefully and becoming familiar with all the changes even they are not listed below.

1. The mailing address has changed.
2. The description of the facility location has been expanded.
3. The facility and the outfall coordinates have been corrected.
4. Parts II, III, and IV have been modified.
5. The monitoring location has been specified.
6. The Free Available Chlorine monthly average concentration limit has been corrected to match 40 CFR Part 423.
7. The compliance schedule has been deleted.
8. The 7Q10 of the receiving stream has been corrected. This has resulted in a change in the critical dilution for biomonitoring.
9. All pH ranges have been changed to 6.0 – 9.0 s.u. to ensure the required accuracy in reporting.
10. The requirement for “no discharge of distinctly visible solids, scum, or foam of a persistent nature, nor shall there be any formation of slime, bottom deposits, or sludge banks and no visible sheen due to the presence of oil” has been removed from the permit for both internal outfalls. This requirement will remain in the permit for the external outfall.
11. The sampling frequencies for TSS and O & G at Internal Outfall 01B have been changed to once per month.

17. SCHEDULE OF COMPLIANCE.

Compliance with final effluent limitations is required by the following schedule:

Compliance is required on the effective date of the permit.

18. MONITORING AND REPORTING.

The applicant is at all times required to monitor the discharge on a regular basis and report the results monthly. The monitoring results will be available to the public.

19. SOURCES.

The following sources were used to draft the permit:

- A. NPDES application No. AR0049611 received 05/30/2006.
- B. APCEC Regulation No. 2.
- C. APCEC Regulation No. 6.
- D. 40 CFR Parts 122, 125, and 423.
- E. NPDES permit file AR0049611.
- F. Discharge Monitoring Reports (DMRs).
- G. "Arkansas Water Quality Inventory Report 2000 (305B)", ADEQ.
- H. "Identification and Classification of Perennial Streams of Arkansas", Arkansas Geological Commission.
- I. Continuing Planning Process (CPP).
- J. Technical Support Document For Water Quality-based Toxic Control.
- K. Region 6 Implementation Guidance for Arkansas Water Quality Standards promulgated at 40 CFR Part 131.36.
- L. Site visit by permit writer on 07/18/2006.
- M. Field Sampling Records for Station ID #OUA0006A.
- N. Letter from Penny L. Derryberry Bray to Martin Maner, P.E., dated 03/08/2007.

20. NPDES POINT OF CONTACT.

For additional information, contact:

Loretta Reiber, P.E.
NPDES Branch, Water Division
Arkansas Department of Environmental Quality
8001 National Drive
Post Office Box 8913
Little Rock, Arkansas 72219-8913
Telephone: (501) 682-0622

ATTACHMENT 1

Priority Pollutant Scan Calculation

Permittee Hot Spring Power Co.
 Receiving Stream Ouachita River
 Permit number AR0049611 Qe for:
 Flow (Qe) 1.15 MGD Municipalities = Design Flow
 Flow (Qe) 1.78 CFS Industrial Discharges = Highest monthly average flow of the last two years
 7Q10 = 246.00 CFS
 Long Term Average = 246.00 CFS TSS for:
 Using Diffusers no Yes/No Gulf Coastal 5.5 mg/l Ouach Mount = 2 mg/l
 pH = 7.19 S.U. Ark River Valley = 3 mg/l Ozark Highlands = 2.5 mg/l
 Total Hardness 28.00 mg/l Boston Mount = 1.3 mg/l Delta = 8 mg/l
 TSS 2 mg/l
 (% of 7Q10 for Chronic) 0.25 Total Hardness for:
 (% of 7Q10 for Acute) 0.13 Arkansas River = 125 mg/l Red River = 211 mg/l
 Ouachita River = 28 mg/l St. Francis River = 103 mg/l

For the following receiving enter 0.06 in cell *C17 White River = 116 mg/l
 Mississippi, Arkansas, Red River. Gulf Coastal = 31 mg/l Ouachita Mount = 31 mg/l
 White (Below confluence with Black River) Ozark Highlands = 148 mg/l Ark River Valley = 25 mg/l
 Ouachita (below Confluence with Little Miss. Rive Boston Mount = 25 mg/l Delta = 81 mg/l

Upstream Flow (Qb) = 61.50 (Chronic) 31.98 (Acute)
 Pollutant Concentration Upstream (Cb) = 0 ug/l
 Water Effect Ratio(WER) 1.00
 Cancer Risk Level: 1.00E-05 (STATE); 1.00e-6 (EPA)

IWC = Instream concentration of pollutant after mixing with the receiving stream
 $IWC = (Ce \cdot Qe + Cb \cdot Qb) / (Qb + Qe)$
 Ce = Pollutant concentration in the effluent (ug/l) : Reported value as Total Recov

	Reported Value (Ce) (ug/l)	Ce*2.13 (ug/l)	EPA Acute (ug/l)	STATE Acute (ug/l)	IWC Acute (ug/l)	EPA Chronic (ug/l)	STATE Chronic (ug/l)	IWC Chronic (ug/l)	EPA Bioacc. (ug/l)	STATE Bioacc. (ug/l)	IWC Bioacc. (ug/l)	Violation of Acute	Chr	Bio
METALS and CYANIDE														
1. Antimony Total	0.00	0.00	9000	*****	0.00	1600	*****	0.00	4300	*****	0.00	NO	NO	NO
2. Arsenic Total	23.90	50.91	568.36	*****	2.68	299.97	*****	1.43	1.40	*****	0.37	NO	NO	NO
3. Beryllium Total	0.00	0.00	130.00	*****	0.00	5.30	*****	0.00	*****	0.076	0.00	NO	NO	NO
4. Cadmium Total*	0.00	0.00	*****	4.33	0.00	*****	1.87	0.00	*****	*****	0.00	NO	NO	NO
6. Chromium (Tri)*	0.00	0.00	*****	875.80	0.00	*****	284.10	0.00	*****	*****	0.00	NO	NO	NO
7. Chromium (hex)	0.00	0.00	*****	15.71	0.00	*****	10.58	0.00	*****	*****	0.00	NO	NO	NO
8. Copper Total*	0.00	0.00	*****	11.52	0.00	*****	8.59	0.00	*****	*****	0.00	NO	NO	NO
9. Lead Total*	0.00	0.00	*****	66.49	0.00	*****	2.59	0.00	*****	*****	0.00	NO	NO	NO
10. Mercury Total*	0.00	0.00	*****	7.41	0.00	*****	0.0120	0.00	0.15	*****	0.00	NO	NO	NO
12. Nickel Total*	0.00	0.00	*****	800.43	0.00	*****	88.89	0.00	4600	*****	0.00	NO	NO	NO
13. Selenium Total	0.00	0.00	*****	20.00	0.00	*****	5.00	0.00	*****	*****	0.00	NO	NO	NO
14. Silver Total*	0.00	0.00	*****	1.2944	0.00	*****	*****	0.00	*****	*****	0.00	NO	NO	NO
15. Thallium Total	0.00	0.00	1400	*****	0.00	40.00	*****	0.00	6.30	*****	0.00	NO	NO	NO
16. Zinc Total*	43.00	91.59	*****	98.82	4.82	*****	90.24	2.57	*****	*****	0.66	NO	NO	NO
129. Phenols, Total	0.00	0.00	*****	*****	*****	*****	*****	*****	*****	*****	0.00	NO	NO	NO
17. Cyanide Total	0.00	0.00	*****	22.36	0.00	*****	5.20	0.00	220000	*****	0.00	NO	NO	NO

* See linear partition coefficient (Page 6)

	Reported	Ce*2.13	EPA	STATE	IWC	EPA	STATE	IWC	EPA	STATE	IWC	Violation of
--	----------	---------	-----	-------	-----	-----	-------	-----	-----	-------	-----	--------------

	Value (Ce) (ug/l)	(ug/l)	Acute (ug/l)	Acute (ug/l)	Acute (ug/l)	Chronic (ug/l)	Chronic (ug/l)	Chronic (ug/l)	Bioacc. (ug/l)	Bioacc. (ug/l)	Bioacc. (ug/l)	Acute Chr	Bio	
DIOXIN														
18. 2-3-7-8-TCDD	0.00	0.00	0.01	*****	0.00	*****	*****	0.00	1.40E-07	1.00E-09	0.00	NO	NO	NO
VOLATILE COMPOUNDS														
19. Acrolein	0.00	0.00	68.00	*****	0.00	21.00	*****	0.00	780.00	*****	0.00	NO	NO	NO
20. Acrylonitrile	0.00	0.00	7550	*****	0.00	2600	*****	0.00	6.60	*****	0.00	NO	NO	NO
21. Benzene	0.00	0.00	5300	*****	0.00	*****	*****	0.00	710.00	*****	0.00	NO	NO	NO
22. Bromoform	0.00	0.00	*****	*****	0.00	*****	*****	0.00	3600.00	*****	0.00	NO	NO	NO
23. Carbon 1 Tet	0.00	0.00	35200	*****	0.00	*****	*****	0.00	44.00	*****	0.00	NO	NO	NO
24. Chlorobenzene	0.00	0.00	250.00	*****	0.00	50.00	*****	0.00	2.10E+04	*****	0.00	NO	NO	NO
25. Chlorodibromomethane	0.00	0.00	*****	*****	0.00	*****	*****	0.00	340.00	*****	0.00	NO	NO	NO
26. Chloroethane	0.00	0.00	*****	*****	0.00	*****	*****	0.00	*****	*****	0.00	NO	NO	NO
27. 2-Chloroethylvinyl ether	0.00	0.00	*****	*****	0.00	*****	*****	0.00	*****	*****	0.00	NO	NO	NO
28. Chloroform	0.00	0.00	28900	*****	0.00	1240	*****	0.00	4700.00	*****	0.00	NO	NO	NO
29. Dichlorobromomethane	0.00	0.00	*****	*****	0.00	*****	*****	0.00	220.00	*****	0.00	NO	NO	NO
30. 1-1-Dichloroethane	0.00	0.00	*****	*****	0.00	*****	*****	0.00	*****	*****	0.00	NO	NO	NO
31. 1-2-Dichloroethane	0.00	0.00	118000	*****	0.00	20000	*****	0.00	990.00	*****	0.00	NO	NO	NO
32. 1-1-Dichloroethylene	0.00	0.00	11600	*****	0.00	*****	*****	0.00	32.00	*****	0.00	NO	NO	NO
33. 1,2 Dichloropropane	0.00	0.00	23000	*****	0.00	5700	*****	0.00	*****	*****	0.00	NO	NO	NO
34. 1,3 Dichloropropylene	0.00	0.00	6060	*****	0.00	244.00	*****	0.00	1700.00	*****	0.00	NO	NO	NO
35. Ethylbenzene	0.00	0.00	32000	*****	0.00	*****	*****	0.00	29000.00	*****	0.00	NO	NO	NO
37. Methyl Chloride	0.00	0.00	*****	*****	0.00	*****	*****	0.00	*****	*****	0.00	NO	NO	NO
36. Methyl bromide	0.00	0.00	*****	*****	0.00	*****	*****	0.00	4000.00	*****	0.00	NO	NO	NO
38. Methylene chloride	0.00	0.00	*****	*****	0.00	*****	*****	0.00	16000.00	*****	0.00	NO	NO	NO
39. 1-1-2-2-Tetrachloroethane	0.00	0.00	9320	*****	0.00	2400	*****	0.00	110.00	*****	0.00	NO	NO	NO
40. Tetrachloroethylene	0.00	0.00	5280	*****	0.00	840	*****	0.00	88.50	*****	0.00	NO	NO	NO
41. Toluene	0.00	0.00	17500	*****	0.00	*****	*****	0.00	2.0E+05	*****	0.00	NO	NO	NO
42. 1,2-trans-dichloroethylene	0.00	0.00	*****	*****	0.00	*****	*****	0.00	*****	*****	0.00	NO	NO	NO
44. 1-1-2-Trichloroethane	0.00	0.00	18000	*****	0.00	9400	*****	0.00	420.00	*****	0.00	NO	NO	NO
43. 1-1-1-Trichloroethane	0.00	0.00	18000	*****	0.00	*****	*****	0.00	*****	*****	0.00	NO	NO	NO
45. Trichloroethylene	0.00	0.00	45000	*****	0.00	21900	*****	0.00	810.00	*****	0.00	NO	NO	NO
46. Vinyl Chloride	0.00	0.00	*****	*****	0.00	*****	*****	0.00	5250.00	*****	0.00	NO	NO	NO

	Reported Value (Ce) (ug/l)	Ce*2.13 (ug/l)	EPA Acute (ug/l)	STATE Acute (ug/l)	IWC Acute (ug/l)	EPA Chronic (ug/l)	STATE Chronic (ug/l)	IWC Chronic (ug/l)	EPA Bioacc. (ug/l)	STATE Bioacc. (ug/l)	IWC Bioacc. (ug/l)	Violation of Acute	Chr	Bio
ACID COMPOUNDS														
47. 2-Chlorophenol	0.00	0.00	4380	*****	0.00	*****	*****	0.00	*****	*****	0.00	NO	NO	NO
48. 2,4-Dichlorophenol	0.00	0.00	2020	*****	0.00	365	*****	0.00	*****	*****	0.00	NO	NO	NO
49. 2,4-Dimethylphenol	0.00	0.00	*****	*****	0.00	*****	*****	0.00	*****	*****	0.00	NO	NO	NO
50. 4,6-Dinitro-o-Cresol	0.00	0.00	*****	*****	0.00	*****	*****	0.00	765.00	*****	0.00	NO	NO	NO
51. 2,4-Dinitrophenol	0.00	0.00	*****	*****	0.00	*****	*****	0.00	14000	*****	0.00	NO	NO	NO
52-53. Nitrophenols	0.00	0.00	230	*****	0.00	150	*****	0.00	*****	*****	0.00	NO	NO	NO
54. 4-Chloro-3-methylphenol	0.00	0.00	30.00	*****	0.00	*****	*****	0.00	*****	*****	0.00	NO	NO	NO
55. Pentachlorophenol	0.00	0.00	2.48	10.98	0.00	6.93	6.93	0.00	82.00	*****	0.00	NO	NO	NO
56. Phenol	0.00	0.00	10200	*****	0.00	2560	*****	0.00	4600000	*****	0.00	NO	NO	NO
57. 2,4,6-Trichlorophenol	0.00	0.00	*****	*****	0.00	*****	*****	0.00	65.00	*****	0.00	NO	NO	NO
BASE/NEUTRAL COMPOUNDS														
58. Acenaphthene	0.00	0.00	1700	*****	0.00	520	*****	0.00	*****	*****	0.00	NO	NO	NO
59. Acenaphthylene	0.00	0.00	*****	*****	0.00	*****	*****	0.00	*****	*****	0.00	NO	NO	NO
60. Anthracene	0.00	0.00	*****	*****	0.00	*****	*****	0.00	110000.00	*****	0.00	NO	NO	NO
61. Benzidine	0.00	0.00	2500	*****	0.00	*****	*****	0.00	5.4E-03	*****	0.00	NO	NO	NO
62. Benzo(a) anthracene	0.00	0.00	*****	*****	0.00	*****	*****	0.00	0.310	*****	0.00	NO	NO	NO
63. Benzo(a) pyrene	0.00	0.00	*****	*****	0.00	*****	*****	0.00	0.310	*****	0.00	NO	NO	NO
64. 3,4-benzoflouranthene	0.00	0.00	*****	*****	0.00	*****	*****	0.00	0.310	*****	0.00	NO	NO	NO
65. Benzo(g,h,i)perylene	0.00	0.00	*****	*****	0.00	*****	*****	0.00	*****	*****	0.00	NO	NO	NO
66. Benzo(k) fluoranthene	0.00	0.00	*****	*****	0.00	*****	*****	0.00	0.310	*****	0.00	NO	NO	NO
67. Bis(2-chloroethoxy)methane	0.00	0.00	*****	*****	0.00	*****	*****	0.00	*****	*****	0.00	NO	NO	NO
68. Bis(2-cloroethyl) Ether	0.00	0.00	*****	*****	0.00	*****	*****	0.00	14.00	*****	0.00	NO	NO	NO
69. Bis(2-Chloroisopropyl) eth	0.00	0.00	*****	*****	0.00	*****	*****	0.00	1.7E+05	*****	0.00	NO	NO	NO
70. Bis(2-ethylhexyl)phthalate	0.00	0.00	*****	*****	0.00	*****	*****	0.00	59.00	*****	0.00	NO	NO	NO
71. 4-Bromophenyl phenyl ether	0.00	0.00	*****	*****	0.00	*****	*****	0.00	*****	*****	0.00	NO	NO	NO
72. Butylbenzy phthalate	0.00	0.00	*****	*****	0.00	*****	*****	0.00	*****	*****	0.00	NO	NO	NO
73. 2-chloronaphthalene	0.00	0.00	1600	*****	0.00	*****	*****	0.00	*****	*****	0.00	NO	NO	NO
74. 4-chlorophenyl phenyl ether	0.00	0.00	*****	*****	0.00	*****	*****	0.00	*****	*****	0.00	NO	NO	NO
75. Chrysene	0.00	0.00	*****	*****	0.00	*****	*****	0.00	0.310	*****	0.00	NO	NO	NO
76. Dibenzo(a,h)anthracene	0.00	0.00	*****	*****	0.00	*****	*****	0.00	0.310	*****	0.00	NO	NO	NO
77-79. Dichlorobenzene(1,2-1,3-1,4)	0.00	0.00	1120	*****	0.00	763	*****	0.00	2600.0	*****	0.00	NO	NO	NO
80. 3,3' Dichlorobenzidine	0.00	0.00	*****	*****	0.00	*****	*****	0.00	0.770	*****	0.00	NO	NO	NO
81. Diethyl Phthalate	0.00	0.00	*****	*****	0.00	*****	*****	0.00	1.2E+05	*****	0.00	NO	NO	NO
82. Dimethyl phthalate	0.00	0.00	*****	*****	0.00	*****	*****	0.00	2.9E+06	*****	0.00	NO	NO	NO
83. Di-n-Butyl phthalate	0.00	0.00	*****	*****	0.00	*****	*****	0.00	1.2E+04	*****	0.00	NO	NO	NO
84. 2,4-Dinitrotoluene	0.00	0.00	330	*****	0.00	230	*****	0.00	91.00	*****	0.00	NO	NO	NO
85. 2,6-Dinitrotoluene	0.00	0.00	*****	*****	0.00	*****	*****	0.00	*****	*****	0.00	NO	NO	NO
86. Di-n-octyl phthalate	0.00	0.00	*****	*****	0.00	*****	*****	0.00	*****	*****	0.00	NO	NO	NO
87. 1,2-diphenylhydrazine	0.00	0.00	270	*****	0.00	*****	*****	0.00	5.400	*****	0.00	NO	NO	NO
88. Fluoranthene	0.00	0.00	3980	*****	0.00	*****	*****	0.00	370.00	*****	0.00	NO	NO	NO
89. Fluorene	0.00	0.00	*****	*****	0.00	*****	*****	0.00	14000.000	*****	0.00	NO	NO	NO
90. Hexachlorobenzene	0.00	0.00	*****	*****	0.00	*****	*****	0.00	0.00770	*****	0.00	NO	NO	NO
91. Hexachlorobutadiene	0.00	0.00	90.00	*****	0.00	9.30	*****	0.00	500.000	*****	0.00	NO	NO	NO
92. Hexachlorocyclopentadiene	0.00	0.00	7.00	*****	0.00	5.20	*****	0.00	1.70E+04	*****	0.00	NO	NO	NO
93. Hexachloroethane	0.00	0.00	980	*****	0.00	540	*****	0.00	89.00	*****	0.00	NO	NO	NO
Hexachlorocyclohexane	0.00	0.00	2.00	2.00	0.00	0.08	0.08	0.00	*****	*****	0.00	NO	NO	NO
94. Indeno(1,2,3-cd)pyrene	0.00	0.00	*****	*****	0.00	*****	*****	0.00	0.31000	*****	0.00	NO	NO	NO
95. Isophorone	0.00	0.00	117000	*****	0.00	*****	*****	0.00	6000	*****	0.00	NO	NO	NO
96. Naphthalene	0.00	0.00	2300	*****	0.00	620	*****	0.00	*****	*****	0.00	NO	NO	NO
97. Nitrobenzene	0.00	0.00	27000	*****	0.00	*****	*****	0.00	1900.00	*****	0.00	NO	NO	NO
98. N-nitrosodimethylamine	0.00	0.00	*****	*****	0.00	*****	*****	0.00	81.00	*****	0.00	NO	NO	NO
99. N-nitrosodi-n-propylamine	0.00	0.00	*****	*****	0.00	*****	*****	0.00	*****	*****	0.00	NO	NO	NO
100. N-nitrosodiphenylamine	0.00	0.00	*****	*****	0.00	*****	*****	0.00	160.00	*****	0.00	NO	NO	NO
101. Phenanthrene	0.00	0.00	*****	*****	0.00	*****	*****	0.00	*****	*****	0.00	NO	NO	NO
103. 1,2,4-trichlorobenzene	0.00	0.00	*****	*****	0.00	*****	*****	0.00	*****	*****	0.00	NO	NO	NO

	Reported Value (Ce) (ug/l)	Ce*2.13 (ug/l)	EPA Acute (ug/l)	STATE Acute (ug/l)	IWC Acute (ug/l)	EPA Chronic (ug/l)	STATE Chronic (ug/l)	IWC Chronic (ug/l)	EPA Bioacc. (ug/l)	STATE Bioacc. (ug/l)	IWC Bioacc. (ug/l)	Violation of Acute	Chr	Bio
PESTICIDES														
104. Aldrin	0.00	0.00	3.00	3.00	0.00	*****	*****	0.00	0.00140	*****	0.00	NO	NO	NO
105. Alpha-BHC	0.00	0.00	*****	2.00	0.00	*****	0.08	0.00	1.300E-01	0.0373	0.00	NO	NO	NO
106. Beta-BHC	0.00	0.00	*****	2.00	0.00	*****	0.08	0.00	0.4600	*****	0.00	NO	NO	NO
107. Gamma-BHC	0.00	0.00	2.00	2.00	0.00	0.08	0.08	0.00	0.6300	*****	0.00	NO	NO	NO
108. Delta-BHC	0.00	0.00	*****	2.00	0.00	*****	0.08	0.00	*****	*****	0.00	NO	NO	NO
109. Chlordane	0.00	0.00	2.40	2.40	0.00	0.0043	0.0043	0.00	5.900E-03	0.0050	0.00	NO	NO	NO
110. 4,4'-DDT	0.00	0.00	1.10	1.10	0.00	0.0010	0.0010	0.00	0.0059	*****	0.00	NO	NO	NO
111. 4,4'-DDE	0.00	0.00	*****	1.10	0.00	*****	0.0010	0.00	0.0059	*****	0.00	NO	NO	NO
112. 4,4'-DDD	0.00	0.00	*****	1.10	0.00	*****	0.0010	0.00	0.0084	*****	0.00	NO	NO	NO
113. Dieldrin	0.00	0.00	2.50	2.50	0.00	0.0019	0.0019	0.00	1.400E-03	0.0012	0.00	NO	NO	NO
114. Alpha-endosulfan	0.00	0.00	0.22	0.22	0.00	0.0560	0.0560	0.00	2.00	*****	0.00	NO	NO	NO
115. Beta-endosulfan	0.00	0.00	0.22	0.22	0.00	0.0560	0.0560	0.00	2.00	*****	0.00	NO	NO	NO
116. Endosulfan sulfate	0.00	0.00	*****	0.22	0.00	*****	0.0560	0.00	2.00	*****	0.00	NO	NO	NO
117. Endrin	0.00	0.00	0.18	0.18	0.00	0.0023	0.0023	0.00	8.100E-01	*****	0.00	NO	NO	NO
118. Endrin aldehyde	0.00	0.00	*****	0.18	0.00	*****	0.0023	0.00	8.100E-01	*****	0.00	NO	NO	NO
119. Heptachlor	0.00	0.00	0.52	0.52	0.00	0.0038	0.0038	0.00	0.0021	*****	0.00	NO	NO	NO
120. Heptachlor epoxide	0.00	0.00	0.52	0.52	0.00	0.0038	0.0038	0.00	0.0011	*****	0.00	NO	NO	NO
121. PCB-1242	0.00	0.00	*****	*****	0.00	0.0140	0.0140	0.00	4.500E-04	4.00E-04	0.00	NO	NO	NO
122. PCB-1254	0.00	0.00	*****	*****	0.00	0.0140	0.0140	0.00	4.500E-04	4.00E-04	0.00	NO	NO	NO
123. PCB-1221	0.00	0.00	*****	*****	0.00	0.0140	0.0140	0.00	4.500E-04	4.00E-04	0.00	NO	NO	NO
124. PCB-1232	0.00	0.00	*****	*****	0.00	0.0140	0.0140	0.00	4.500E-04	4.00E-04	0.00	NO	NO	NO
125. PCB-1248	0.00	0.00	*****	*****	0.00	0.0140	0.0140	0.00	4.500E-04	4.00E-04	0.00	NO	NO	NO
126. PCB-1260	0.00	0.00	*****	*****	0.00	0.0140	0.0140	0.00	4.500E-04	4.00E-04	0.00	NO	NO	NO
127. PCB-1016	0.00	0.00	*****	*****	0.00	0.0140	0.0140	0.00	4.500E-04	4.00E-04	0.00	NO	NO	NO
128. Toxaphene	0.00	0.00	0.73	0.73	0.00	0.00020	0.0002	0.00	4.500E-04	0.0063	0.00	NO	NO	NO
130. Chlorpyrifos	0.00	0.00	0.083	0.083	0.00	0.041	0.041	0.00	*****	*****	0.00	NO	NO	NO

	Reported Value (Ce) (ug/l)	Ce*2.13 (ug/l)	STATE Acute (ug/l)	IWC Acute (ug/l)	STATE Chronic (ug/l)	IWC Chronic (ug/l)	STATE Bioacc. (ug/l)	IWC Bioacc. (ug/l)	Violation of Acute Chr	Bio
AWQ, Reg. No. 2										
Alpha-BHC	0.00	0.00	2.00	0.00	0.08	0.00	0.0373	0.00	NO	NO
Beta-BHC	0.00	0.00	2.00	0.00	0.08	0.00			NO	NO
Gamma-BHC	0.00	0.00	2.00	0.00	0.08	0.00			NO	NO
Delta-BHC	0.00	0.00	2.00	0.00	0.08	0.00			NO	NO
Pentachlorophenol	0.00	0.00	10.98	0.00	6.93	0.00			NO	NO
Aldrin	0.00	0.00	3.00	0.00					NO	
Chlordane	0.00	0.00	2.40	0.00	0.0043	0.00	0.005	0.00	NO	NO
4,4'-DDT	0.00	0.00	1.10	0.00	0.0010	0.00			NO	NO
4,4'-DDE	0.00	0.00	1.10	0.00	0.0010	0.00			NO	NO
4,4'-DDD	0.00	0.00	1.10	0.00	0.0010	0.00			NO	NO
Dieldrin	0.00	0.00	2.50	0.00	0.0019	0.00	0.0012	0.00	NO	NO
Alpha-endosulfan	0.00	0.00	0.22	0.00	0.0560	0.00			NO	NO
Beta-endosulfan	0.00	0.00	0.22	0.00	0.0560	0.00			NO	NO
Endosulfan sulfate	0.00	0.00	0.22	0.00	0.0560	0.00			NO	NO
Endrin	0.00	0.00	0.18	0.00	0.0023	0.00			NO	NO
Endrin aldehyde	0.00	0.00	0.18	0.00	0.0023	0.00			NO	NO
Heptachlor	0.00	0.00	0.52	0.00	0.0038	0.00			NO	NO
Heptachlor epoxide	0.00	0.00	0.52	0.00	0.0038	0.00			NO	NO
Toxaphene	0.00	0.00	0.73	0.00	0.0002	0.00	0.0063	0.00	NO	NO
Chlorpyrifos	0.00	0.00	0.083	0.00	0.0410	0.00			NO	NO
Cadmium Total*	0.00	0.00	4.33	0.00	1.87	0.00			NO	NO
Chromium (hex)	0.00	0.00	15.71	0.00	10.58	0.00			NO	NO
Copper Total*	0.00	0.00	11.52	0.00	8.59	0.00			NO	NO
Lead Total*	0.00	0.00	66.49	0.00	2.59	0.00			NO	NO
Mercury Total*	0.00	0.00	7.41	0.00	0.0120	0.00			NO	NO
Nickel Total*	0.00	0.00	800.43	0.00	88.89	0.00			NO	NO
Selenium Total	0.00	0.00	20.00	0.00	5.00	0.00			NO	NO
Silver Total*	0.00	0.00	1.2944	0.00					NO	
Zinc Total*	43.00	91.59	98.82	4.82	90.24	2.57			NO	NO
Chromium (Tri)*	0.00	0.00	875.80	0.00	284.10	0.00			NO	NO
Cyanide Total	0.00	0.00	22.36	0.00	5.20	0.00			NO	NO
Beryllium Total	0.00	0.00					0.076	0.00		NO
PCB-1242	0.00	0.00			0.0140	0.00	4.00E-04	0.00	NO	NO
PCB-1254	0.00	0.00			0.0140	0.00	4.00E-04	0.00	NO	NO
PCB-1221	0.00	0.00			0.0140	0.00	4.00E-04	0.00	NO	NO
PCB-1232	0.00	0.00			0.0140	0.00	4.00E-04	0.00	NO	NO
PCB-1248	0.00	0.00			0.0140	0.00	4.00E-04	0.00	NO	NO
PCB-1260	0.00	0.00			0.0140	0.00	4.00E-04	0.00	NO	NO
PCB-1016	0.00	0.00			0.0140	0.00	4.00E-04	0.00	NO	NO
2-3-7-8-TCDD	0.00	0.00					1E-06	0.00		NO

* See Linear Partition Coefficient (Page 6)

Linear Partition Coefficients

Metals	Streams	
	Kpo	a
Arsenic	*****	-0.73
Cadmium	*****	-1.13
Chromium(3)	*****	-0.93
Copper	*****	-0.74
Lead	*****	-0.80
Mercury	*****	-1.14
Nickel	*****	-0.57
Zinc	*****	-0.70
Silver	*****	-1.03

$Kp = Kpo \times TSS^a$

Kp = Linear Partition Coefficient
 TSS = Total Suspended Solids (mg/l)
 Kpo = found from above table
 a = found from above table

$C/Ct = 1 / (1 + Kp \times TSS \times 10^{-6})$

C / Ct = Fraction of Metal Dissolved

Metals	Kp	Streams
		C / Ct
Arsenic	289394	0.6334
Cadmium	1827663	0.2148
Chromium (3)	1763524	0.2209
Copper	622689	0.4454
Lead	1608178	0.2372
Mercury	1315903	0.2753
Nickel	330072	0.6024
Zinc	769465	0.3939
Silver	1175304	0.2985

Total Metal = Dissolved Metal / (C/Ct)

AQUATIC LIFE CRITERIA (DISSOLVED ACUTE VALUES)

Pollutant	Dissolved(ug/l)	Formula
Cadmium	0.93	WER X Conversion Factor* X e[1.128ln(hardness)]-3.828
Chromium(III)	193.46	WER X 0.316 X e[0.819ln(hardness)]+3.688
Chromium(V)	15.71	WER X 0.982 X 16
Copper	5.13	WER X 0.96 X e[0.9422ln(hardness)]-1.464
Lead	15.77	WER X Conversion Factor** X e[1.273ln(hardness)]-1.460
Mercury	2.04	WER X 0.85 X 2.4
Nickel	482.14	WER X 0.998 X e[0.8460ln(hardness)]+3.3612
Silver	0.3863	WER X 0.85 X e[1.72ln(hardness)]-6.52
Zinc	38.92	WER X 0.978 X e[0.8473ln(hardness)]+0.8604

* 1.136672 - [(ln hardness)(0.041838)]

** 1.46203 - [(ln hardness)(0.145712)]

AQUATIC LIFE CRITERIA (DISSOLVED CHRONIC VALUES)

Pollutant	Dissolved(ug/l)	Formula
Cadmium	0.40	WER X Conversion Factor* X e[0.7852ln(hardness)]-3.490
Chromium(III)	62.76	WER X 0.86 X e[0.819ln(hardness)]+1.561
Chromium(V)	10.58	WER X 10
Copper	3.82	WER X 0.96 X e[0.8545ln(hardness)]-1.465
Lead	0.61	WER X Conversion Factor** X e[1.273ln(hardness)]-4.705
Nickel	53.60	WER X 0.997 X e[0.8460ln(hardness)]+1.1645
Zinc	35.54	WER X 0.986 X e[0.8473ln(hardness)]+0.7614

* 1.101672 - [(ln hardness)(0.041838)]

** 1.46203 - [(ln hardness)(0.145712)]



ARKANSAS
Department of Environmental Quality

**RESPONSE TO COMMENTS
FINAL PERMITTING DECISION**

Response to comments received on the subject draft permit in accordance with regulations promulgated at 40 CFR Part 124.17 are as follows:

Permit No.: AR0049611

Applicant: Hot Spring Power Company, LLC

Prepared by: Loretta Reiber, P.E.

Public Notice Date: The draft permit was publicly noticed on or about February 9, 2007.

Date Prepared: March 13, 2007

The following comments have been received on the draft permit:

Letter from Ms. Pennye L. Derryberry Bray to Mr. Martin Maner, P.E. dated March 8, 2007. (Issue #1)

Letter from Ms. Cindy Osborne to Ms. Loretta Reiber, P.E. dated March 19, 2007. (Issue #2)

ISSUE #1

The monitoring frequency for Outfall 01B should be changed back to once per quarter. There have not been any instances of non-compliance at this outfall to warrant a frequency of once per week.

RESPONSE #1

Staff agrees in part. It is the Department's understanding that the facility has only been in normal operations since April 2006. The increase in frequency was also due in part to the need for additional information concerning this outfall. The Department will change the monitoring frequency for TSS and O & G to once per month at Outfall 01B because it is an internal outfall. Also, the following condition will be added to Part III of the permit:

"After two years of data (i.e., a minimum of 24 data points) demonstrating compliance with the TSS and the O & G limits at Outfall 01B, the permittee may request a reduction in the monitoring frequency from once per month to once per quarter. This request must be made in writing and must be approved by the Department prior to taking place. The reductions in frequency will be made without a major permit modification."

ISSUE #2

The Arkansas Natural Heritage Commission stated that the following species of concern are known to occur within five miles downstream of the outfall location:

Arkansia wheeleri – Ouachita rock pocketbook – federal concern (endangered)

Lampsilis abrputa – pink mucket – federal concern (endangered)

Ligumia recta – black sandshell – state concern

Toxolasma lividus – purple lilliput – state concern

RESPONSE #2

The comments from the Arkansas Natural Heritage Commission were received after the end of the public comment period. They are being addressed in this response to comments only because no changes are being made to the permit.

Staff agrees. The following language has been added to Item #7.b of the Fact Sheet.

“The Arkansas Natural Heritage Commission stated that the following species of concern are present in the receiving stream near the location of the outfall: *Arkansia wheeleri* – Ouachita rock pocketbook – federal concern (endangered); *Lampsilis abrputa* – pink mucket – federal concern (endangered); *Ligumia recta* – black sandshell – state concern; and *Toxolasma lividus* – purple lilliput – state concern. ADEQ has concluded that issuance of this NPDES permit will have no effect on any endangered or candidate species or the critical habitat.”

ADEQ COMMENT

The sample type for flow at Outfall 01B has been changed to “calculated” to reflect the requirement of the previously issued permit.